

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月24日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	6.18	6.31	61.68	1.27	18.48	12.19	0.97	74905.80
1	7.37	4.23	55.32	1.48	20.32	10.39	0.94	88112.64
2	9.56	2.33	40.62	3.01	18.11	11.16	0.94	84310.89
3	10.43	1.58	47.93	2.76	18.25	11.26	0.93	83201.28
4	10.73	1.92	46.68	2.37	18.50	11.15	0.92	83888.46
5	7.34	11.92	51.00	1.03	19.75	11.00	0.94	86423.57
6	10.29	3.47	30.54	2.84	16.20	11.44	0.94	82474.61
7	8.72	1.15	37.17	2.06	17.05	11.53	0.95	80788.28
8	9.63	1.23	33.16	2.24	17.34	11.26	0.97	82166.60
9	9.12	1.39	28.94	2.65	15.93	11.65	0.97	77621.77
10	4.57	1.27	36.45	1.68	16.76	11.66	0.96	81488.37
11	6.85	2.08	49.68	1.35	17.73	11.68	0.97	80043.09
12	9.85	2.22	47.45	2.17	16.38	11.87	0.97	77831.70
13	7.53	2.45	40.30	1.33	17.23	11.62	0.96	80624.58
14	7.27	4.49	33.45	1.67	16.89	11.80	0.97	77481.62
15	8.19	3.12	35.24	1.89	16.70	11.42	0.96	78281.41
16	10.90	5.35	32.98	3.77	14.23	11.41	0.97	77149.06
17	7.29	2.67	51.26	1.40	17.60	11.08	0.97	83122.32
18	8.39	5.01	54.88	0.94	19.21	10.60	0.97	87598.47
19	8.83	5.50	46.95	1.68	17.48	11.10	0.97	84889.67
20	10.80	7.17	44.01	2.04	16.60	11.36	0.96	82047.33
21	10.94	5.27	53.40	2.14	16.94	11.26	0.93	81955.48
22	11.60	2.93	62.48	1.25	19.04	10.72	0.94	86727.25
23	9.26	3.29	47.68	2.04	16.65	11.68	0.94	81127.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.82	3.68	44.55	1.96	17.47	11.35	0.95	81844.22
最 大 值	11.60	11.92	62.48	3.77	20.32	12.19	0.98	88112.64
發生時間	22	5	22	16	1	0		1
最 小 值	4.57	1.15	28.94	0.94	14.23	10.39	0.92	74905.80
發生時間	10	7	9	18	16	1		0
零點偏移(率)	-0.01 %	-0.08 %	-0.00 %	-0.01 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	0.70 %	0.44 %	0.27 %		0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月24日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.27	3.50	57.69	2.35	17.77	11.00	0.97	79893.79
1	5.25	5.60	54.74	2.66	18.57	10.92	0.97	80208.67
2	1.94	5.52	56.89	3.38	15.63	11.79	0.98	75169.35
3	6.50	1.06	46.10	3.77	16.44	11.40	0.98	78581.67
4	6.43	4.66	45.08	3.44	17.09	11.06	0.98	80209.59
5	9.01	5.81	45.05	3.41	15.19	11.51	0.99	78190.42
6	7.49	5.14	54.64	3.13	15.14	11.72	0.98	81174.00
7	8.21	2.84	56.77	2.42	16.69	11.38	0.98	78411.24
8	9.55	1.55	64.79	1.82	17.36	11.02	0.95	80029.34
9	9.61	1.61	56.39	1.99	17.24	11.06	0.96	80219.68
10	8.21	1.85	53.43	1.87	17.94	11.07	0.97	79134.70
11	7.66	1.78	52.52	1.53	18.25	10.69	0.97	82360.92
12	7.30	9.47	47.06	2.79	15.36	11.70	0.95	76519.80
13	4.98	2.37	61.70	1.62	17.54	11.83	0.97	73691.19
14	11.40	6.46	42.33	3.37	14.99	11.44	0.97	78520.24
15	5.02	4.81	39.48	2.91	14.42	11.78	0.95	77160.19
16	0.20	1.26	39.25	1.08	17.88	10.95	0.95	80659.44
17	0.21	1.39	37.75	1.71	17.05	10.98	0.94	81033.18
18	1.78	2.71	65.45	0.95	18.92	10.81	0.95	80724.08
19	2.66	4.70	49.75	2.73	16.35	10.83	0.94	82944.03
20	0.54	5.55	54.79	2.94	15.53	11.52	0.94	78441.43
21	0.13	2.29	59.77	1.87	16.85	11.43	0.94	77395.08
22	0.15	1.94	55.81	1.93	17.89	10.69	0.96	82814.25
23	1.60	1.77	57.27	1.62	16.97	11.28	0.96	78908.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.17	3.57	52.27	2.39	16.79	11.24	0.96	79266.43
最 大 值	11.40	9.47	65.45	3.77	18.92	11.83	1.00	82944.03
發生時間	14	12	18	3	18	13		19
最 小 值	0.13	1.06	37.75	0.95	14.42	10.69	0.94	73691.19
發生時間	21	3	17	18	15	11		13
零點偏移(率)	-0.06 %	-0.02 %	-0.03 %	-0.04 %		-0.03		0.00 %
全幅偏移(率)	0.11 %	0.56 %	-0.23 %	0.19 %		-0.08		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

