

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月30日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.41	0.97	55.82	1.28	17.57	11.09	1.31	79976.06
1	8.26	0.71	52.14	1.96	18.49	11.38	1.30	81256.94
2	9.71	2.08	41.03	1.61	18.72	10.42	1.29	85054.64
3	7.98	2.32	51.22	1.33	18.10	10.55	1.29	80956.52
4	9.31	3.40	47.36	1.67	18.29	10.20	1.29	85738.29
5	3.20	10.74	58.86	1.02	17.67	10.73	1.29	88718.62
6	6.40	2.37	56.83	1.76	17.70	10.91	1.30	82555.51
7	7.45	2.03	54.11	1.99	17.53	10.83	1.31	82548.38
8	10.59	2.37	54.32	2.72	17.22	10.76	1.35	82596.97
9	10.92	2.14	54.02	2.29	17.21	10.94	1.35	81801.14
10	9.01	2.56	51.22	1.93	16.64	11.01	1.35	79161.55
11	9.04	4.30	52.28	2.17	16.14	11.09	1.34	78468.69
12	6.26	2.46	48.94	1.98	15.73	10.99	1.35	80685.60
13	6.77	2.94	52.69	2.52	15.63	11.55	1.35	75941.01
14	10.25	4.73	52.03	2.20	16.55	10.91	1.35	82198.58
15	8.66	3.67	52.26	1.94	16.37	11.05	1.34	79903.50
16	8.46	6.05	49.00	1.32	17.80	10.52	1.35	80176.14
17	10.79	7.34	43.97	1.78	17.34	10.04	1.34	83676.93
18	8.41	3.53	48.40	1.88	16.78	10.57	1.34	79389.30
19	5.36	3.75	54.46	0.93	19.48	10.01	1.33	79192.91
20	9.89	3.10	49.90	1.21	19.03	9.31	1.32	82913.92
21	8.52	2.45	32.21	1.67	16.92	9.96	1.33	79754.18
22	10.18	4.29	42.96	1.98	17.04	10.50	1.34	80733.21
23	9.60	6.14	45.59	1.73	16.27	10.77	1.34	79119.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.27	3.60	50.07	1.79	17.34	10.67	1.33	81354.94
最 大 值	10.92	10.74	58.86	2.72	19.48	11.55	1.38	88718.62
發生時間	9	5	5	8	19	13		5
最 小 值	3.20	0.71	32.21	0.93	15.63	9.31	1.29	75941.01
發生時間	5	1	21	19	13	20		13
零點偏移(率)	-0.05 %	-0.02 %	-0.10 %	0.00 %		0.00		0.30 %
全幅偏移(率)	0.00 %	0.44 %	0.55 %	-0.60 %		0.08		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月30日

報表日期: 114年04月30日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.66	1.69	64.86	1.58	17.46	10.66	1.43	73956.86
1	3.00	2.55	56.07	1.46	18.51	9.85	1.46	87308.98
2	6.45	1.47	62.88	1.81	17.53	10.17	1.45	84599.27
3	4.45	8.70	52.95	1.60	19.59	9.21	1.45	85099.83
4	8.76	1.33	49.78	1.86	18.65	9.05	1.45	87408.73
5	8.68	4.63	55.25	1.81	18.42	9.22	1.46	83994.90
6	9.45	5.09	58.54	2.16	17.66	9.08	1.46	91876.86
7	6.95	3.46	63.30	1.46	16.97	9.61	1.48	79607.84
8	7.13	1.09	61.69	1.89	16.25	9.91	1.47	78260.84
9	6.60	6.26	61.69	2.00	16.61	9.86	1.48	80381.58
10	8.70	1.86	64.56	1.99	15.95	10.14	1.47	78597.21
11	9.33	2.26	62.72	2.51	14.70	10.45	1.46	74760.30
12	5.84	1.53	63.75	1.99	15.62	10.14	1.45	77435.19
13	5.24	7.01	59.78	2.03	16.04	9.96	1.48	77952.31
14	4.01	5.70	60.35	1.83	15.84	10.22	1.48	76808.95
15	2.65	2.35	62.90	1.73	15.41	10.37	1.45	72958.41
16	4.54	5.28	56.72	1.77	16.91	9.35	1.43	78576.90
17	10.39	3.05	59.52	2.06	17.64	9.49	1.47	80731.18
18	7.20	2.95	56.99	1.78	18.05	9.12	1.48	83369.69
19	3.60	6.58	40.30	0.94	18.62	8.22	1.48	85208.63
20	8.89	2.80	54.37	2.00	16.28	9.47	1.48	79010.42
21	9.66	3.95	43.20	1.66	18.17	8.52	1.44	81965.01
22	4.68	1.58	61.60	2.18	15.18	10.23	1.43	70450.23
23	3.38	4.79	58.33	1.43	17.67	9.56	1.45	79539.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.39	3.67	58.00	1.81	17.07	9.66	1.46	80410.82
最 大 值	10.39	8.70	64.86	2.51	19.59	10.66	1.50	91876.86
發生時間	17	3	0	11	3	0		6
最 小 值	2.65	1.09	40.30	0.94	14.70	8.22	1.42	70450.23
發生時間	15	8	19	19	11	19		22
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	0.00 %		0.00		-0.20 %
全幅偏移(率)	0.02 %	0.61 %	0.08 %	-0.25 %		0.20		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								