

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月09日

報表日期: 114年08月09日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.30	7.72	61.11	1.84	16.48	11.82	1.29	69819.24
1	6.49	8.11	60.15	1.99	16.73	11.33	1.29	73330.22
2	9.27	8.75	53.15	2.32	16.10	11.43	1.26	73681.33
3	10.07	8.92	54.90	2.62	14.87	11.89	1.25	70740.36
4	8.06	9.07	58.58	2.48	14.40	12.19	1.26	68974.30
5	14.31	9.08	59.57	3.17	14.31	11.85	1.25	71104.36
6	7.66	8.91	58.75	2.76	13.96	12.00	1.26	71030.44
7	8.64	8.93	60.61	2.33	14.85	12.04	1.26	69958.82
8	9.21	8.73	63.00	2.69	13.78	11.95	1.26	71151.90
9	8.44	9.92	61.27	2.69	13.98	12.11	1.27	69381.63
10	7.05	9.91	56.11	3.08	12.87	12.18	1.25	68746.92
11	7.01	8.96	60.79	2.76	13.47	12.10	1.26	68534.09
12	7.84	8.69	54.41	2.95	13.12	11.99	1.25	69032.79
13	7.29	9.39	58.79	2.66	13.91	12.31	1.25	65703.93
14	6.41	8.68	55.81	2.15	15.54	11.69	1.25	71106.86
15	9.77	8.54	61.95	2.32	15.74	11.76	1.25	70776.83
16	8.79	9.15	62.22	2.79	15.32	12.01	1.25	69303.48
17	7.71	9.32	70.93	2.59	14.48	12.41	1.25	66657.07
18	8.68	9.18	57.76	1.96	15.74	11.99	1.25	68718.14
19	6.50	8.97	50.73	1.99	15.32	11.87	1.25	70272.65
20	5.23	8.91	50.84	1.84	15.63	11.79	1.25	70489.77
21	4.87	10.73	57.18	3.11	16.09	11.71	1.25	71154.29
22	2.33	8.97	46.77	4.34	14.77	11.81	1.25	70932.78
23	0.81	9.32	56.80	3.37	15.54	12.22	1.25	67852.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.49	9.04	58.01	2.62	14.88	11.94	1.26	69935.63
最 大 值	14.31	10.73	70.93	4.34	16.73	12.41	1.29	73681.33
發生時間	5	21	17	22	1	17		2
最 小 值	0.81	7.72	46.77	1.84	12.87	11.33	1.24	65703.93
發生時間	23	0	22	0	10	1		13
零點偏移(率)	-0.04 %	-0.01 %	-0.07 %	0.01 %		0.00		0.10 %
全幅偏移(率)	0.00 %	-0.65 %	-0.10 %	0.25 %		0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月09日

報表日期: 114年08月09日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.34	8.45	57.96	0.35	17.19	10.84	1.02	81733.14
1	8.37	8.43	57.60	1.71	18.31	10.84	1.02	80395.13
2	7.19	8.57	55.58	2.72	16.36	11.19	1.02	76371.63
3	8.90	8.26	56.20	2.26	17.61	10.88	1.00	81488.17
4	9.69	8.37	60.80	2.78	17.17	10.95	0.99	82087.88
5	7.48	8.53	53.55	2.84	16.44	11.22	0.99	79055.83
6	9.64	8.41	52.40	1.60	16.04	11.26	1.03	81002.04
7	9.50	8.38	58.07	3.57	16.56	11.14	1.04	80048.96
8	9.03	8.09	56.35	2.82	16.96	11.02	1.05	81712.59
9	7.85	10.81	59.59	3.57	15.51	11.48	1.04	77793.06
10	9.72	8.48	54.76	2.93	15.89	11.09	1.04	79647.44
11	9.01	8.48	53.21	3.24	15.89	11.21	1.04	79092.96
12	8.65	8.43	52.74	2.47	16.43	11.12	1.04	79635.22
13	9.06	8.91	56.19	1.91	17.76	10.94	1.04	80531.24
14	9.62	7.85	55.42	2.69	16.40	11.16	1.03	80939.12
15	8.52	8.27	54.83	2.51	15.96	11.40	1.04	78973.89
16	8.36	8.54	56.56	3.30	16.66	11.21	1.04	79917.44
17	8.75	8.22	57.60	2.94	17.15	11.14	1.03	79891.56
18	9.69	8.23	56.36	2.88	16.54	11.13	1.03	80075.69
19	7.83	8.33	56.54	2.92	16.51	11.13	1.05	80623.28
20	9.63	10.42	56.54	3.50	15.67	11.24	1.04	79352.28
21	8.50	11.37	53.74	2.97	16.62	11.10	1.04	79354.06
22	9.40	11.95	51.51	2.92	16.62	10.90	1.03	79927.76
23	8.72	11.79	53.98	2.83	17.19	10.93	1.03	80098.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.85	8.98	55.75	2.68	16.64	11.11	1.03	79989.52
最 大 值	9.72	11.95	60.80	3.57	18.31	11.48	1.06	82087.88
發生時間	10	22	4	7	1	9		4
最 小 值	7.19	7.85	51.51	0.35	15.51	10.84	0.98	76371.63
發生時間	2	14	22	0	9	0		2
零點偏移(率)	-0.07 %	-0.00 %	-0.02 %	-0.01 %		-0.07		-0.10 %
全幅偏移(率)	0.14 %	0.58 %	-0.18 %	0.02 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

