

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月21日

報表日期: 113年02月21日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.39	9.56	61.25	0.35	17.42	12.79	1.05	71287.53
1	9.29	7.84	39.03	0.62	19.67	11.28	0.99	81621.00
2	9.64	6.68	48.61	0.72	18.17	11.02	0.97	85999.33
3	10.41	6.77	48.68	1.52	16.13	11.50	0.97	83824.85
4	10.13	7.18	47.58	1.77	15.73	11.74	0.97	82565.81
5	11.32	6.13	44.30	2.12	15.68	12.06	0.97	79456.30
6	11.13	4.54	49.06	1.18	16.87	11.73	0.97	80989.03
7	9.81	9.21	55.49	0.48	17.40	11.71	0.98	80605.64
8	9.64	3.95	43.30	0.88	16.68	11.69	0.99	81659.89
9	9.83	3.72	46.23	0.83	16.82	11.70	1.00	81397.61
10	9.99	3.36	48.21	0.53	16.96	11.52	1.03	82738.13
11	10.30	3.71	39.32	0.96	15.78	11.83	1.02	80502.17
12	12.43	3.78	43.13	0.87	16.63	11.96	1.02	79312.60
13	6.85	4.08	55.54	0.82	16.45	12.63	1.03	73383.37
14	9.87	3.91	60.01	0.61	15.72	12.19	1.03	77662.26
15	8.96	4.47	36.60	1.29	16.29	11.97	1.03	79374.00
16	8.96	7.66	42.59	0.33	18.09	11.20	1.02	83925.74
17	9.72	4.51	53.30	0.40	17.21	11.28	1.02	84148.54
18	9.65	4.05	41.37	0.99	17.58	11.24	1.02	84187.07
19	6.32	6.82	41.18	0.78	16.47	11.90	1.02	79290.96
20	9.62	5.71	55.44	1.21	16.96	11.92	1.02	78745.76
21	7.04	6.23	47.39	0.45	16.79	12.53	1.02	73761.12
22	3.23	10.36	59.48	0.63	15.57	13.73	1.16	63972.26
23	7.23	8.48	57.09	0.50	17.35	12.77	1.07	71207.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.95	5.95	48.51	0.87	16.85	11.91	1.02	79234.09
最 大 值	12.43	10.36	61.25	2.12	19.67	13.73	1.28	85999.33
發生時間	12	22	0	5	1	22		2
最 小 值	3.23	3.36	36.60	0.33	15.57	11.02	0.96	63972.26
發生時間	22	10	15	16	22	2		22
零點偏移(率)	-0.32 %	0.01 %	-0.17 %	-0.08 %		-0.23		0.00 %
全幅偏移(率)	0.00 %	0.02 %	0.22 %	0.02 %		-0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月21日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.05	3.64	49.20	1.23	18.29	10.60	1.06	81995.30
1	8.71	3.91	43.88	1.80	18.36	10.64	1.06	82085.50
2	10.41	5.55	49.28	2.63	15.37	11.07	1.04	81037.85
3	9.77	2.90	50.48	2.17	15.63	11.26	1.04	79837.99
4	14.76	4.16	46.12	2.50	15.93	11.18	1.03	80252.49
5	8.76	3.49	45.26	2.23	15.35	11.38	1.02	79312.24
6	6.10	6.11	47.05	2.28	14.73	11.48	1.03	77587.84
7	9.18	3.43	46.81	2.09	15.10	11.51	1.03	77877.61
8	4.23	1.84	53.76	1.26	16.20	11.29	1.03	79638.87
9	1.28	1.58	52.95	1.91	15.36	11.10	1.05	80875.90
10	3.64	1.47	53.69	2.36	14.61	11.42	1.06	79224.33
11	8.08	1.47	51.15	2.72	14.44	11.51	1.06	78154.28
12	11.30	1.53	50.81	2.70	15.15	11.34	1.06	78513.28
13	14.55	1.85	50.21	2.98	15.29	11.31	1.06	79212.57
14	7.92	2.06	70.41	2.57	16.91	11.18	1.06	78029.24
15	7.02	1.91	60.72	2.58	14.26	11.58	1.06	78070.31
16	9.42	2.56	43.25	2.75	15.55	11.25	1.06	79561.91
17	9.08	1.90	44.62	2.39	16.33	10.97	1.06	81082.31
18	9.49	3.16	38.25	3.06	14.38	11.55	1.06	77475.46
19	9.42	4.68	40.91	3.41	13.54	11.63	1.04	77282.12
20	9.92	4.34	43.47	3.49	13.03	11.52	1.04	78166.21
21	8.17	4.70	45.12	2.96	13.53	11.51	1.04	78395.50
22	8.78	5.63	45.34	2.57	13.31	11.84	1.06	76289.52
23	10.08	9.71	43.72	2.58	13.90	11.71	1.06	77191.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.67	3.48	48.60	2.47	15.19	11.33	1.05	79047.94
最 大 值	14.76	9.71	70.41	3.49	18.36	11.84	1.08	82085.50
發生時間	4	23	14	20	1	22		1
最 小 值	1.28	1.47	38.25	1.23	13.03	10.60	1.02	76289.52
發生時間	9	10	18	0	20	0		22
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	0.00 %		0.03		-0.20 %
全幅偏移(率)	0.02 %	-0.35 %	-0.51 %	-0.00 %		-0.02		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月21日

[illegible]