

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.14	13.12	51.11	0.37	18.49	11.05	1.03	72002.80
1	9.05	12.09	59.79	0.48	19.13	10.56	1.03	74759.63
2	7.70	13.54	62.94	0.62	17.80	11.24	1.03	71219.76
3	4.64	12.41	58.99	0.25	18.97	10.93	1.02	72067.07
4	8.02	14.53	65.62	0.58	18.20	11.43	1.02	69421.63
5	1.14	15.21	58.93	0.35	18.21	11.99	1.07	66701.14
6	1.08	11.55	61.69	0.47	17.44	11.88	1.08	67107.35
7	2.83	14.26	45.99	0.58	18.26	10.52	1.02	76092.31
8	5.53	21.14	52.79	1.12	17.17	10.81	0.99	74513.78
9	9.81	9.55	42.47	2.38	14.81	10.69	1.00	69609.07
10	9.70	5.33	39.87	2.60	16.36	10.48	0.98	70986.26
11	9.43	8.79	58.32	2.39	16.58	11.45	0.99	67581.58
12	4.24	12.01	61.13	0.34	18.05	11.56	1.02	68949.11
13	4.69	11.66	46.36	0.28	18.67	10.96	0.99	72225.15
14	7.75	11.22	45.82	1.14	17.08	11.16	1.00	71937.06
15	8.65	12.54	60.45	1.04	16.85	11.59	1.00	69238.74
16	8.80	13.32	49.24	1.12	17.05	11.26	1.01	70910.11
17	7.74	11.29	50.34	0.82	17.42	11.14	0.99	71379.17
18	7.05	10.19	64.64	0.42	18.18	11.39	0.99	69176.81
19	5.35	11.20	53.31	0.34	18.87	10.87	1.29	80590.82
20	9.88	12.84	45.73	0.84	17.82	11.11	1.05	83789.91
21	10.02	14.26	56.33	0.79	17.83	11.04	1.03	84985.51
22	9.56	16.57	60.32	1.34	16.29	11.67	1.05	81340.23
23	11.37	12.02	58.22	0.75	19.24	10.70	1.02	87044.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.09	12.53	54.60	0.89	17.70	11.14	1.03	73484.58
最大值	11.37	21.14	65.62	2.60	19.24	11.99	1.85	87044.87
發生時間	23	8	4	10	23	5		23
最小值	1.08	5.33	39.87	0.25	14.81	10.48	0.97	66701.14
發生時間	6	10	10	3	9	10		5
零點偏移(率)	-0.09 %	-0.05 %	-0.02 %	-0.01 %		0.07		0.00 %
全幅偏移(率)	0.29 %	-2.12 %	0.11 %	-0.95 %		-0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.06	6.63	58.32	0.84	17.86	9.77	1.17	85811.66
1	6.72	6.79	57.35	1.10	17.55	9.79	1.17	84496.15
2	8.40	6.29	60.02	0.96	17.15	9.99	1.18	82824.00
3	8.05	7.18	55.74	1.05	17.10	9.80	1.17	83226.00
4	3.63	5.85	69.35	0.49	18.36	10.24	1.18	78903.81
5	0.48	7.38	59.35	0.57	17.42	10.87	1.17	73087.87
6	0.24	11.01	37.30	0.79	18.61	9.49	1.15	75781.93
7	0.28	9.28	40.28	0.92	16.96	9.88	1.15	77416.61
8	0.80	14.83	45.74	0.65	18.13	9.33	1.15	80958.39
9	1.01	8.41	30.25	0.58	16.80	8.39	1.14	74886.34
10	1.76	3.11	37.51	0.83	15.60	9.04	1.14	73619.17
11	1.77	9.30	38.32	0.61	16.54	9.14	1.15	72522.98
12	1.90	10.44	62.99	0.48	19.08	9.12	1.16	84318.18
13	1.64	5.14	51.26	0.90	17.36	10.39	1.15	78252.94
14	5.24	4.27	52.53	0.86	17.85	10.17	1.15	77423.65
15	11.54	13.33	54.99	2.23	16.15	10.46	1.15	78710.34
16	7.64	12.25	56.03	0.92	18.03	10.02	1.15	80147.72
17	6.82	6.60	53.96	1.10	17.01	9.63	1.15	80614.85
18	10.18	5.22	50.36	1.13	17.42	9.44	1.17	82324.56
19	6.50	4.11	53.74	0.89	17.97	9.67	1.15	80429.85
20	8.18	5.22	47.50	0.85	17.80	9.55	1.15	81818.12
21	10.22	6.25	60.01	0.93	17.85	9.58	1.15	83883.78
22	9.92	3.82	57.18	1.14	17.43	9.79	1.15	83187.26
23	9.80	5.00	52.82	1.15	16.86	9.90	1.14	81452.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.49	7.40	51.79	0.92	17.45	9.73	1.16	79837.43
最大值	11.54	14.83	69.35	2.23	19.08	10.87	1.19	85811.66
發生時間	15	8	4	15	12	5		0
最小值	0.24	3.11	30.25	0.48	15.60	8.39	1.12	72522.98
發生時間	6	10	9	12	10	9		11
零點偏移(率)	-0.09 %	0.00 %	-0.02 %	-0.01 %		0.09		0.00 %
全幅偏移(率)	-0.22 %	0.17 %	-0.24 %	-0.20 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.43	11.08	56.45	1.88	17.65	10.67	1.03	82783.04
1	2.88	10.66	45.48	1.64	17.38	10.73	1.02	78195.82
2	3.23	12.16	51.38	1.83	16.26	10.68	1.02	79736.69
3	4.44	8.50	46.10	1.82	16.56	10.43	1.02	80818.72
4	2.08	9.64	59.48	1.67	16.71	11.33	1.03	75275.44
5	0.45	12.08	71.45	2.12	15.87	12.55	1.13	67078.52
6	0.72	8.91	47.51	1.54	18.71	10.01	1.04	86801.87
7	2.15	12.43	45.11	2.33	14.76	10.63	1.03	84390.41
8	2.72	7.07	49.00	2.08	15.47	10.95	1.06	79330.91
9	2.83	8.03	42.36	2.69	13.65	10.65	1.02	72573.85
10	2.98	8.36	39.34	5.36	12.67	10.45	1.05	71451.07
11	1.59	7.78	43.58	2.14	15.33	10.41	1.03	72444.95
12	5.49	11.29	47.67	2.03	16.39	10.63	1.05	82658.02
13	2.59	2.16	55.13	2.05	15.64	11.26	1.05	78588.75
14	2.55	3.54	55.41	2.05	15.59	11.26	1.04	80116.21
15	2.21	13.87	46.20	1.95	16.33	10.40	1.03	80197.20
16	4.60	7.15	50.69	2.26	15.11	10.83	1.04	77823.57
17	9.07	13.11	53.25	2.84	14.33	11.22	1.07	77148.99
18	9.40	6.01	54.81	2.29	15.69	10.81	1.08	79140.30
19	8.61	4.40	52.05	1.89	16.78	10.67	1.07	82284.68
20	5.87	5.35	53.27	1.73	16.72	10.71	1.05	81887.59
21	8.60	7.25	50.76	1.99	16.97	10.54	1.02	83064.68
22	8.58	11.84	50.36	2.18	15.66	10.82	1.06	79936.82
23	7.91	8.69	44.67	1.98	16.93	10.22	1.07	82804.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.54	8.81	50.48	2.18	15.97	10.79	1.05	79022.18
最大值	9.40	13.87	71.45	5.36	18.71	12.55	1.50	86801.87
發生時間	18	15	5	10	6	5		6
最小值	0.45	2.16	39.34	1.54	12.67	10.01	1.01	67078.52
發生時間	5	13	10	6	10	6		5
零點偏移(率)	-0.07 %	0.00 %	-0.02 %	-0.00 %		0.05		0.00 %
全幅偏移(率)	-0.48 %	1.04 %	-1.36 %	-0.13 %		0.38		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								