

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.92	7.89	54.09	3.05	16.68	11.83	1.25	69408.66
1	2.48	7.99	57.28	2.72	17.48	11.85	1.24	69183.96
2	1.59	7.87	52.64	4.17	14.25	12.01	1.24	70575.89
3	2.09	8.00	61.79	4.55	14.09	12.47	1.25	66706.77
4	5.32	7.83	52.80	4.58	14.72	12.25	1.24	68224.67
5	2.32	7.01	61.31	2.92	14.10	12.72	1.25	63708.36
6	1.28	6.79	60.28	2.40	13.90	12.68	1.25	65530.37
7	6.96	6.87	61.58	2.26	15.17	12.07	1.26	69167.05
8	9.01	9.93	58.39	2.34	15.07	11.95	1.27	69764.80
9	8.76	9.84	61.88	2.35	15.32	11.85	1.28	70147.64
10	9.09	9.91	67.20	2.64	14.57	12.03	1.26	68816.27
11	9.14	9.80	55.10	2.62	14.91	11.88	1.27	70194.08
12	7.94	10.03	62.40	2.21	15.13	12.06	1.26	68884.72
13	5.64	10.09	58.22	2.08	14.96	11.90	1.27	70450.90
14	8.56	9.98	63.32	2.27	15.28	11.74	1.26	71235.99
15	5.97	10.05	60.73	2.43	14.55	11.87	1.25	69899.35
16	9.90	10.47	66.51	2.65	15.28	11.67	1.26	71458.08
17	8.21	9.82	60.73	2.33	15.67	11.52	1.25	71850.88
18	8.45	10.01	63.26	2.31	15.49	11.64	1.25	71252.15
19	9.37	10.02	71.29	2.30	15.53	11.68	1.26	71669.98
20	9.12	10.16	60.32	2.60	14.27	11.85	1.26	71431.06
21	7.98	9.13	62.62	2.25	14.92	11.85	1.27	70707.10
22	8.97	7.64	51.92	2.41	15.14	11.80	1.27	71115.18
23	9.32	7.68	55.30	2.41	15.03	11.94	1.28	70148.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.68	8.95	60.04	2.70	15.06	11.96	1.26	69647.18
最 大 值	9.90	10.47	71.29	4.58	17.48	12.72	1.29	71850.88
發生時間	16	16	19	4	1	5		17
最 小 值	1.28	6.79	51.92	2.08	13.90	11.52	1.23	63708.36
發生時間	6	6	22	13	6	17		5
零點偏移(率)	-0.27 %	0.00 %	-0.01 %	-0.01 %		0.00		0.10 %
全幅偏移(率)	0.81 %	-0.06 %	-0.56 %	-0.17 %		0.09		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月08日

[illegible]