

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月22日

報表日期: 115年09月22日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.59	11.70	61.91	2.38	18.04	11.34	1.09	72825.91
1	8.75	12.74	59.93	2.49	18.59	12.01	1.10	67952.46
2	11.44	11.70	54.24	2.46	18.58	11.26	1.10	73581.95
3	9.09	11.38	55.09	2.59	18.35	11.03	1.10	74331.15
4	9.77	11.71	56.70	2.70	18.50	11.25	1.11	72198.17
5	2.78	11.89	54.66	2.45	16.29	11.70	1.10	73904.52
6	10.56	12.00	54.22	3.09	16.28	11.77	1.09	70736.72
7	10.38	12.65	58.96	3.16	16.58	11.85	1.10	69868.62
8	8.48	11.61	52.93	2.65	17.46	11.32	1.09	73021.06
9	9.67	11.52	55.52	2.65	17.45	11.24	1.09	72526.26
10	11.35	12.07	59.51	2.54	17.41	11.67	1.09	69549.16
11	7.49	11.70	46.87	3.12	15.44	11.62	1.09	71314.32
12	13.77	12.17	51.29	3.21	14.38	11.75	1.09	70624.96
13	7.65	12.01	53.78	1.79	14.98	11.73	1.09	70738.97
14	9.10	12.07	64.31	1.54	16.91	11.58	1.10	70022.82
15	4.70	11.82	65.56	2.43	16.45	11.54	1.11	70844.75
16	6.17	11.95	54.13	2.63	16.32	11.59	1.11	70525.73
17	7.61	11.57	52.14	3.07	15.76	11.36	1.09	72897.02
18	9.32	11.94	62.68	3.09	16.33	11.72	1.09	70136.87
19	9.00	12.40	61.09	3.18	15.92	11.79	1.09	70103.88
20	7.02	12.48	63.20	2.91	15.61	12.17	1.10	67522.23
21	14.96	11.66	49.60	2.73	17.28	11.20	1.09	73630.25
22	5.73	11.16	51.23	3.53	17.56	10.89	1.09	74980.57
23	4.20	12.00	53.26	2.86	18.08	10.95	1.09	73991.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.65	11.91	56.37	2.72	16.86	11.51	1.10	71576.22
最 大 值	14.96	12.74	65.56	3.53	18.59	12.17	1.13	74980.57
發生時間	21	1	15	22	1	20		22
最 小 值	2.78	11.16	46.87	1.54	14.38	10.89	1.09	67522.23
發生時間	5	22	11	14	12	22		20
零點偏移(率)	-0.01 %	-0.05 %	-0.04 %	-0.03 %		-0.03	-0.01	0.20 %
全幅偏移(率)	0.32 %	-0.21 %	0.06 %	0.51 %		-0.28	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月22日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.49	12.62	58.56	0.81	18.44	10.89	0.90	83033.65
1	0.43	12.63	57.98	1.46	18.10	10.82	0.90	84028.05
2	0.39	12.73	52.37	1.53	17.39	11.31	0.90	80919.71
3	0.34	12.35	52.09	1.61	17.34	10.94	0.90	84100.84
4	0.40	11.55	54.20	1.82	17.26	11.19	0.90	82493.38
5	0.37	11.45	60.45	1.73	17.57	11.18	0.90	82657.24
6	0.32	11.35	53.83	1.53	18.19	11.13	0.89	79718.12
7	0.28	11.25	58.34	1.86	17.70	11.07	0.90	82682.34
8	0.22	11.14	59.66	1.74	18.19	10.94	0.91	82629.89
9	0.26	11.00	63.17	0.90	19.44	10.66	0.92	83564.03
10	0.17	11.41	58.15	1.49	17.32	10.94	0.91	83080.57
11	1.48	11.55	54.23	1.89	15.72	11.61	0.90	79860.73
12	3.83	11.58	46.25	2.19	15.43	11.41	0.90	81708.41
13	3.92	11.59	49.14	1.02	16.77	11.28	0.90	81634.69
14	3.21	11.44	44.69	1.42	15.40	11.36	0.90	82214.41
15	3.60	11.76	51.28	2.38	14.33	11.89	0.90	79007.57
16	0.28	11.95	43.19	2.21	13.85	12.00	0.90	79304.44
17	0.91	11.80	53.10	2.07	14.87	11.76	0.90	80445.50
18	1.20	12.04	53.87	2.18	14.97	11.83	0.90	79359.24
19	9.35	12.24	51.34	2.35	15.94	11.76	0.90	81367.85
20	7.54	12.81	66.01	2.43	15.61	11.65	0.90	81263.33
21	12.82	11.34	63.55	1.97	15.11	11.49	0.90	82044.98
22	7.66	11.08	59.77	1.71	16.70	11.07	0.90	83431.89
23	3.31	11.47	52.81	1.03	16.83	11.37	0.90	80582.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.62	11.76	54.92	1.72	16.60	11.31	0.90	81713.90
最 大 值	12.82	12.81	66.01	2.43	19.44	12.00	0.92	84100.84
發生時間	21	20	20	20	9	16		3
最 小 值	0.17	11.00	43.19	0.81	13.85	10.66	0.88	79007.57
發生時間	10	9	16	0	16	9		15
零點偏移(率)	-0.02 %	0.00 %	-0.04 %	-0.01 %		0.02	-0.01	-0.10 %
全幅偏移(率)	-0.85 %	-0.39 %	0.83 %	1.84 %		0.03	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月22日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.78	12.14	65.01	2.24	18.02	10.71	1.24	78255.64
1	6.45	12.38	59.96	2.38	20.90	10.54	1.24	76790.01
2	6.04	11.84	65.28	3.55	19.18	10.25	1.24	75039.44
3	4.53	11.80	55.61	3.34	18.60	10.33	1.27	75001.32
4	6.73	11.85	58.60	3.28	17.85	10.49	1.27	74494.86
5	5.09	11.91	62.41	3.38	18.16	10.51	1.27	74864.04
6	5.07	12.25	61.20	3.30	17.34	10.86	1.28	73272.91
7	8.33	11.85	49.49	1.91	19.43	10.29	1.26	75270.82
8	7.23	11.76	56.63	1.67	17.95	10.36	1.27	77921.57
9	10.48	11.70	57.31	1.73	19.42	10.06	1.24	80801.87
10	8.99	11.83	57.44	1.72	17.63	10.47	1.24	77628.68
11	8.74	11.99	59.07	1.58	16.55	10.78	1.27	75365.72
12	8.48	11.93	58.18	1.58	16.96	10.67	1.24	75281.02
13	10.35	12.02	58.93	1.62	16.54	10.79	1.21	74424.42
14	15.86	12.26	56.04	2.17	15.67	10.69	1.23	75355.53
15	8.31	11.63	62.56	3.10	16.45	10.10	1.23	76489.37
16	11.22	11.90	62.63	3.47	15.87	10.54	1.23	75241.10
17	10.50	11.55	65.65	3.11	17.13	10.29	1.22	76530.48
18	8.72	12.17	64.66	3.19	16.13	10.90	1.23	71651.79
19	8.43	12.19	66.54	3.13	17.06	10.83	1.22	74367.09
20	7.39	13.44	62.11	3.37	16.84	10.61	1.23	74395.97
21	7.98	12.76	63.17	3.25	16.82	10.44	1.23	75218.26
22	10.91	11.53	62.02	3.21	17.66	10.11	1.23	76211.30
23	8.85	11.52	60.73	3.44	18.61	10.05	1.24	77625.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.48	12.01	60.47	2.70	17.62	10.49	1.24	75729.11
最 大 值	15.86	13.44	66.54	3.55	20.90	10.90	1.30	80801.87
發生時間	14	20	19	2	1	18		9
最 小 值	4.53	11.52	49.49	1.58	15.67	10.05	1.18	71651.79
發生時間	3	23	7	11	14	23		18
零點偏移(率)	-0.02 %	-0.02 %	-0.00 %	0.01 %		-0.04	-0.01	0.00 %
全幅偏移(率)	-1.26 %	1.43 %	0.27 %	0.99 %		0.20	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								