

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.30	5.91	43.12	0.57	18.35	10.75	1.05	87333.78
1	4.75	3.61	61.80	0.73	19.41	11.29	1.06	82018.29
2	6.51	3.39	59.08	0.53	19.43	10.82	1.06	86063.84
3	7.61	6.22	48.72	0.56	18.78	10.74	1.06	87189.48
4	9.48	7.91	51.70	1.61	16.82	11.07	1.06	86495.34
5	9.59	8.54	60.16	1.44	16.15	11.86	1.06	80249.78
6	10.26	8.67	45.96	1.76	16.43	11.55	1.06	82577.10
7	7.49	8.46	64.21	0.64	18.17	11.86	1.07	78303.23
8	4.90	9.64	45.86	0.42	17.90	12.29	1.06	74806.95
9	2.26	9.29	39.05	0.63	16.79	12.16	1.03	76903.48
10	6.61	7.12	31.18	1.31	16.51	11.38	1.02	83919.00
11	9.97	7.48	27.27	1.65	16.09	11.29	1.03	84708.15
12	9.86	8.23	27.19	1.10	17.14	11.13	1.06	84971.90
13	9.15	5.02	43.60	1.12	17.26	11.35	1.06	82499.14
14	8.44	6.42	64.13	0.54	18.46	11.50	1.06	80706.12
15	5.04	5.75	65.68	1.05	16.70	12.31	1.09	75295.62
16	4.50	6.08	57.12	1.37	15.22	11.88	1.07	80389.58
17	4.66	4.88	52.40	1.28	17.00	11.47	1.08	82656.39
18	3.05	4.78	63.10	0.82	16.27	12.27	1.06	76501.60
19	3.56	5.38	60.12	0.84	16.65	12.21	1.06	76379.87
20	6.56	4.54	54.16	0.60	17.22	11.34	1.05	83618.58
21	9.05	5.75	56.80	1.09	17.02	11.20	1.04	84566.39
22	7.72	6.37	62.13	1.60	15.70	11.90	1.04	79759.82
23	6.69	6.14	55.65	1.11	16.58	11.87	1.04	79349.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.96	6.48	51.67	1.02	17.17	11.56	1.06	81552.60
最大值	10.26	9.64	65.68	1.76	19.43	12.31	1.14	87333.78
發生時間	6	8	15	6	2	15		0
最小值	2.26	3.39	27.19	0.42	15.22	10.74	1.02	74806.95
發生時間	9	2	12	8	16	3		8
零點偏移(率)	-0.05 %	0.00 %	-0.03 %	-0.02 %		-0.08		0.10 %
全幅偏移(率)	0.00 %	-0.25 %	-0.01 %	-0.18 %		-0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.09	3.87	52.61	2.28	16.16	11.33	1.04	78638.30
1	3.16	3.99	48.05	2.17	17.15	11.03	1.06	79978.63
2	3.57	4.04	49.71	2.03	16.36	11.21	1.06	79341.23
3	1.70	4.55	51.02	1.84	16.68	11.19	1.06	79851.57
4	10.39	5.29	43.81	3.52	15.29	11.33	1.05	79674.26
5	7.89	4.60	55.97	1.96	16.52	11.27	1.06	79489.49
6	6.44	5.84	63.51	2.11	15.55	11.87	1.05	76980.57
7	3.84	5.92	45.17	1.84	15.78	12.59	1.07	69065.98
8	2.93	5.65	49.32	2.30	15.92	12.31	1.06	70921.83
9	8.06	4.45	30.59	2.57	16.80	10.80	1.02	82755.89
10	9.73	4.89	28.13	3.59	14.76	11.15	1.02	81312.28
11	9.67	0.49	28.62	3.33	14.92	11.30	1.03	79489.86
12	9.11	6.56	37.61	1.63	17.85	10.46	1.06	83902.21
13	10.09	4.42	37.17	3.28	15.32	11.09	1.03	80111.64
14	7.80	2.93	41.66	2.63	15.97	11.37	1.02	77939.36
15	7.13	5.99	56.14	1.38	17.76	10.94	1.02	80268.83
16	8.53	3.27	46.98	1.81	18.87	9.88	1.04	86270.45
17	9.03	2.70	49.73	2.77	14.82	11.12	1.05	80550.33
18	1.99	4.29	58.79	1.85	14.78	12.78	1.06	67912.57
19	2.64	3.20	42.69	1.61	16.72	11.03	1.06	80377.52
20	3.16	3.03	51.06	1.49	16.46	11.44	1.04	77547.12
21	4.03	4.55	51.63	1.67	16.41	11.10	1.04	80134.51
22	7.13	4.54	57.82	1.99	15.96	11.23	1.04	79596.08
23	6.88	4.41	49.60	1.64	16.10	11.42	1.04	77224.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.33	4.31	46.97	2.22	16.20	11.30	1.04	78722.28
最大值	10.39	6.56	63.51	3.59	18.87	12.78	1.10	86270.45
發生時間	4	12	6	10	16	18		16
最小值	1.70	0.49	28.13	1.38	14.76	9.88	1.02	67912.57
發生時間	3	11	10	15	10	16		18
零點偏移(率)	-0.07 %	-0.02 %	-0.03 %	-0.01 %		-0.02		-0.10 %
全幅偏移(率)	0.30 %	0.27 %	-0.48 %	0.21 %		-0.29		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.15	2.67	49.38	0.68	18.52	10.10	1.04	82934.33
1	3.44	2.78	47.63	0.49	20.41	10.03	1.04	81806.46
2	5.87	2.43	49.69	0.71	17.77	10.33	1.04	82182.62
3	5.31	4.92	48.31	1.18	15.70	10.59	1.04	79704.65
4	5.63	3.54	48.36	1.13	17.72	10.02	1.04	81114.04
5	3.57	6.75	57.17	0.31	17.90	10.85	1.04	75908.41
6	0.03	7.50	58.19	0.20	18.81	11.02	1.04	75611.96
7	1.25	7.17	43.92	0.24	20.30	9.34	1.04	83640.53
8	1.51	6.81	57.50	0.36	17.52	10.60	1.04	79715.53
9	3.14	2.95	62.07	0.61	16.66	10.78	1.04	79118.39
10	6.69	2.66	53.18	1.96	14.83	10.84	1.04	80823.62
11	8.59	0.92	49.86	2.11	14.47	11.10	1.04	78646.66
12	9.07	1.69	56.08	1.13	16.68	10.76	1.04	80396.96
13	5.41	4.18	49.16	0.78	16.93	10.67	1.04	80210.04
14	9.42	4.39	49.82	1.00	17.75	10.16	1.04	83384.62
15	7.33	4.72	54.04	1.07	16.55	10.85	1.04	78905.87
16	6.75	4.00	53.96	0.96	17.00	10.42	1.04	81534.82
17	4.60	3.61	55.84	0.77	16.42	10.79	1.04	79642.08
18	1.40	5.22	59.12	0.65	16.19	11.75	1.04	72283.54
19	2.86	5.45	49.99	0.44	18.02	10.92	1.04	77112.16
20	3.27	4.11	44.87	0.38	18.11	10.00	1.04	84168.48
21	3.92	4.53	53.39	0.57	16.51	10.76	1.04	79719.75
22	1.43	4.79	62.07	0.56	15.91	11.35	1.04	75252.70
23	2.60	4.32	60.93	0.52	16.38	10.97	1.04	77327.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.63	4.25	53.11	0.78	17.21	10.62	1.04	79631.07
最大值	9.42	7.50	62.07	2.11	20.41	11.75	1.06	84168.48
發生時間	14	6	9	11	1	18		20
最小值	0.03	0.92	43.92	0.20	14.47	9.34	1.04	72283.54
發生時間	6	11	7	6	11	7		18
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	0.01 %		-0.05		0.20 %
全幅偏移(率)	0.06 %	0.11 %	0.07 %	0.27 %		-0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								