

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月14日

報表日期: 114年04月14日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.60	2.69	58.75	0.72	18.13	10.07	1.28	82268.88
1	4.74	4.50	65.06	0.63	20.19	9.79	1.29	84492.85
2	8.98	4.15	64.01	1.40	16.09	10.54	1.29	81309.16
3	13.68	8.95	47.46	2.50	15.47	10.66	1.28	81218.76
4	4.48	6.74	47.89	1.56	16.68	10.49	1.26	81199.96
5	0.44	3.70	60.34	0.40	18.88	10.54	1.26	77481.92
6	7.25	3.02	56.97	0.50	17.74	10.37	1.27	84728.12
7	6.59	3.18	60.75	0.85	17.73	11.19	1.28	78400.01
8	2.15	4.30	58.75	0.63	18.01	11.83	1.27	71360.62
9	5.68	7.05	51.09	1.11	17.93	10.63	1.27	82040.28
10	5.03	3.87	42.08	1.08	16.63	10.58	1.27	80286.06
11	6.62	5.78	41.58	1.04	17.56	10.31	1.29	81800.73
12	4.21	4.14	41.82	0.77	17.19	10.65	1.29	79404.51
13	5.55	2.39	42.04	0.66	17.73	10.62	1.29	79859.66
14	9.93	3.02	45.34	0.78	17.42	10.67	1.28	78739.54
15	5.93	3.71	43.82	0.82	17.05	10.65	1.27	78997.29
16	5.00	4.62	45.65	0.76	16.98	10.53	1.28	80285.72
17	5.78	5.36	44.64	0.41	17.95	10.12	1.29	81871.81
18	4.08	4.42	41.82	0.77	17.36	10.37	1.27	80201.88
19	0.78	2.90	53.02	0.39	17.61	10.68	1.28	78741.63
20	5.22	3.05	60.14	0.28	18.27	10.51	1.28	80853.18
21	5.44	6.04	39.50	0.71	18.06	10.18	1.29	81740.50
22	1.58	1.47	46.91	0.48	18.80	10.32	1.27	81346.85
23	3.43	2.44	51.11	0.40	19.20	10.42	1.24	80817.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.26	4.23	50.44	0.82	17.69	10.53	1.28	80393.66
最 大 值	13.68	8.95	65.06	2.50	20.19	11.83	1.31	84728.12
發生時間	3	3	1	3	1	8		6
最 小 值	0.44	1.47	39.50	0.28	15.47	9.79	1.23	71360.62
發生時間	5	22	21	20	3	1		8
零點偏移(率)	-0.12 %	-0.03 %	-0.12 %	-0.03 %		-0.09		0.20 %
全幅偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		-0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月14日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.16	2.03	47.38	2.14	16.22	10.55	1.06	82993.85
1	9.00	1.95	58.77	3.02	15.27	10.99	1.04	83760.88
2	9.21	6.60	54.16	2.42	15.27	11.04	1.05	84109.38
3	9.47	3.10	56.84	2.35	15.79	10.70	1.06	85379.58
4	8.93	7.30	52.53	2.36	17.30	10.37	1.06	87412.14
5	9.10	5.61	47.53	2.90	15.82	10.57	1.06	87540.44
6	8.15	2.75	59.37	2.60	14.88	11.39	1.05	88034.30
7	9.27	2.12	59.79	2.52	16.48	10.57	1.03	86182.65
8	8.89	2.76	58.57	2.36	16.41	10.81	1.04	84330.96
9	8.98	5.96	50.65	2.52	16.65	10.32	1.05	85653.93
10	8.35	2.34	57.96	2.25	15.93	10.49	1.05	83885.04
11	8.61	2.73	54.36	2.01	15.42	10.63	1.05	82181.32
12	8.82	3.60	55.11	2.10	16.10	10.63	1.05	81754.29
13	9.23	1.87	60.14	2.20	16.35	10.79	1.06	83265.83
14	8.88	4.27	55.31	2.79	15.72	10.96	1.04	79979.77
15	9.30	2.86	46.25	2.35	15.89	10.65	1.04	80792.46
16	10.29	5.60	50.27	2.06	16.47	10.36	1.05	84660.80
17	8.86	2.61	49.39	2.25	16.58	9.87	1.06	88099.76
18	8.05	4.34	45.90	2.67	15.10	10.34	1.04	82215.11
19	9.17	6.38	44.07	1.49	16.58	10.11	1.04	84129.13
20	9.10	3.04	44.86	1.59	17.50	10.24	1.03	86970.67
21	9.25	2.31	50.56	2.07	16.59	10.33	1.03	87001.20
22	9.80	2.95	53.12	1.80	16.04	11.01	1.05	81884.91
23	9.64	5.64	53.22	1.93	16.75	10.69	1.04	84812.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.02	3.78	52.75	2.28	16.13	10.60	1.05	84459.64
最 大 值	10.29	7.30	60.14	3.02	17.50	11.39	1.06	88099.76
發生時間	16	4	13	1	20	6		17
最 小 值	8.05	1.87	44.07	1.49	14.88	9.87	1.02	79979.77
發生時間	18	13	19	19	6	17		14
零點偏移(率)	-0.04 %	-0.00 %	-0.06 %	-0.00 %		0.01		0.10 %
全幅偏移(率)	0.14 %	0.91 %	0.19 %	0.24 %		-0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月14日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	4.99	4.31	58.93	1.16	16.78	10.04	1.55	82874.19
1	5.07	1.25	57.42	1.43	16.78	10.00	1.55	83121.87
2	10.23	1.34	57.45	2.31	15.68	10.08	1.52	83961.95
3	10.39	3.27	54.47	2.67	14.84	10.40	1.52	82540.76
4	8.71	2.60	59.81	2.09	15.83	10.24	1.52	83091.49
5	7.24	2.18	55.52	1.75	16.49	9.95	1.52	85197.50
6	8.49	6.48	53.40	1.75	16.43	10.10	1.54	85334.84
7	4.79	1.81	58.63	1.16	18.13	10.10	1.60	81696.16
8	7.82	5.60	55.95	1.94	16.37	10.43	1.61	84624.43
9	9.10	6.58	56.59	2.18	16.16	10.71	1.60	84749.72
10	9.13	3.48	58.73	1.99	16.39	10.76	1.58	85738.91
11	9.46	4.61	59.73	2.92	14.69	11.16	1.59	82511.00
12	7.62	4.99	63.52	2.42	15.51	11.06	1.57	82030.29
13	7.54	8.48	53.08	1.81	15.91	10.88	1.54	84356.74
14	3.29	1.57	60.68	1.10	16.95	10.79	1.55	80731.29
15	5.54	2.48	61.13	1.89	15.87	10.96	1.56	83798.83
16	4.89	7.41	52.76	1.24	17.60	10.09	1.54	84581.44
17	7.27	8.19	52.33	1.44	17.92	9.30	1.54	87233.65
18	6.03	2.31	55.95	1.51	17.48	9.52	1.57	88349.35
19	7.58	2.32	55.17	1.83	16.22	9.92	1.60	86397.75
20	7.72	2.74	48.19	1.48	17.88	9.23	1.58	85815.06
21	6.69	2.93	51.82	1.20	17.00	9.47	1.56	81857.01
22	6.17	5.69	59.17	1.37	17.93	9.43	1.58	83029.62
23	9.27	1.09	55.09	1.41	17.74	9.58	1.56	79654.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.29	3.90	56.48	1.75	16.61	10.17	1.56	83886.60
最 大 值	10.39	8.48	63.52	2.92	18.13	11.16	1.62	88349.35
發生時間	3	13	12	11	7	11		18
最 小 值	3.29	1.09	48.19	1.10	14.69	9.23	1.52	79654.58
發生時間	14	23	20	14	11	20		23
零點偏移(率)	0.00 %	-0.02 %	-0.07 %	0.00 %		0.04		-0.10 %
全幅偏移(率)	0.02 %	0.47 %	0.15 %	0.07 %		0.40		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								