

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.92	9.84	61.32	1.15	15.63	11.80	1.02	82126.34
1	8.13	11.88	46.16	2.52	14.42	12.04	1.02	80714.67
2	9.41	4.05	37.76	2.10	15.01	11.76	1.02	82297.36
3	8.47	5.46	44.03	1.50	15.01	12.05	1.02	80169.54
4	10.48	5.93	40.56	1.76	15.81	11.67	1.02	82517.09
5	10.01	9.77	56.12	2.22	14.76	11.66	1.02	82720.65
6	9.25	6.66	49.97	3.08	13.26	12.13	1.02	81049.52
7	8.79	5.07	60.58	1.51	15.06	11.83	1.01	82177.35
8	9.43	5.68	48.98	2.41	14.17	12.02	1.00	81020.92
9	9.14	5.00	54.95	1.63	15.57	11.68	1.02	83214.00
10	9.76	7.49	49.68	2.15	14.20	11.90	1.02	81786.04
11	7.32	7.74	58.92	1.78	14.72	12.19	1.03	79028.87
12	7.89	7.06	60.44	1.09	15.81	11.70	1.03	82563.59
13	10.26	8.97	46.72	2.11	14.38	11.84	1.03	82075.62
14	7.93	6.97	50.80	2.03	14.51	11.96	1.02	81152.14
15	8.35	7.39	51.84	2.22	14.36	11.97	1.02	81100.21
16	9.67	7.79	61.20	1.63	15.18	11.91	1.02	80736.30
17	10.34	11.42	49.19	1.82	15.16	11.70	0.99	83550.83
18	7.78	14.89	50.17	2.56	13.99	12.11	0.99	81045.47
19	9.78	12.76	53.74	2.17	14.77	11.74	0.99	83259.47
20	11.71	11.61	52.41	2.84	13.74	12.14	0.99	80670.56
21	8.64	6.95	45.26	2.62	14.04	12.09	1.00	80636.26
22	10.17	10.01	49.19	2.15	14.30	12.04	1.00	81044.74
23	8.70	9.67	48.18	2.14	14.42	12.02	1.00	81103.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.14	8.34	51.17	2.05	14.68	11.91	1.01	81573.37
最 大 值	11.71	14.89	61.32	3.08	15.81	12.19	1.05	83550.83
發生時間	20	18	0	6	4	11		17
最 小 值	7.32	4.05	37.76	1.09	13.26	11.66	0.99	79028.87
發生時間	11	2	2	12	6	5		11
零點偏移(率)	0.00 %	-0.00 %	-0.01 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.02 %	-0.38 %	-0.12 %	0.22 %		0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月07日

[illegible]