

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.06	14.48	56.83	2.99	14.78	12.20	0.96	76053.71
1	10.95	11.91	44.40	2.26	16.79	11.16	0.95	83343.67
2	10.33	12.43	47.42	2.11	15.79	11.80	0.94	79126.42
3	12.90	12.15	48.03	2.87	15.27	11.71	0.92	80468.40
4	10.02	12.92	48.81	4.03	14.40	11.78	0.92	80016.79
5	7.65	12.39	43.83	3.33	14.96	12.05	1.01	77971.09
6	9.94	13.15	57.25	2.99	14.45	12.51	1.02	74222.79
7	12.00	11.79	55.36	3.42	15.03	11.61	1.02	81077.46
8	11.61	13.14	45.42	3.08	14.26	12.16	1.02	77406.91
9	9.77	13.36	49.10	2.07	15.58	11.97	1.02	77994.78
10	12.48	12.56	60.79	2.51	15.04	11.42	1.05	83104.47
11	12.15	12.99	52.41	2.53	15.03	11.76	1.06	78855.65
12	9.76	12.87	52.45	3.06	13.82	11.89	1.05	80044.99
13	9.58	13.51	50.31	3.27	13.66	12.15	1.05	77946.45
14	10.82	12.48	58.37	3.08	14.30	11.54	1.04	82340.18
15	10.26	10.96	46.53	3.12	13.86	11.97	1.03	79370.98
16	11.94	9.62	48.12	3.01	14.14	12.24	1.03	75483.35
17	12.74	9.98	45.60	2.89	14.34	11.91	1.02	76922.84
18	11.13	11.89	50.20	2.61	15.24	11.42	1.00	81453.39
19	10.95	11.95	55.06	1.94	15.63	11.21	1.01	83932.85
20	10.50	14.05	48.06	2.70	14.71	11.82	1.04	79620.28
21	12.49	13.75	39.99	3.40	14.40	12.21	1.04	76487.23
22	13.36	13.65	48.78	2.65	14.43	12.19	1.04	76976.81
23	9.15	13.23	66.64	1.65	15.80	11.75	1.06	78780.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.86	12.55	50.82	2.82	14.82	11.85	1.01	79125.07
最大值	13.36	14.48	66.64	4.03	16.79	12.51	1.07	83932.85
發生時間	22	0	23	4	1	6		19
最小值	7.65	9.62	39.99	1.65	13.66	11.16	0.92	74222.79
發生時間	5	16	21	23	13	1		6
零點偏移(率)	-0.01 %	0.01 %	-0.12 %	0.00 %		-0.16	-0.01	0.30 %
全幅偏移(率)	1.41 %	1.90 %	0.07 %	0.21 %		-0.01	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.73	11.84	48.56	2.00	18.06	10.28	0.98	77477.61
1	13.44	11.84	44.88	3.71	17.70	10.26	0.98	77457.34
2	9.64	12.04	48.96	2.21	17.60	10.49	0.98	75099.29
3	11.05	13.08	43.08	2.93	16.76	10.31	0.98	78276.53
4	10.81	12.36	52.14	2.09	15.81	10.86	0.98	75888.40
5	12.03	12.04	52.88	2.85	16.04	10.69	0.98	77130.89
6	9.43	12.07	55.41	3.21	16.27	10.19	0.98	73159.41
7	12.63	11.19	45.35	2.76	18.75	9.61	0.98	78922.07
8	8.84	11.79	52.94	2.91	18.33	9.57	0.98	79328.90
9	10.21	11.30	51.51	2.55	17.19	9.96	0.99	77314.42
10	9.14	12.39	52.43	2.77	15.78	10.21	1.02	75362.76
11	9.42	11.63	72.72	2.16	15.06	10.81	1.02	75412.57
12	8.93	11.59	58.91	1.92	14.51	10.84	1.02	74321.93
13	10.28	11.78	59.00	1.78	15.29	10.93	1.02	75466.89
14	9.81	11.64	57.33	2.21	14.22	10.86	1.02	75695.15
15	12.21	11.96	60.87	1.64	14.70	11.14	1.02	76538.34
16	10.07	12.26	50.45	1.90	14.96	10.82	1.02	76871.93
17	15.71	12.00	50.69	1.16	15.49	11.04	1.01	74557.29
18	12.58	11.37	30.73	1.32	18.23	10.04	0.97	79892.40
19	8.98	12.04	42.68	2.30	16.71	10.92	0.96	79418.90
20	10.19	12.21	48.20	2.42	15.81	11.19	0.96	78195.11
21	9.52	12.20	49.03	2.95	14.27	11.35	0.96	75073.04
22	11.26	12.02	52.83	2.16	14.85	11.13	0.98	75983.93
23	9.29	11.91	57.95	1.19	16.79	10.84	0.99	78435.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.76	11.94	51.65	2.30	16.22	10.60	0.99	76720.03
最大值	15.71	13.08	72.72	3.71	18.75	11.35	1.03	79892.40
發生時間	17	3	11	1	7	21		18
最小值	8.84	11.19	30.73	1.16	14.22	9.57	0.94	73159.41
發生時間	8	7	18	17	14	8		6
零點偏移(率)	-0.09 %	-0.01 %	-0.06 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-1.41 %	1.32 %	-0.25 %	-0.11 %		-0.10	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.43	11.96	39.99	2.56	17.02	9.34	1.43	74869.13
1	9.12	11.78	38.85	2.33	18.61	9.03	1.43	76274.87
2	9.52	12.41	39.23	1.92	16.56	9.80	1.43	73477.67
3	9.98	12.32	43.67	2.02	16.21	9.96	1.43	73285.69
4	9.42	12.46	45.47	2.11	16.35	9.93	1.43	73892.34
5	9.73	12.50	45.53	2.20	16.34	9.92	1.43	73397.01
6	9.71	12.32	51.19	2.11	16.94	9.92	1.43	74132.77
7	8.62	11.23	48.14	2.21	15.49	10.22	1.42	70840.07
8	10.25	11.21	54.99	2.00	17.14	9.98	1.42	75562.25
9	10.45	11.60	52.56	2.30	15.20	10.35	1.42	73696.71
10	10.25	11.98	56.49	2.77	14.21	10.42	1.42	72446.85
11	10.38	11.99	55.69	3.74	13.97	10.50	1.43	71848.43
12	16.83	12.66	46.50	3.92	16.68	9.21	1.42	71079.26
13	15.02	12.80	34.02	3.70	18.96	8.38	1.41	74656.91
14	10.54	10.84	44.32	2.03	15.73	9.82	1.41	71978.03
15	13.61	11.32	54.05	2.90	15.07	9.96	1.41	71703.06
16	6.85	14.01	41.31	2.14	14.98	9.50	1.41	70173.21
17	9.09	12.29	35.79	1.41	17.70	9.03	1.41	70592.27
18	9.33	12.18	39.22	0.39	17.65	9.49	1.41	71186.91
19	9.59	12.00	48.10	2.08	14.63	10.62	1.41	70116.55
20	9.18	11.35	52.99	2.23	14.91	10.24	1.41	73583.83
21	9.78	11.27	51.38	2.17	15.41	10.26	1.40	73767.14
22	11.96	11.39	52.69	2.60	15.23	10.36	1.39	73607.83
23	8.91	11.33	56.62	1.96	15.80	10.29	1.41	73530.22
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.40	11.97	47.03	2.33	16.12	9.86	1.42	72904.13
最大值	16.83	14.01	56.62	3.92	18.96	10.62	1.45	76274.87
發生時間	12	16	23	12	13	19		1
最小值	6.85	10.84	34.02	0.39	13.97	8.38	1.38	70116.55
發生時間	16	14	13	18	11	13		19
零點偏移(率)	-0.11 %	-0.05 %	-0.03 %	-0.01 %		-0.08	-0.01	-0.10 %
全幅偏移(率)	-0.36 %	0.51 %	0.22 %	-0.06 %		0.15	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								