

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年06月26日

報表日期: 115年06月26日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	7.79	12.88	55.44	2.89	19.52	10.66	1.19	83942.50
1	9.63	12.72	57.58	2.20	20.00	10.71	1.19	83346.75
2	10.27	12.67	54.00	2.03	18.91	10.55	1.19	85726.54
3	10.68	12.83	55.30	2.44	18.73	10.70	1.19	85354.20
4	9.03	12.15	54.09	2.72	19.42	10.29	1.19	87924.47
5	8.37	12.44	54.33	2.58	18.56	10.87	1.20	83190.29
6	10.57	13.35	53.72	3.75	16.54	11.27	1.21	82601.22
7	8.88	13.05	57.64	2.03	16.72	11.51	1.23	80359.57
8	5.86	12.88	56.07	1.72	17.63	11.29	1.21	81381.63
9	10.17	13.18	49.08	1.95	17.57	11.12	1.21	82594.99
10	7.01	14.51	44.96	2.53	16.47	11.23	1.19	82151.87
11	9.85	13.43	63.77	1.89	17.39	11.60	1.20	79117.19
12	6.78	12.68	56.77	1.62	17.66	11.12	1.21	82877.18
13	11.08	13.62	42.57	2.54	16.23	11.47	1.21	81112.94
14	12.33	13.98	43.87	2.74	15.94	11.76	1.20	78623.11
15	7.84	13.20	50.28	1.87	17.47	11.55	1.23	79264.62
16	12.35	12.91	52.96	1.77	17.97	11.09	1.22	83017.20
17	5.16	12.72	57.99	1.30	18.79	11.04	1.21	82403.82
18	11.96	12.73	51.37	1.96	18.08	11.13	1.22	82221.18
19	5.23	13.02	52.33	1.63	17.62	11.34	1.20	81282.20
20	11.70	13.73	43.93	3.69	15.66	11.41	1.20	82352.23
21	13.19	12.56	45.62	2.52	17.93	10.95	1.22	83794.79
22	7.20	12.73	60.84	1.38	19.81	10.90	1.23	82198.12
23	10.47	12.32	51.33	2.38	19.69	10.57	1.23	84844.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.31	13.01	52.74	2.26	17.93	11.09	1.21	82570.14
最 大 值	13.19	14.51	63.77	3.75	20.00	11.76	1.24	87924.47
發生時間	21	10	11	6	1	14		4
最 小 值	5.16	12.15	42.57	1.30	15.66	10.29	1.18	78623.11
發生時間	17	4	13	17	20	4		14
零點偏移(率)	-0.01 %	-0.00 %	-0.21 %	0.00 %		-0.03	-0.01	0.20 %
全幅偏移(率)	0.98 %	2.37 %	0.09 %	0.83 %		-0.29	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月26日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.26	13.14	55.87	0.97	20.30	10.72	0.95	81108.61
1	5.15	12.35	50.75	1.09	20.31	10.63	0.95	82078.65
2	6.51	12.68	54.49	1.65	18.92	11.06	0.96	80632.82
3	8.31	14.20	58.74	2.01	18.42	11.27	0.94	78875.61
4	9.67	13.09	55.02	1.39	19.20	11.29	0.96	78525.53
5	8.42	12.57	54.89	1.89	18.86	10.91	0.94	81143.61
6	8.51	12.06	52.47	2.83	18.09	10.69	0.94	79730.32
7	11.81	12.08	60.23	2.13	18.44	10.67	0.95	83829.32
8	4.13	11.92	57.33	0.99	19.64	10.40	0.97	84416.31
9	16.91	12.65	41.36	2.36	18.87	10.64	0.97	84418.16
10	12.11	12.17	55.74	1.18	19.77	10.58	0.96	84004.17
11	2.03	12.74	53.17	1.13	18.46	11.16	0.95	80602.85
12	2.37	13.35	50.13	1.19	17.97	11.69	0.97	76622.40
13	1.74	12.84	46.78	1.61	17.64	11.01	0.95	82614.12
14	3.66	12.61	47.30	0.99	18.43	11.07	0.97	80836.99
15	5.69	13.13	42.70	1.18	18.51	10.61	0.98	84865.24
16	2.70	12.65	45.54	1.22	17.68	11.15	0.97	81729.87
17	2.03	12.44	47.35	0.85	19.05	10.87	0.97	82464.72
18	1.60	12.61	50.43	0.65	19.34	10.87	0.97	82027.04
19	1.21	12.68	46.72	1.08	17.97	11.11	0.96	81369.91
20	2.63	12.49	43.18	1.22	17.69	10.94	0.97	82930.13
21	5.19	12.24	46.21	0.75	19.12	10.69	0.98	83928.43
22	2.08	12.49	55.15	0.29	20.55	10.43	0.97	83809.49
23	1.90	12.90	45.71	0.23	20.68	9.94	0.95	87839.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.61	12.67	50.72	1.29	18.91	10.85	0.96	82100.15
最 大 值	16.91	14.20	60.23	2.83	20.68	11.69	0.99	87839.29
發生時間	9	3	7	6	23	12		23
最 小 值	1.21	11.92	41.36	0.23	17.64	9.94	0.94	76622.40
發生時間	19	8	9	23	13	23		12
零點偏移(率)	-0.05 %	-0.11 %	-0.05 %	-0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	0.98 %	0.53 %	1.72 %	1.11 %		-0.22	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年06月26日

報表日期: 115年06月26日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.69	12.55	48.77	3.20	21.25	8.99	1.31	74395.50
1	3.47	12.24	52.12	3.22	20.80	9.12	1.31	74158.34
2	2.78	12.31	59.58	3.26	18.45	9.67	1.31	72394.86
3	5.06	12.13	60.38	3.59	18.88	9.52	1.31	73286.29
4	5.32	12.68	57.09	3.20	20.29	9.32	1.30	75047.72
5	4.18	12.50	55.16	3.46	18.81	9.55	1.27	74134.28
6	2.48	12.35	63.29	3.48	19.08	9.73	1.27	72537.95
7	2.64	11.18	52.62	3.00	18.69	9.40	1.29	75827.23
8	3.07	11.03	57.35	3.29	19.73	9.14	1.29	74752.59
9	4.94	11.34	57.23	3.39	19.25	9.10	1.29	75931.17
10	4.11	11.01	60.31	3.36	19.08	9.48	1.28	75328.34
11	5.78	11.87	50.26	3.05	20.18	9.31	1.27	72638.41
12	3.71	11.78	60.78	2.07	19.43	9.95	1.28	69637.78
13	3.79	11.57	63.18	1.68	19.56	9.80	1.31	72635.31
14	2.15	11.34	57.37	1.50	18.00	9.90	1.30	70120.08
15	12.22	12.16	53.06	1.82	17.00	9.61	1.27	72360.85
16	8.49	11.39	57.05	1.84	19.16	9.18	1.28	74220.41
17	8.37	10.92	54.49	1.77	19.33	9.11	1.31	75790.62
18	7.81	11.40	55.19	1.66	19.39	9.21	1.31	73956.81
19	10.00	11.87	63.52	1.80	19.30	9.79	1.28	72443.66
20	10.18	12.26	60.24	1.76	17.73	9.67	1.27	74627.63
21	11.65	11.20	65.16	1.75	19.29	9.60	1.27	76998.59
22	8.64	11.11	55.09	1.71	20.75	9.17	1.26	76810.58
23	11.64	10.92	55.11	2.78	20.44	9.04	1.27	78768.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.05	11.71	57.27	2.57	19.33	9.43	1.29	74116.81
最 大 值	12.22	12.68	65.16	3.59	21.25	9.95	1.34	78768.40
發生時間	15	4	21	3	0	12		23
最 小 值	2.15	10.92	48.77	1.50	17.00	8.99	1.25	69637.78
發生時間	14	17	0	14	15	0		12
零點偏移(率)	-0.04 %	-0.01 %	-0.07 %	0.00 %		-0.05	-0.01	0.10 %
全幅偏移(率)	-0.97 %	-1.86 %	-0.40 %	-1.17 %		0.19	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								