

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.13	11.44	53.47	0.93	19.30	10.72	1.10	77156.13
1	8.69	12.00	55.80	0.84	20.66	10.77	1.10	76101.46
2	9.08	11.79	51.67	1.23	19.08	11.04	1.17	75956.03
3	7.34	13.88	52.79	1.24	18.58	11.27	1.14	74490.14
4	6.18	12.59	57.13	0.78	19.75	11.03	1.10	75162.25
5	9.33	10.91	47.57	1.44	18.65	10.97	1.07	76302.78
6	8.90	8.84	47.53	1.10	18.91	10.69	1.07	77803.88
7	9.30	10.18	49.04	1.40	18.33	10.99	1.07	75438.12
8	6.65	11.88	50.29	1.13	18.03	11.25	1.05	73641.25
9	5.56	7.28	50.67	0.78	19.33	10.91	1.06	74674.40
10	9.26	5.65	50.20	0.96	18.81	10.69	1.03	76186.58
11	6.53	6.06	55.14	0.97	18.58	11.42	1.05	71280.16
12	1.11	6.59	63.55	0.21	20.13	10.55	1.06	75839.61
13	2.28	5.77	63.93	0.52	19.40	10.54	1.05	76622.97
14	8.22	5.58	46.05	0.92	19.38	10.81	1.05	75004.77
15	7.62	5.39	38.85	0.74	19.43	10.91	1.06	74211.35
16	9.46	5.63	45.90	0.82	19.80	10.68	1.07	75759.86
17	9.18	6.99	43.37	1.47	18.34	10.81	1.04	75666.80
18	8.79	9.50	48.19	0.62	20.70	10.27	1.03	78693.59
19	8.60	8.21	46.60	0.69	20.06	10.46	1.05	77241.90
20	8.15	8.30	55.70	0.35	20.91	10.33	1.07	77628.38
21	10.16	9.27	53.59	0.53	20.25	10.23	1.06	78717.68
22	10.08	10.07	46.57	1.30	18.28	11.14	1.05	73906.11
23	7.89	11.35	44.85	1.11	18.66	11.11	1.05	73461.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.81	8.96	50.77	0.92	19.31	10.82	1.07	75706.16
最大值	10.16	13.88	63.93	1.47	20.91	11.42	1.50	78717.68
發生時間	21	3	13	17	20	11		21
最小值	1.11	5.39	38.85	0.21	18.03	10.23	1.02	71280.16
發生時間	12	15	15	12	8	21		11
零點偏移(率)	-0.01 %	0.00 %	-0.13 %	-0.04 %		0.00		0.00 %
全幅偏移(率)	0.02 %	1.71 %	-0.18 %	0.28 %		0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.00	5.09	58.01	1.31	18.23	10.20	1.05	84652.72
1	6.10	8.93	50.09	1.65	19.50	9.80	1.05	86400.33
2	4.92	3.68	56.57	1.21	17.88	10.48	1.05	83052.35
3	6.64	6.60	40.16	1.38	18.31	9.96	1.05	87081.66
4	5.40	6.11	54.49	1.24	17.92	10.03	1.05	86443.65
5	3.91	8.78	50.70	1.66	16.54	10.43	1.05	83974.85
6	1.75	3.36	61.74	1.50	16.43	11.01	1.02	83956.54
7	6.15	5.94	57.72	2.45	15.10	10.78	1.03	83215.21
8	2.83	5.62	58.30	1.05	17.81	10.41	1.06	83186.91
9	6.11	6.01	57.60	1.64	17.43	9.90	1.06	87374.71
10	6.73	2.89	51.91	2.52	15.46	10.59	1.05	83854.45
11	6.77	2.13	58.13	1.18	17.75	10.10	1.05	85185.12
12	1.74	1.41	67.03	0.92	17.64	10.36	1.05	83393.77
13	0.38	4.44	47.64	1.25	17.72	10.00	1.05	86199.58
14	4.35	3.84	48.46	1.41	17.74	9.96	1.05	86307.96
15	8.53	5.22	56.20	2.21	15.79	10.81	1.05	82244.58
16	7.32	1.79	57.55	1.28	18.14	10.16	1.10	85112.65
17	6.26	2.77	53.86	1.15	19.30	9.56	1.07	87916.20
18	7.74	3.14	49.20	1.40	18.69	9.49	1.06	89868.69
19	7.64	3.67	56.39	1.96	17.02	10.05	1.08	87077.55
20	6.29	9.53	58.08	1.10	19.28	9.23	1.05	90199.96
21	10.78	3.34	58.98	1.64	17.86	9.57	1.05	89474.48
22	17.34	13.23	57.58	2.35	17.74	9.97	1.05	87163.13
23	9.51	6.77	56.24	1.80	17.15	10.04	1.05	87344.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.30	5.18	55.11	1.55	17.60	10.12	1.05	85861.75
最大值	17.34	13.23	67.03	2.52	19.50	11.01	1.17	90199.96
發生時間	22	22	12	10	1	6		20
最小值	0.38	1.41	40.16	0.92	15.10	9.23	1.02	82244.58
發生時間	13	12	3	12	7	20		15
零點偏移(率)	-0.13 %	-0.05 %	-0.01 %	0.00 %		0.04		-0.10 %
全幅偏移(率)	0.04 %	0.30 %	-0.58 %	0.21 %		0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.92	5.70	57.12	0.67	16.31	11.26	1.05	77753.23
1	2.35	7.67	48.47	0.80	17.40	10.93	1.04	81071.76
2	5.32	6.94	53.97	1.55	14.88	11.19	1.02	77170.91
3	5.91	4.84	47.98	1.66	14.60	10.90	1.02	77677.85
4	4.86	6.20	49.35	1.32	15.22	10.78	1.03	78067.39
5	6.08	6.76	44.59	1.60	14.62	10.75	1.09	75554.42
6	4.74	9.72	45.92	2.09	13.39	10.98	1.03	76151.33
7	6.57	5.14	38.33	1.59	15.36	10.39	1.02	72454.44
8	2.19	4.61	36.19	1.61	13.25	10.60	1.01	74145.79
9	0.14	4.56	42.10	0.66	15.93	10.45	1.03	74385.29
10	5.02	13.16	33.77	1.34	14.75	9.99	1.01	75615.56
11	2.94	4.95	46.21	1.11	14.85	10.71	1.05	72667.33
12	1.15	6.99	43.71	0.49	16.53	10.04	1.02	78970.32
13	1.54	8.75	38.22	1.01	14.91	10.60	1.00	74154.75
14	4.16	2.89	42.70	1.17	15.10	10.77	0.99	73608.90
15	5.19	2.14	55.87	0.68	17.11	10.06	1.03	78171.75
16	10.04	4.70	40.06	1.46	15.70	10.17	1.05	79869.29
17	10.03	3.22	42.26	1.29	14.93	10.69	1.02	77884.06
18	10.81	2.75	49.82	1.18	16.53	10.40	1.00	80965.82
19	11.15	4.15	64.31	1.17	16.90	10.63	1.03	82585.12
20	11.32	6.11	66.29	0.94	17.19	10.25	1.03	83037.87
21	8.97	8.69	51.89	0.72	16.79	10.53	1.02	80950.09
22	9.82	4.55	54.55	0.82	17.26	10.35	1.02	84442.74
23	9.12	5.46	51.06	0.79	16.98	10.61	1.01	81123.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.93	5.86	47.70	1.16	15.69	10.58	1.03	77853.33
最大值	11.32	13.16	66.29	2.09	17.40	11.26	1.16	84442.74
發生時間	20	10	20	6	1	0		22
最小值	0.14	2.14	33.77	0.49	13.25	9.99	0.99	72454.44
發生時間	9	15	10	12	8	10		7
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.39 %	-0.16 %	0.34 %		0.41		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								