

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.17	2.85	57.09	2.92	19.13	11.39	1.47	74746.09
1	1.60	4.19	60.37	2.58	20.68	11.40	1.49	73485.16
2	6.29	0.48	50.42	2.97	19.80	11.43	1.43	74021.52
3	7.76	1.68	59.19	3.09	19.31	11.21	1.43	76317.59
4	7.49	6.33	48.46	3.31	17.46	11.72	1.41	73928.32
5	5.09	5.20	55.15	3.28	18.49	11.40	1.37	78369.07
6	10.21	5.21	48.61	3.51	18.33	11.49	1.37	74358.75
7	9.75	4.25	52.01	3.57	18.16	11.77	1.38	73170.14
8	10.62	2.65	53.36	3.36	19.71	11.15	1.38	76800.41
9	9.50	2.36	48.95	2.90	20.42	10.63	1.38	80175.13
10	11.32	4.88	52.01	3.40	17.76	11.54	1.41	74680.18
11	9.07	5.57	55.69	3.37	17.56	11.78	1.39	73185.68
12	5.76	1.29	56.72	3.16	18.49	11.57	1.40	73565.58
13	3.84	1.25	52.77	3.02	18.93	11.37	1.44	75259.15
14	6.32	1.99	56.03	3.22	18.53	11.60	1.42	73378.67
15	6.04	2.32	51.39	3.27	17.90	11.66	1.42	73686.56
16	8.02	2.02	56.02	3.30	17.76	11.81	1.38	72864.74
17	9.10	3.43	54.38	3.12	18.53	11.42	1.39	74932.20
18	6.95	1.58	55.88	3.19	18.70	11.59	1.40	73382.27
19	8.83	4.02	59.15	3.23	17.97	11.67	1.40	73954.87
20	8.10	5.16	55.48	3.21	18.35	11.53	1.42	74698.52
21	9.52	3.62	59.16	3.12	19.23	11.30	1.43	76025.72
22	6.91	3.65	51.68	3.06	19.70	11.31	1.40	75311.43
23	8.72	10.54	49.23	3.28	18.58	11.35	1.35	75576.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.50	3.61	54.13	3.19	18.73	11.46	1.41	74828.09
最大值	11.32	10.54	60.37	3.57	20.68	11.81	1.54	80175.13
發生時間	10	23	1	7	1	16		9
最小值	1.60	0.48	48.46	2.58	17.46	10.63	1.33	72864.74
發生時間	1	2	4	1	4	9		16
零點偏移(率)	-0.02 %	-0.01 %	-0.01 %	-0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	-0.48 %	0.18 %	-0.88 %	0.35 %		0.25	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.12	0.77	60.95	3.08	15.39	10.85	1.36	62513.08
1	9.43	1.42	51.37	2.18	16.46	10.46	1.35	61984.26
2	8.36	0.59	54.27	2.45	16.79	10.37	1.34	62207.31
3	9.50	0.67	56.80	2.40	17.22	10.20	1.34	65032.66
4	6.75	1.79	53.70	2.14	16.59	10.82	1.34	62027.40
5	8.15	2.03	61.91	1.72	18.17	10.46	1.34	65283.24
6	11.13	2.66	54.23	2.43	17.70	10.39	1.30	65435.23
7	9.73	3.37	59.88	1.85	17.66	10.39	1.30	65916.68
8	9.57	2.80	57.21	1.66	18.66	10.27	1.30	66556.64
9	10.41	10.36	51.33	1.54	19.86	9.78	1.33	67556.25
10	10.28	3.26	47.52	3.48	17.55	10.51	1.29	65346.28
11	9.51	4.18	59.04	3.09	18.02	10.69	1.26	64761.36
12	8.93	1.34	54.75	2.24	16.45	10.89	1.30	65725.01
13	8.31	4.78	56.70	2.28	14.99	11.13	1.32	62358.63
14	12.29	8.55	57.34	2.67	14.59	11.06	1.30	61857.88
15	10.09	2.44	54.91	2.30	15.42	10.84	1.30	62890.56
16	10.05	0.88	56.73	2.06	16.35	10.65	1.27	63653.83
17	11.40	2.13	60.49	2.41	14.84	11.21	1.25	63497.92
18	10.06	4.69	64.79	2.54	16.26	10.82	1.25	64620.22
19	10.34	4.15	61.05	2.00	16.18	10.82	1.25	64687.56
20	10.28	11.20	58.40	2.35	15.21	11.21	1.25	61979.74
21	7.77	1.65	47.64	1.78	16.87	10.34	1.29	61190.96
22	9.81	11.65	46.50	2.07	16.52	10.26	1.29	61266.38
23	10.75	7.36	53.94	1.92	17.14	10.16	1.26	63618.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.75	3.95	55.89	2.28	16.70	10.61	1.30	63831.99
最大值	12.29	11.65	64.79	3.48	19.86	11.21	1.37	67556.25
發生時間	14	22	18	10	9	17		9
最小值	6.75	0.59	46.50	1.54	14.59	9.78	1.25	61190.96
發生時間	4	2	22	9	14	9		21
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.01 %		-0.06	0.00	0.00 %
全幅偏移(率)	1.01 %	0.30 %	-0.22 %	0.29 %		0.05	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.68	13.32	57.87	2.18	16.40	10.66	1.72	83301.59
1	7.46	1.79	56.22	1.79	17.92	10.47	1.71	86333.28
2	7.60	7.56	53.00	2.77	15.74	10.69	1.70	83722.60
3	9.19	0.93	53.73	2.86	16.49	10.43	1.71	84409.41
4	9.54	0.88	56.24	2.45	16.72	10.50	1.72	84564.20
5	10.06	1.63	56.15	2.46	16.39	10.58	1.72	83178.53
6	10.39	4.99	54.54	2.71	15.90	10.47	1.71	82076.93
7	10.82	4.80	55.85	2.09	17.54	10.02	1.72	88421.00
8	7.64	3.84	61.74	1.92	18.51	9.56	1.72	89231.01
9	10.55	3.15	49.44	1.86	19.14	9.25	1.72	89989.48
10	8.99	2.70	50.45	1.78	17.05	10.13	1.75	85954.58
11	9.38	5.01	56.37	2.92	16.32	10.38	1.74	86867.01
12	6.74	0.98	55.67	2.14	15.43	10.89	1.74	82309.24
13	6.11	1.48	57.25	2.19	14.84	10.75	1.73	81773.60
14	4.84	1.02	56.97	2.14	14.94	10.93	1.73	81146.14
15	8.60	0.89	59.87	2.25	15.09	11.04	1.73	83295.67
16	9.97	2.08	59.71	2.59	14.17	11.33	1.72	82329.34
17	10.69	4.73	58.76	2.78	14.17	11.17	1.72	83504.27
18	8.94	1.35	59.76	2.06	15.91	10.82	1.72	83796.98
19	8.05	2.16	63.67	2.39	14.74	11.26	1.72	81867.12
20	9.17	1.70	55.44	2.09	15.64	10.84	1.72	82875.11
21	9.55	1.09	62.13	1.93	16.50	10.72	1.70	83742.13
22	10.17	4.73	55.17	1.92	16.07	10.75	1.69	84369.50
23	9.82	8.19	62.02	2.22	15.23	11.08	1.68	83032.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.00	3.38	57.00	2.27	16.12	10.61	1.72	84253.82
最大值	11.68	13.32	63.67	2.92	19.14	11.33	1.79	89989.48
發生時間	0	0	19	11	9	16		9
最小值	4.84	0.88	49.44	1.78	14.17	9.25	1.67	81146.14
發生時間	14	4	9	10	16	9		14
零點偏移(率)	-0.14 %	-0.02 %	-0.00 %	-0.04 %		0.00	0.00	0.00 %
全幅偏移(率)	0.42 %	0.18 %	-0.29 %	0.11 %		0.36	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								