

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.54	3.68	56.14	2.25	16.86	11.79	1.41	71610.16
1	4.52	3.21	48.32	2.58	16.57	11.96	1.41	70975.71
2	6.33	3.15	58.33	2.49	17.33	11.70	1.43	72257.52
3	5.22	3.28	59.20	2.42	17.08	11.76	1.46	72623.20
4	3.72	3.30	61.72	1.97	18.55	11.48	1.46	73533.43
5	11.34	3.72	58.47	3.02	17.59	11.46	1.43	72451.18
6	10.48	3.15	52.50	3.12	16.92	11.62	1.42	73110.37
7	6.62	3.20	59.70	2.75	16.96	11.73	1.41	72772.67
8	7.99	3.21	52.40	3.10	16.63	11.96	1.38	70685.21
9	6.16	3.47	56.29	2.58	17.29	11.61	1.42	73113.39
10	4.53	3.36	56.61	2.58	17.42	11.58	1.39	72876.63
11	6.03	3.49	57.55	2.67	17.08	11.87	1.42	70443.23
12	0.45	3.24	72.03	2.09	17.92	11.76	1.46	70263.02
13	0.12	3.53	64.96	2.06	19.43	11.73	1.43	69777.16
14	0.10	3.32	44.30	1.72	20.44	10.97	1.41	74491.66
15	1.12	3.20	35.17	2.04	19.18	11.00	1.41	74846.28
16	5.69	4.09	41.93	2.80	16.71	11.66	1.41	72782.34
17	6.28	4.22	57.33	2.75	16.99	11.83	1.41	70516.58
18	6.90	3.28	63.66	2.49	18.12	11.61	1.43	71484.54
19	4.75	3.54	56.56	2.47	18.40	11.53	1.42	72277.91
20	9.82	4.54	42.53	3.20	16.78	11.61	1.41	72355.74
21	9.88	5.33	52.76	3.10	16.87	11.76	1.41	71584.84
22	10.59	3.62	54.76	3.44	15.95	11.97	1.37	70250.79
23	9.36	4.27	46.93	3.41	16.01	12.11	1.34	69305.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.86	3.60	54.59	2.63	17.46	11.67	1.41	71932.88
最大值	11.34	5.33	72.03	3.44	20.44	12.11	1.50	74846.28
發生時間	5	21	12	22	14	23		15
最小值	0.10	3.15	35.17	1.72	15.95	10.97	1.33	69305.64
發生時間	14	2	15	14	22	14		23
零點偏移(率)	-0.06 %	0.00 %	-0.02 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.87 %	0.27 %	-0.64 %	0.20 %		0.17	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.60	1.26	48.38	1.42	18.77	10.40	1.38	83308.67
1	1.75	1.32	44.08	1.30	18.94	10.46	1.38	80956.76
2	6.49	1.82	53.72	2.34	17.84	10.57	1.38	82612.66
3	5.56	1.22	61.49	2.08	18.00	10.52	1.38	83026.07
4	6.64	1.44	35.88	2.13	19.26	9.78	1.38	84043.82
5	7.47	2.07	47.54	2.50	17.21	10.41	1.37	80814.90
6	5.91	7.23	41.95	2.29	17.56	10.27	1.33	78167.17
7	4.32	1.78	40.75	2.24	17.22	10.32	1.34	79073.60
8	3.76	3.44	40.45	1.84	19.11	9.84	1.38	84166.44
9	8.09	2.74	74.26	2.13	18.26	10.38	1.36	84947.30
10	3.88	2.05	50.12	1.69	18.61	10.33	1.38	83238.60
11	4.88	6.66	54.29	1.43	20.42	9.63	1.35	87179.22
12	4.16	5.04	28.63	1.98	18.48	9.65	1.33	77636.27
13	19.50	8.20	33.83	4.02	17.35	9.85	1.37	76956.54
14	9.54	10.27	39.02	11.87	15.04	10.62	1.37	78548.60
15	2.07	4.82	31.43	5.17	17.83	10.20	1.35	80911.46
16	7.70	5.53	38.73	3.73	16.89	10.15	1.35	79498.84
17	10.08	3.55	42.20	2.06	18.02	10.28	1.36	82616.55
18	9.11	4.17	40.13	1.99	18.80	9.89	1.33	82768.99
19	7.29	12.85	22.17	3.11	16.77	10.11	1.33	79169.78
20	11.45	2.35	40.48	2.75	15.83	10.46	1.36	79335.16
21	12.99	2.71	41.11	4.78	17.55	9.71	1.38	78129.83
22	9.87	2.58	36.39	2.64	18.19	9.80	1.36	80854.48
23	9.84	3.78	44.13	2.52	17.20	10.23	1.33	79866.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.41	4.12	42.97	2.92	17.88	10.16	1.36	81159.49
最大值	19.50	12.85	74.26	11.87	20.42	10.62	1.39	87179.22
發生時間	13	19	9	14	11	14		11
最小值	1.75	1.22	22.17	1.30	15.04	9.63	1.33	76956.54
發生時間	1	3	19	1	14	11		13
零點偏移(率)	-0.05 %	0.00 %	-0.03 %	-0.01 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.03 %	0.01 %	-0.97 %	0.03 %		-0.10	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.77	2.43	58.58	1.63	16.31	11.01	1.45	83256.37
1	3.37	3.24	52.74	1.42	17.11	10.99	1.44	82860.68
2	4.12	7.95	51.70	2.81	16.93	10.55	1.46	84945.41
3	4.52	5.57	49.34	3.10	14.69	11.11	1.46	77225.89
4	5.17	2.50	57.65	1.70	17.18	10.53	1.46	83346.76
5	7.15	3.96	53.47	2.24	16.24	10.72	1.45	80628.90
6	5.81	5.20	55.37	1.76	17.45	10.43	1.45	83088.23
7	2.10	2.36	54.42	1.96	16.36	10.80	1.46	75996.65
8	6.30	2.66	62.87	2.38	16.22	10.81	1.47	83333.06
9	4.45	2.16	67.48	1.90	17.72	10.92	1.47	83529.52
10	4.78	3.33	46.58	1.77	17.97	10.34	1.46	84189.70
11	5.06	4.40	56.17	2.19	16.16	10.81	1.47	82243.74
12	3.04	4.34	49.68	1.90	17.45	10.26	1.44	78670.22
13	10.54	8.17	57.58	2.96	17.40	10.29	1.44	85280.23
14	11.14	9.88	58.52	7.21	15.01	11.14	1.45	87243.38
15	3.25	2.75	37.56	1.58	13.93	11.18	1.47	75530.78
16	8.67	4.44	58.26	2.60	16.58	10.72	1.47	83396.62
17	9.18	6.27	59.73	2.61	15.23	11.35	1.45	83944.08
18	9.66	11.83	55.70	2.56	16.40	10.77	1.45	86960.04
19	14.75	5.39	60.89	2.93	15.84	11.10	1.46	86102.10
20	11.04	8.36	65.23	4.13	14.31	11.66	1.47	84348.47
21	14.25	2.53	54.69	3.82	15.06	11.40	1.44	82216.74
22	6.95	6.07	48.30	2.97	15.29	11.00	1.43	80626.63
23	9.25	2.51	60.89	2.31	16.39	11.01	1.45	85389.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.05	4.93	55.56	2.60	16.22	10.87	1.45	82681.39
最大值	14.75	11.83	67.48	7.21	17.97	11.66	1.49	87243.38
發生時間	19	18	9	14	10	20		14
最小值	2.10	2.16	37.56	1.42	13.93	10.26	1.43	75530.78
發生時間	7	9	15	1	15	12		15
零點偏移(率)	-0.09 %	-0.04 %	-0.01 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.60 %	0.71 %	-0.81 %	0.11 %		0.14	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								