

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年09月14日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.37	5.51	61.99	2.20	17.13	11.99	1.02	78464.61
1	6.82	4.97	59.69	1.34	20.51	11.04	1.03	83882.77
2	9.95	5.22	47.74	2.13	18.05	11.38	1.02	82031.37
3	8.66	5.31	44.01	2.10	17.29	11.51	1.02	81611.42
4	8.24	5.37	50.90	2.51	16.69	11.80	1.01	79634.97
5	10.04	5.67	48.66	1.73	16.10	11.93	0.99	78909.63
6	9.84	4.18	56.94	1.31	17.66	11.62	1.00	81669.15
7	9.08	4.41	48.99	1.88	16.39	11.78	1.02	81093.27
8	10.60	5.42	47.04	2.17	16.29	11.90	1.02	80065.69
9	9.16	5.33	47.73	2.46	15.65	12.02	1.01	78096.68
10	6.55	4.51	52.59	1.45	17.13	11.84	1.01	79719.58
11	5.01	5.37	49.18	1.19	16.55	11.99	1.01	78855.37
12	2.64	4.92	58.39	1.22	16.28	12.47	1.01	75042.12
13	1.45	4.80	52.16	1.54	16.20	12.02	1.00	79347.89
14	5.09	4.50	45.65	2.40	15.22	11.98	1.02	76792.04
15	0.71	2.59	44.92	2.40	14.43	12.13	1.02	74168.04
16	3.84	2.35	50.46	2.48	15.63	12.24	1.02	74653.61
17	7.89	3.71	52.30	1.48	17.61	11.81	1.02	77805.75
18	5.85	3.06	49.54	0.73	18.90	11.47	1.01	81815.70
19	2.13	2.22	56.35	0.69	18.15	11.75	1.00	79926.09
20	4.14	2.97	54.42	0.64	18.64	11.56	1.02	81013.53
21	7.82	3.80	48.00	1.52	17.06	11.86	1.02	79627.66
22	6.71	4.04	49.31	1.11	16.92	12.02	1.02	78074.94
23	7.87	3.40	55.09	1.11	17.10	12.04	1.01	77681.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.52	4.32	51.34	1.66	16.98	11.84	1.01	79165.98
最 大 值	10.60	5.67	61.99	2.51	20.51	12.47	1.03	83882.77
發生時間	8	5	0	4	1	12		1
最 小 值	0.71	2.22	44.01	0.64	14.43	11.04	0.98	74168.04
發生時間	15	19	3	20	15	1		15
零點偏移(率)	-0.23 %	0.00 %	-0.21 %	-0.11 %		-0.26		0.00 %
全幅偏移(率)	-1.09 %	0.27 %	0.48 %	0.70 %		-0.20		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年09月14日

報表日期: 113年09月14日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.70	3.90	63.00	1.54	15.37	11.65	1.73	71860.58
1	1.36	2.99	63.10	0.77	17.75	11.29	1.76	75567.40
2	9.13	2.68	59.43	1.27	16.45	11.21	1.76	78116.28
3	12.83	3.04	59.76	1.96	15.87	11.38	1.76	77188.43
4	9.11	2.76	61.70	1.75	15.71	11.50	1.75	76839.74
5	10.62	2.67	60.87	1.52	15.94	11.38	1.74	77020.04
6	9.45	3.01	53.24	2.00	14.85	11.76	1.73	76802.76
7	5.90	3.05	51.04	1.84	14.66	11.38	1.76	78083.68
8	9.77	3.03	52.52	2.83	14.45	11.74	1.73	74314.77
9	4.00	2.89	48.98	2.41	13.66	12.19	1.75	74017.99
10	5.97	2.21	55.62	1.14	15.20	11.46	1.78	74690.40
11	9.86	2.23	52.70	1.51	14.27	11.98	1.74	72953.33
12	8.44	2.15	58.20	1.37	14.75	12.23	1.74	74046.51
13	6.92	3.79	52.31	2.18	13.78	11.74	1.70	74122.53
14	8.97	7.28	54.23	3.37	12.64	12.18	1.75	69516.75
15	7.18	7.75	47.00	2.99	12.57	11.69	1.76	68674.87
16	7.73	3.31	50.60	2.04	14.02	11.67	1.76	69205.80
17	9.48	3.77	58.87	0.74	16.05	11.56	1.76	69122.61
18	8.04	2.49	58.12	0.72	16.89	11.33	1.76	75909.82
19	13.64	2.84	57.13	0.98	16.94	11.13	1.74	78162.19
20	9.11	2.39	57.74	0.70	16.26	11.64	1.71	75148.97
21	9.33	2.77	54.36	0.90	15.78	11.52	1.70	76103.32
22	7.88	2.82	53.75	0.95	15.61	11.61	1.70	76119.74
23	5.08	2.58	55.19	0.91	15.72	11.67	1.72	74915.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.15	3.27	55.81	1.60	15.22	11.62	1.74	74521.00
最 大 值	13.64	7.75	63.10	3.37	17.75	12.23	1.82	78162.19
發生時間	19	15	1	14	1	12		19
最 小 值	1.36	2.15	47.00	0.70	12.57	11.13	1.69	68674.87
發生時間	1	12	15	20	15	19		15
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.09 %		-0.17		0.00 %
全幅偏移(率)	0.02 %	0.02 %	-0.00 %	0.02 %		-0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								