

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.30	6.62	57.89	1.27	18.09	11.47	1.08	78556.32
1	1.06	11.61	60.85	2.08	17.17	12.48	1.08	70771.90
2	2.08	12.12	50.01	1.21	18.95	11.42	1.08	77798.95
3	3.66	6.75	52.15	1.84	16.82	11.58	1.07	78604.87
4	8.78	9.05	51.60	2.89	16.22	11.80	1.07	76984.87
5	9.96	11.61	51.76	2.73	16.73	11.69	1.06	73793.13
6	9.93	8.39	50.92	3.18	16.03	11.72	1.07	68776.41
7	6.46	7.34	50.61	2.38	16.50	11.68	1.07	68556.07
8	8.14	7.39	57.01	2.64	16.26	11.74	1.07	68560.27
9	8.88	8.37	58.33	3.02	16.23	11.76	1.05	68580.98
10	8.93	7.10	57.99	1.73	17.12	11.54	1.08	68972.51
11	9.24	8.27	55.08	1.92	17.45	11.61	1.07	68240.09
12	9.15	6.99	56.65	1.73	18.22	11.27	1.05	69760.90
13	7.76	7.99	51.43	2.26	16.63	11.80	1.05	67686.21
14	6.18	7.13	59.53	1.44	17.99	11.64	1.05	67908.25
15	5.04	7.40	56.88	0.93	18.66	11.16	1.07	70273.39
16	5.69	7.93	54.46	0.89	19.68	10.93	1.07	70550.95
17	5.10	7.24	53.39	0.86	19.73	11.22	1.07	68351.07
18	3.67	7.18	50.94	0.86	19.13	11.20	1.06	69733.28
19	5.53	8.40	40.75	1.16	19.06	11.06	1.05	70233.98
20	7.77	9.73	36.45	1.88	18.44	11.28	1.07	69265.60
21	5.24	6.96	43.15	0.95	19.57	10.68	1.07	72662.85
22	5.20	7.46	41.71	1.53	18.47	11.26	1.07	69859.76
23	2.78	7.39	49.55	0.89	19.30	11.30	1.05	69247.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.19	8.18	52.05	1.76	17.85	11.47	1.07	70988.75
最大值	9.96	12.12	60.85	3.18	19.73	12.48	1.13	78604.87
發生時間	5	2	1	6	17	1		3
最小值	1.06	6.62	36.45	0.86	16.03	10.68	1.05	67686.21
發生時間	1	0	20	17	6	21		13
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.11 %	-0.06 %	0.18 %		0.14		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.46	4.90	53.59	1.84	18.69	10.43	0.99	84418.74
1	1.25	4.48	52.45	1.44	20.44	9.89	0.99	86310.81
2	1.71	9.57	51.01	2.37	18.37	10.02	0.99	87252.72
3	2.25	7.46	46.55	2.50	17.85	10.26	0.99	86963.25
4	1.80	3.84	53.33	2.49	17.00	10.41	0.99	85797.63
5	5.00	5.22	52.87	3.35	16.59	10.51	0.99	84883.78
6	8.72	8.04	60.10	3.73	16.65	10.42	0.97	79225.83
7	6.40	4.70	52.53	3.13	16.93	10.47	0.96	84864.59
8	9.68	6.69	53.29	3.75	15.63	10.75	0.97	84355.48
9	4.22	4.86	52.46	3.00	16.70	10.50	0.97	84888.27
10	7.99	4.40	52.01	2.44	18.24	9.91	0.97	88055.53
11	7.65	8.43	52.13	3.45	17.04	10.37	0.97	86149.35
12	7.77	3.41	49.94	2.26	17.75	10.16	0.97	87022.35
13	7.09	4.29	47.90	2.55	18.44	10.21	0.97	85018.15
14	4.03	5.60	48.97	1.89	19.13	9.91	0.97	87105.82
15	5.17	6.84	42.86	2.13	18.84	10.08	0.98	85789.49
16	2.16	5.60	45.41	1.67	20.15	9.77	0.98	87040.02
17	0.67	3.68	51.16	1.49	19.18	10.01	0.98	86810.27
18	0.32	3.86	50.28	1.51	18.34	10.26	0.97	85074.68
19	0.11	4.47	51.43	2.40	16.42	11.06	0.96	80470.95
20	0.36	3.26	53.25	1.55	19.31	10.06	0.97	85179.13
21	0.38	4.05	53.65	1.53	19.97	9.84	0.96	86467.55
22	0.84	4.96	47.70	1.29	20.05	9.52	0.95	89826.21
23	1.54	7.78	49.16	2.22	18.67	9.88	0.97	87706.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.65	5.43	51.00	2.33	18.18	10.20	0.97	85694.86
最大值	9.68	9.57	60.10	3.75	20.44	11.06	1.00	89826.21
發生時間	8	2	6	8	1	19		22
最小值	0.11	3.26	42.86	1.29	15.63	9.52	0.94	79225.83
發生時間	19	20	15	22	8	22		6
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.03 %		0.00		-0.20 %
全幅偏移(率)	-0.24 %	0.12 %	-0.41 %	0.21 %		-0.30		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.11	7.65	42.14	1.24	16.04	10.53	1.02	73444.19
1	1.23	7.79	44.92	1.23	16.78	10.98	1.04	76424.12
2	2.88	4.47	46.35	1.22	17.65	10.28	1.05	82370.09
3	5.78	5.19	46.48	1.48	17.03	10.47	1.05	82371.13
4	5.86	5.30	51.22	1.86	15.30	11.28	1.05	78684.69
5	4.92	5.82	53.87	2.15	15.05	11.16	1.05	80764.71
6	2.55	9.70	52.46	2.30	13.94	11.47	1.05	78553.93
7	2.86	7.18	46.63	1.93	14.78	11.14	1.02	74137.50
8	2.86	4.32	49.35	1.50	15.54	11.03	1.02	76762.25
9	3.56	8.28	49.02	2.22	14.61	11.05	1.04	77690.49
10	2.90	5.05	50.78	1.76	14.91	11.01	1.01	75923.46
11	3.67	4.97	51.78	1.53	15.49	11.07	1.04	77016.48
12	5.81	7.61	49.22	1.79	15.80	10.86	1.05	78168.12
13	8.27	5.86	48.67	2.26	16.29	10.46	1.04	81192.60
14	8.88	2.60	49.15	1.85	16.31	10.74	1.05	78412.34
15	6.65	7.27	53.64	1.27	17.56	10.73	1.06	79236.36
16	5.98	4.75	55.66	1.14	18.02	10.60	1.05	80378.30
17	2.45	11.95	47.37	0.93	17.86	10.30	1.05	79593.66
18	2.06	8.82	31.83	1.07	15.80	10.51	1.03	74863.15
19	1.33	4.53	45.37	0.97	16.83	10.89	1.00	76825.57
20	2.21	6.42	46.89	1.04	17.81	10.51	1.04	80935.17
21	2.62	3.02	40.86	1.11	18.85	9.80	1.03	83361.79
22	3.72	4.80	41.36	1.11	16.98	10.58	1.00	78084.21
23	1.64	4.69	50.68	1.21	16.12	11.29	0.99	73427.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.83	6.17	47.74	1.51	16.31	10.78	1.03	78275.92
最大值	8.88	11.95	55.66	2.30	18.85	11.47	1.06	83361.79
發生時間	14	17	16	6	21	6		21
最小值	1.11	2.60	31.83	0.93	13.94	9.80	0.98	73427.83
發生時間	0	14	18	17	6	21		23
零點偏移(率)	-0.18 %	-0.06 %	-0.07 %	-0.05 %		0.00		0.00 %
全幅偏移(率)	-1.68 %	-0.13 %	-0.95 %	0.08 %		0.29		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								