

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月01日

報表日期: 114年09月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.78	9.53	55.07	2.67	14.86	12.05	1.23	68199.64
1	9.28	9.43	61.30	2.53	15.37	12.10	1.22	68397.24
2	9.30	9.29	53.89	2.90	13.91	12.14	1.20	68432.58
3	8.91	9.24	61.46	2.83	13.98	12.09	1.20	68693.39
4	8.52	9.33	54.58	2.71	13.42	12.20	1.21	68073.30
5	9.17	9.95	68.28	2.94	14.98	11.61	1.25	70465.76
6	9.87	10.08	54.00	2.87	13.60	12.07	1.25	70054.20
7	8.44	9.95	59.29	2.41	14.54	11.96	1.25	70339.99
8	14.90	9.40	42.08	2.18	16.22	11.58	1.25	71731.38
9	3.82	9.53	42.94	2.26	14.22	12.07	1.25	68853.06
10	8.37	9.63	44.96	2.02	15.95	11.80	1.25	69800.95
11	9.55	10.80	60.43	4.55	15.32	11.52	1.25	72154.65
12	7.09	12.24	42.28	3.23	15.00	11.94	1.25	69393.14
13	9.04	12.21	47.58	2.28	15.01	11.92	1.24	68963.43
14	7.97	12.41	67.35	1.90	15.23	12.08	1.23	67058.70
15	11.49	11.94	48.07	2.85	14.36	11.63	1.24	71252.67
16	11.69	12.28	57.49	2.91	14.30	11.86	1.24	71018.42
17	9.74	12.25	57.35	2.82	14.22	11.96	1.25	70237.36
18	5.26	12.52	55.07	2.36	14.34	12.14	1.25	66923.80
19	8.84	12.61	62.77	2.07	14.61	11.84	1.25	70034.84
20	10.12	12.53	55.82	2.61	13.62	12.02	1.25	69886.70
21	7.81	12.53	60.04	2.00	15.00	12.07	1.25	69035.82
22	7.42	12.47	59.35	2.18	14.62	11.93	1.25	70160.93
23	10.18	14.52	54.90	2.28	14.79	12.07	1.25	68822.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.98	11.11	55.26	2.60	14.64	11.94	1.24	69499.36
最 大 值	14.90	14.52	68.28	4.55	16.22	12.20	1.27	72154.65
發生時間	8	23	5	11	8	4		11
最 小 值	3.82	9.24	42.08	1.90	13.42	11.52	1.20	66923.80
發生時間	9	3	8	14	4	11		18
零點偏移(率)	-0.07 %	-0.11 %	-0.03 %	0.00 %		-0.03		0.10 %
全幅偏移(率)	0.00 %	-0.01 %	-0.51 %	0.25 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月01日

報表日期: 114年09月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.32	9.01	53.95	1.71	18.47	9.47	1.34	74089.00
1	4.65	12.58	47.73	1.90	18.59	8.98	1.33	72857.65
2	6.85	10.76	48.17	2.13	15.35	9.24	1.35	70760.76
3	9.16	8.33	48.46	2.27	15.68	9.03	1.38	73703.57
4	8.56	7.48	46.39	0.45	16.47	9.02	1.38	73470.42
5	9.36	7.50	53.99	0.40	16.63	9.54	1.40	70016.66
6	9.42	7.62	55.86	0.39	17.31	9.43	1.38	70610.32
7	6.82	9.86	48.08	3.46	16.89	8.95	1.38	72594.57
8	9.20	9.64	50.81	4.19	18.67	8.43	1.34	77965.69
9	9.81	10.54	45.22	2.93	16.11	8.61	1.34	74340.75
10	5.63	10.18	49.19	1.94	16.93	8.91	1.38	72827.90
11	4.70	10.52	46.62	3.25	16.25	9.05	1.33	72050.70
12	3.51	10.51	45.72	3.06	15.96	9.25	1.32	71126.30
13	3.24	10.55	49.69	3.05	16.39	9.25	1.35	73362.67
14	3.93	11.70	53.50	3.29	16.90	9.32	1.39	73327.18
15	4.46	12.54	45.50	3.42	17.11	8.83	1.38	72646.89
16	4.63	14.02	59.69	3.52	15.79	9.32	1.38	73624.35
17	4.49	13.91	66.13	3.58	15.95	9.32	1.37	73726.53
18	3.73	13.70	69.47	3.20	17.54	9.04	1.34	75586.26
19	3.29	13.35	61.30	3.09	15.87	9.19	1.34	74856.51
20	3.53	13.59	68.67	3.21	17.72	9.27	1.34	77040.87
21	3.72	13.82	49.42	3.12	16.86	9.36	1.34	79375.26
22	4.09	13.90	58.77	3.24	17.37	9.45	1.33	78275.80
23	6.17	14.12	59.53	3.54	17.34	9.50	1.35	77995.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.76	11.24	53.41	2.68	16.84	9.16	1.36	74009.68
最 大 值	9.81	14.12	69.47	4.19	18.67	9.54	1.42	79375.26
發生時間	9	23	18	8	8	5		21
最 小 值	3.24	7.48	45.22	0.39	15.35	8.43	1.31	70016.66
發生時間	13	4	9	6	2	8		5
零點偏移(率)	-0.06 %	0.00 %	-0.16 %	-0.07 %		-0.03		0.00 %
全幅偏移(率)	0.02 %	-0.01 %	-0.27 %	0.12 %		0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								