

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月29日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.05	10.90	55.92	1.43	19.94	10.38	1.18	85486.34
1	9.16	11.13	52.63	1.81	20.89	10.44	1.18	84658.72
2	13.30	11.67	48.40	2.82	19.30	10.61	1.16	84960.04
3	7.14	11.20	52.87	2.24	18.99	10.75	1.18	84488.55
4	8.36	11.47	50.78	2.11	18.47	10.76	1.17	84750.14
5	2.36	15.26	66.45	1.74	18.45	11.94	1.20	80008.13
6	9.17	14.52	62.19	1.99	19.57	11.01	1.20	81512.93
7	13.66	13.58	42.66	3.10	19.08	10.46	1.21	85998.12
8	6.98	13.70	47.43	3.28	18.36	10.53	1.24	86003.55
9	9.53	13.46	51.86	3.40	17.94	10.57	1.20	86264.01
10	7.98	13.63	52.44	4.47	18.52	10.44	1.22	86892.27
11	4.87	14.45	65.00	2.84	17.98	11.49	1.22	78768.94
12	7.07	13.67	52.07	2.62	19.48	10.33	1.21	86721.62
13	6.54	13.50	57.41	3.13	18.78	10.72	1.20	84358.52
14	5.48	14.00	58.27	2.77	18.63	11.00	1.20	82197.55
15	7.23	13.92	38.92	4.01	17.35	11.18	1.20	81979.31
16	9.26	11.66	47.66	2.09	18.36	11.00	1.19	83098.41
17	10.70	11.86	46.35	1.93	17.22	11.41	1.19	80464.44
18	9.29	11.41	54.15	1.62	18.24	11.07	1.19	82068.83
19	5.97	11.85	51.06	0.94	19.46	11.06	1.18	80874.36
20	11.89	11.34	48.56	1.46	19.69	10.80	1.20	82457.04
21	9.00	11.83	64.49	1.04	19.98	11.16	1.20	79609.31
22	9.54	11.03	48.23	1.75	19.18	10.55	1.19	85251.06
23	6.82	12.83	65.08	1.68	18.47	12.13	1.19	73310.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.35	12.66	53.37	2.34	18.85	10.91	1.20	83007.61
最 大 值	13.66	15.26	66.45	4.47	20.89	12.13	1.25	86892.27
發生時間	7	5	5	10	1	23		10
最 小 值	2.36	10.90	38.92	0.94	17.22	10.33	1.15	73310.43
發生時間	5	0	15	19	17	12		23
零點偏移(率)	-0.14 %	-0.12 %	-0.34 %	-0.00 %		-0.02	-0.01	0.10 %
全幅偏移(率)	1.03 %	0.97 %	-0.04 %	1.05 %		-0.16	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月29日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.01	11.98	58.79	0.83	20.51	10.34	0.95	85107.30
1	3.24	12.52	43.91	1.05	21.78	10.46	0.95	82933.35
2	2.44	12.02	48.80	0.53	20.59	10.28	0.95	86336.29
3	7.27	12.11	58.60	1.09	18.97	10.66	0.96	85240.16
4	4.39	12.45	53.41	0.31	21.07	10.62	0.94	83727.48
5	1.68	12.57	34.10	0.84	20.20	10.57	0.94	84003.26
6	3.13	12.31	34.45	0.35	19.83	10.45	0.94	85740.56
7	2.19	12.11	50.33	0.63	19.51	10.55	0.94	85557.96
8	1.15	11.99	56.89	0.50	19.71	10.44	0.95	85837.26
9	0.97	12.32	48.56	0.58	18.58	10.88	0.94	82740.34
10	0.69	12.67	59.82	0.23	19.11	11.12	0.95	78477.76
11	0.48	11.80	42.68	0.10	20.26	10.16	0.94	82455.34
12	0.48	12.54	38.00	0.52	19.12	10.38	0.94	82369.38
13	0.78	12.68	52.35	0.38	19.04	11.06	0.94	80134.79
14	0.38	12.94	49.11	0.71	18.09	11.37	0.94	79354.53
15	0.34	12.74	49.60	0.75	18.50	11.20	0.94	80202.40
16	0.82	12.54	46.24	0.86	17.73	10.94	0.94	83697.08
17	1.69	13.24	57.61	0.96	17.41	11.61	0.94	78781.85
18	1.07	12.69	51.09	0.78	19.06	11.06	0.94	81446.64
19	0.78	12.64	49.27	0.42	19.64	10.91	0.94	82228.92
20	0.78	12.44	51.38	0.58	19.77	10.63	0.94	84346.54
21	1.31	12.39	44.50	0.87	19.34	10.78	0.94	83582.90
22	0.74	12.85	57.71	0.45	19.81	11.10	0.94	80752.71
23	0.81	12.78	56.93	0.33	20.88	10.72	0.94	82305.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.07	12.47	49.76	0.61	19.52	10.76	0.94	82806.66
最 大 值	12.01	13.24	59.82	1.09	21.78	11.61	0.98	86336.29
發生時間	0	17	10	3	1	17		2
最 小 值	0.34	11.80	34.10	0.10	17.41	10.16	0.94	78477.76
發生時間	15	11	5	11	17	11		10
零點偏移(率)	-0.14 %	0.00 %	-0.04 %	0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	-2.43 %	-1.02 %	0.55 %	0.56 %		0.03	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月29日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.16	11.56	56.35	3.38	20.07	9.34	1.33	78066.74
1	11.52	11.52	55.56	3.50	21.24	9.60	1.34	74768.38
2	5.38	11.05	59.26	3.42	19.44	9.31	1.36	76452.31
3	12.44	11.29	67.22	4.00	18.38	9.92	1.36	73662.95
4	6.40	11.09	64.17	3.50	19.01	9.63	1.36	75193.02
5	10.83	11.04	65.05	3.76	19.96	9.45	1.36	75907.08
6	3.21	12.24	65.85	3.26	18.73	10.64	1.36	65263.28
7	3.04	12.01	45.73	2.89	20.92	8.91	1.32	75577.44
8	3.60	12.15	55.99	3.18	20.76	9.34	1.35	78166.48
9	4.76	12.01	50.36	3.08	20.06	8.88	1.31	74937.41
10	6.58	13.19	34.83	3.73	19.89	7.92	1.31	76698.37
11	10.47	11.80	33.52	2.78	18.32	8.39	1.35	72779.86
12	3.90	11.52	44.55	2.78	19.57	8.84	1.34	70406.43
13	5.47	11.58	41.07	2.88	20.44	8.32	1.31	73348.59
14	2.35	11.76	40.27	2.67	20.12	8.71	1.31	70550.25
15	2.69	12.27	36.37	3.12	20.23	8.12	1.31	74174.34
16	2.50	12.06	40.90	1.47	18.99	8.83	1.31	74633.47
17	4.96	11.80	48.48	1.45	18.87	8.95	1.35	77714.79
18	4.32	11.86	55.10	1.46	18.22	9.46	1.31	72916.87
19	4.01	11.69	52.65	1.55	19.99	8.92	1.33	75037.29
20	3.81	11.54	51.23	1.58	19.96	8.89	1.32	75396.55
21	9.96	12.21	45.24	2.67	20.24	8.54	1.31	78832.85
22	5.00	11.71	55.60	1.61	19.90	9.10	1.31	74937.88
23	7.47	11.25	42.03	2.44	21.21	8.45	1.31	75559.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.95	11.76	50.31	2.76	19.77	9.02	1.33	74624.27
最 大 值	12.44	13.19	67.22	4.00	21.24	10.64	1.36	78832.85
發生時間	3	10	3	3	1	6		21
最 小 值	2.35	11.04	33.52	1.45	18.22	7.92	1.28	65263.28
發生時間	14	5	11	17	18	10		6
零點偏移(率)	-0.04 %	-0.01 %	-0.02 %	-0.00 %		-0.02	-0.01	-0.10 %
全幅偏移(率)	-2.33 %	-1.85 %	-0.82 %	-1.12 %		0.32	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								