

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.47	10.44	51.42	1.06	16.83	12.08	1.29	76484.43
1	2.56	10.53	53.25	0.46	19.00	11.13	1.29	82305.25
2	3.93	11.02	61.78	1.79	16.55	11.78	1.29	79251.32
3	5.91	14.00	52.55	2.54	15.59	11.98	1.29	78340.27
4	5.47	8.69	60.20	2.24	16.24	11.89	1.29	78186.45
5	4.34	10.10	59.71	2.02	17.28	11.58	1.29	85707.29
6	2.96	9.07	64.20	1.96	17.25	11.63	1.29	79880.69
7	7.17	8.90	57.22	2.66	16.92	11.20	1.29	83607.95
8	3.61	11.63	58.47	3.91	15.24	12.03	1.29	77930.27
9	15.17	12.22	58.84	2.93	16.82	11.54	1.29	80635.64
10	10.90	10.06	51.16	4.53	14.31	12.08	1.30	76515.25
11	0.41	11.24	59.76	4.58	14.16	12.40	1.29	76584.93
12	0.43	10.37	62.05	3.73	13.80	12.04	1.29	78436.29
13	2.22	7.93	61.23	3.02	15.02	12.08	1.29	77737.59
14	4.08	7.93	57.94	2.66	15.61	11.82	1.29	79241.56
15	6.38	9.07	54.04	3.17	14.79	11.90	1.29	78992.40
16	5.54	7.84	50.65	2.26	16.32	11.50	1.29	80914.58
17	6.80	8.69	48.38	3.00	15.06	11.61	1.29	80861.27
18	4.49	7.75	48.81	2.13	15.88	11.51	1.29	81542.93
19	0.63	7.58	58.69	2.46	16.26	11.34	1.29	82469.83
20	0.15	7.76	55.75	3.37	15.76	11.30	1.29	83680.88
21	0.35	8.27	60.70	3.46	16.23	11.32	1.29	82650.30
22	2.04	8.86	61.11	3.85	15.07	12.33	1.29	75742.20
23	3.70	9.19	58.34	3.24	15.76	11.91	1.28	78732.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.28	9.55	56.93	2.79	15.91	11.75	1.29	79851.33
最 大 值	15.17	14.00	64.20	4.58	19.00	12.40	1.31	85707.29
發生時間	9	3	6	11	1	11		5
最 小 值	0.15	7.58	48.38	0.46	13.80	11.13	1.26	75742.20
發生時間	20	19	17	1	12	1		22
零點偏移(率)	-0.10 %	-0.08 %	-0.08 %	-0.02 %		-0.03		0.10 %
全幅偏移(率)	0.00 %	-0.00 %	0.01 %	0.04 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月08日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.01	10.47	59.09	0.98	19.22	10.77	1.00	81818.11
1	8.41	13.20	68.84	1.31	18.76	10.62	1.00	83436.07
2	6.05	8.58	55.98	1.87	18.61	10.72	1.00	81831.85
3	6.94	8.39	59.17	2.19	17.32	10.91	0.99	78249.21
4	8.02	7.97	58.74	2.25	17.88	10.54	0.99	81077.77
5	7.44	9.01	58.97	1.75	18.78	10.45	0.99	82019.04
6	10.88	11.25	60.96	2.78	17.49	11.06	0.99	87804.70
7	7.98	10.08	57.46	3.16	16.51	11.09	0.99	81447.84
8	5.40	7.56	68.32	2.60	17.15	11.49	0.98	79745.27
9	7.53	7.59	64.40	2.21	18.19	11.44	0.97	81310.76
10	8.11	7.85	43.16	1.88	19.19	11.21	0.96	82416.24
11	8.37	7.81	45.74	3.07	16.67	11.88	0.95	79312.77
12	5.24	7.99	59.67	3.84	15.07	12.14	0.96	78024.06
13	3.39	10.42	60.90	3.71	16.11	11.84	0.95	79662.88
14	5.55	10.02	58.33	3.36	16.60	11.65	0.97	80136.00
15	0.70	8.14	60.82	3.31	15.91	11.89	0.97	78539.91
16	9.65	8.87	54.82	3.16	17.55	11.19	0.97	83349.01
17	7.92	8.39	52.72	2.33	17.72	10.65	0.98	81383.35
18	9.35	10.04	53.95	1.78	19.35	10.21	0.97	84428.83
19	8.67	10.48	49.90	2.64	17.88	10.52	0.98	83342.37
20	9.61	9.23	54.16	3.07	17.11	10.70	0.97	81350.76
21	11.58	6.67	54.23	2.51	17.07	10.72	0.96	82700.56
22	8.33	13.06	55.13	2.08	17.32	10.98	0.96	79299.08
23	6.75	6.59	61.03	1.66	17.74	11.19	0.94	76256.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.37	9.15	57.35	2.48	17.55	11.08	0.97	81205.97
最 大 值	11.58	13.20	68.84	3.84	19.35	12.14	1.01	87804.70
發生時間	21	1	1	12	18	12		6
最 小 值	0.70	6.59	43.16	0.98	15.07	10.21	0.94	76256.72
發生時間	15	23	10	0	12	18		23
零點偏移(率)	-0.06 %	0.00 %	-0.04 %	-0.01 %		-0.10		-0.20 %
全幅偏移(率)	0.06 %	-0.05 %	0.32 %	0.01 %		-0.23		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月08日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.18	12.62	51.97	0.15	18.43	9.43	1.43	73837.98
1	3.25	5.71	67.30	0.13	20.44	9.36	1.44	70616.35
2	3.11	9.21	49.24	0.16	20.14	8.87	1.46	81839.34
3	3.34	8.71	46.21	0.27	19.48	9.82	1.45	76307.36
4	3.53	5.69	54.97	0.44	17.33	9.89	1.42	75924.41
5	3.44	5.82	53.48	0.39	17.14	9.83	1.43	75958.94
6	3.90	6.88	59.91	0.26	19.25	9.50	1.42	79363.58
7	1.46	8.63	47.48	0.41	17.81	9.49	1.39	80998.82
8	1.16	9.32	59.89	0.86	16.70	9.98	1.39	75511.12
9	1.12	6.05	61.89	0.42	17.72	10.08	1.41	74981.59
10	1.17	7.00	60.29	0.53	17.28	9.86	1.43	76411.18
11	1.12	8.15	58.24	0.88	16.59	10.24	1.41	74890.46
12	0.07	10.56	59.70	3.26	15.61	9.54	1.38	72071.37
13	1.76	8.48	62.37	3.76	16.18	8.92	1.40	69616.16
14	1.99	7.44	63.60	3.61	16.75	8.94	1.42	69302.92
15	1.99	9.39	62.07	3.68	16.78	8.85	1.43	71578.45
16	1.93	8.62	59.71	3.50	16.91	8.49	1.43	71761.38
17	1.89	10.53	56.88	3.57	16.21	8.33	1.42	71173.89
18	1.88	7.69	56.28	3.42	17.67	8.10	1.40	71386.37
19	1.88	8.26	53.47	3.51	18.13	7.98	1.37	74343.40
20	1.91	7.72	62.06	3.62	18.14	8.17	1.39	74059.05
21	1.94	8.35	61.71	3.71	17.48	8.43	1.39	75181.09
22	2.03	8.32	61.45	3.68	17.21	9.03	1.38	73106.76
23	2.21	8.87	61.05	4.12	16.87	10.10	1.38	70894.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.14	8.25	57.97	2.01	17.59	9.22	1.41	74213.19
最 大 值	3.90	12.62	67.30	4.12	20.44	10.24	1.47	81839.34
發生時間	6	0	1	23	1	11		2
最 小 值	0.07	5.69	46.21	0.13	15.61	7.98	1.34	69302.92
發生時間	12	4	3	1	12	19		14
零點偏移(率)	-0.07 %	-0.15 %	-0.04 %	-0.03 %		-0.08		-0.10 %
全幅偏移(率)	-0.07 %	0.16 %	-0.74 %	0.41 %		0.00		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								