

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.38	3.46	57.29	2.00	19.91	11.18	1.40	76101.36
1	6.43	4.37	66.40	2.10	19.70	11.89	1.40	71121.42
2	9.86	6.22	57.38	2.28	18.71	11.66	1.39	73317.81
3	10.63	4.39	65.43	2.05	18.96	10.94	1.40	79244.68
4	13.45	11.22	47.45	2.79	17.61	11.45	1.41	76103.15
5	7.25	2.94	67.27	2.10	19.19	11.38	1.45	86842.80
6	4.77	5.22	63.41	2.13	18.85	11.86	1.48	72807.75
7	8.49	4.37	52.12	1.76	20.53	10.89	1.42	79288.58
8	6.23	1.03	61.96	2.05	18.92	11.52	1.45	75786.26
9	6.81	2.61	64.49	2.32	18.27	12.51	1.54	68041.35
10	4.47	4.20	48.35	2.19	18.55	11.61	1.47	74903.03
11	12.63	7.80	50.45	2.36	17.86	11.39	1.46	76589.50
12	8.82	2.75	62.16	2.22	18.57	11.43	1.46	76112.17
13	10.42	11.41	49.92	2.55	17.06	11.49	1.45	76361.45
14	9.55	1.01	59.92	2.09	18.67	11.06	1.43	78203.48
15	6.98	0.71	59.23	2.21	17.63	11.60	1.42	75784.07
16	9.48	1.94	54.46	2.20	17.47	11.35	1.41	78368.26
17	8.75	2.12	59.69	2.18	17.84	11.31	1.43	77392.75
18	9.90	1.13	57.71	2.20	19.01	11.47	1.46	75783.28
19	10.67	2.63	40.74	2.23	18.07	11.19	1.46	78389.37
20	14.85	12.30	49.27	2.70	16.54	11.53	1.46	76882.22
21	15.57	2.53	52.07	3.41	16.85	11.51	1.46	78640.01
22	11.32	1.46	66.56	1.68	20.26	10.63	1.46	82132.41
23	8.33	3.21	65.37	2.20	18.47	11.95	1.46	73458.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.38	4.21	57.46	2.25	18.48	11.45	1.44	76569.00
最大值	15.57	12.30	67.27	3.41	20.53	12.51	1.77	86842.80
發生時間	21	20	5	21	7	9		5
最小值	4.47	0.71	40.74	1.68	16.54	10.63	1.38	68041.35
發生時間	10	15	19	22	20	22		9
零點偏移(率)	0.00 %	-0.06 %	-0.02 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	0.02 %	0.03 %	-0.31 %	0.50 %		0.38	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.01	3.82	59.95	1.75	17.25	10.56	1.33	66052.06
1	6.01	2.74	60.14	1.68	17.89	10.45	1.33	67029.02
2	9.91	1.89	63.80	2.29	16.56	10.64	1.33	66863.97
3	8.29	3.11	63.09	2.35	15.77	10.72	1.35	64663.34
4	9.41	3.65	63.92	2.37	15.64	10.93	1.36	64473.28
5	9.63	2.46	67.67	2.25	16.35	10.78	1.36	65908.38
6	6.89	3.90	54.03	2.19	16.16	10.38	1.37	62877.87
7	9.25	2.30	64.79	2.17	16.85	10.54	1.36	66547.03
8	9.18	3.48	59.24	2.49	15.78	10.68	1.36	65216.16
9	10.22	3.51	61.22	2.40	15.69	10.75	1.37	64805.17
10	10.48	2.86	62.31	2.42	15.78	10.85	1.38	64358.96
11	9.57	2.83	58.55	2.27	16.05	10.56	1.37	65421.77
12	9.14	3.36	64.87	2.45	15.07	11.02	1.36	65080.01
13	9.28	6.13	59.09	2.47	14.90	10.98	1.37	66031.99
14	8.50	1.71	62.78	2.52	15.07	10.93	1.36	66646.19
15	11.69	6.46	63.11	3.64	13.99	11.13	1.35	64826.42
16	8.30	4.55	59.80	2.68	14.26	11.10	1.33	64769.47
17	10.06	1.20	58.99	2.44	15.32	10.87	1.31	66103.99
18	9.94	1.83	63.43	2.36	16.16	10.70	1.30	66095.47
19	9.79	2.49	61.97	2.45	15.80	10.76	1.30	66007.92
20	11.97	7.90	63.59	3.02	14.42	10.97	1.31	66203.87
21	9.67	2.95	57.97	2.74	15.69	10.74	1.33	66888.99
22	6.31	1.09	59.69	2.16	15.81	10.66	1.34	65562.92
23	10.28	2.08	61.35	2.12	17.01	10.19	1.34	67966.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.24	3.26	61.47	2.40	15.80	10.75	1.34	65683.39
最大值	11.97	7.90	67.67	3.64	17.89	11.13	1.38	67966.99
發生時間	20	20	5	15	1	15		23
最小值	6.01	1.09	54.03	1.68	13.99	10.19	1.30	62877.87
發生時間	1	22	6	1	15	23		6
零點偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	3.28 %	0.56 %	-0.08 %	0.27 %		0.31	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.42	5.20	69.79	2.61	15.48	11.46	1.81	84199.43
1	6.71	7.72	66.28	2.76	15.09	11.35	1.80	85562.15
2	8.35	4.17	63.32	5.14	14.52	11.00	1.80	86551.58
3	10.03	1.73	66.85	2.86	14.66	11.24	1.82	87127.68
4	7.99	3.00	64.23	3.00	14.66	11.06	1.81	85875.27
5	9.45	4.08	71.17	2.65	16.09	10.85	1.81	87495.64
6	8.53	5.04	64.09	2.73	15.56	11.03	1.80	86974.60
7	2.63	2.25	64.91	2.26	15.58	10.75	1.78	78064.17
8	8.28	2.36	61.38	2.43	15.69	10.60	1.79	86662.14
9	10.90	5.61	58.81	2.65	15.19	10.46	1.77	82002.83
10	7.49	1.93	63.45	2.42	15.97	10.58	1.77	85282.84
11	10.43	5.83	53.93	2.70	15.09	10.42	1.75	82225.19
12	10.81	1.57	63.77	2.94	14.25	10.76	1.77	85473.79
13	8.07	1.86	63.10	3.07	13.54	11.01	1.77	83432.95
14	8.18	1.84	74.71	2.46	16.34	10.56	1.78	86019.24
15	12.40	6.04	56.39	2.93	14.48	10.81	1.74	85083.74
16	12.93	2.83	63.78	2.81	14.52	10.58	1.72	85477.52
17	11.25	2.84	64.34	2.85	14.47	10.80	1.71	82482.35
18	11.24	2.51	63.76	2.69	14.84	10.64	1.72	83818.02
19	8.49	2.55	62.09	2.92	13.72	11.02	1.72	80101.05
20	12.49	7.58	62.49	3.72	13.37	10.90	1.73	83228.79
21	14.54	5.44	64.14	3.68	13.48	11.36	1.76	82938.49
22	7.82	1.22	64.73	2.36	15.25	10.80	1.76	87615.29
23	8.36	1.75	63.25	2.28	15.47	10.61	1.76	86893.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.37	3.62	63.95	2.87	14.89	10.86	1.77	84607.83
最大值	14.54	7.72	74.71	5.14	16.34	11.46	1.82	87615.29
發生時間	21	1	14	2	14	0		22
最小值	2.63	1.22	53.93	2.26	13.37	10.42	1.70	78064.17
發生時間	7	22	11	7	20	11		7
零點偏移(率)	-0.04 %	-0.02 %	-0.09 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	1.66 %	0.19 %	-0.02 %	0.15 %		0.31	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								