

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月05日

報表日期: 114年09月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.82	13.91	63.84	2.04	15.59	12.03	1.25	68336.11
1	7.59	14.15	58.28	2.43	15.44	12.28	1.25	66959.41
2	10.85	13.64	54.62	2.19	16.31	11.92	1.25	69045.92
3	11.32	13.40	47.90	2.92	14.97	11.75	1.25	71679.97
4	9.67	12.98	61.52	2.92	15.04	11.69	1.25	71688.04
5	3.31	13.41	68.83	2.81	14.46	12.01	1.24	71970.05
6	11.54	13.57	52.65	3.14	13.83	12.10	1.24	69557.54
7	2.10	13.62	61.45	1.85	15.35	11.87	1.26	69773.25
8	1.00	13.77	55.37	2.62	13.78	12.21	1.25	67756.43
9	5.49	13.68	53.98	2.04	15.13	12.01	1.25	67884.04
10	10.18	15.30	60.13	2.38	15.52	11.97	1.25	68718.59
11	10.27	12.91	52.63	2.92	15.55	11.83	1.25	68942.65
12	8.61	12.51	63.40	2.89	15.21	12.07	1.25	67262.72
13	7.18	11.13	56.49	2.42	16.11	11.83	1.25	68788.94
14	14.31	14.56	62.10	3.51	15.59	11.93	1.24	67610.83
15	10.51	13.49	63.25	3.72	13.98	12.09	1.25	67031.65
16	9.25	12.92	56.50	3.47	14.14	11.66	1.24	70646.45
17	9.58	12.92	59.12	3.49	13.99	11.76	1.24	70718.66
18	12.20	12.84	62.84	3.73	13.72	11.69	1.25	71542.82
19	7.03	12.94	56.26	3.76	13.92	11.74	1.25	71622.47
20	4.60	14.32	64.26	2.75	15.09	11.84	1.24	70421.18
21	6.53	15.13	36.60	3.01	16.10	10.75	1.23	73424.24
22	12.98	13.48	49.45	3.92	13.44	11.57	1.24	70246.68
23	10.07	13.90	37.98	3.40	13.71	11.66	1.24	69100.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.58	13.52	56.64	2.93	14.83	11.84	1.25	69613.70
最 大 值	14.31	15.30	68.83	3.92	16.31	12.28	1.27	73424.24
發生時間	14	10	5	22	2	1		21
最 小 值	1.00	11.13	36.60	1.85	13.44	10.75	1.23	66959.41
發生時間	8	13	21	7	22	21		1
零點偏移(率)	-0.15 %	-0.11 %	-0.11 %	-0.01 %		-0.02		0.10 %
全幅偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	7.83	14.35	63.66	2.90	17.93	10.24	1.34	83575.68
1	8.91	14.47	61.52	2.99	18.00	10.06	1.34	81330.58
2	9.37	12.12	56.31	3.04	16.63	10.03	1.35	80137.92
3	9.58	12.45	56.48	3.20	16.03	9.96	1.38	79077.29
4	11.20	12.54	62.38	3.21	16.98	10.06	1.39	83038.07
5	8.99	12.54	66.61	2.98	17.63	10.12	1.39	85046.71
6	8.97	12.42	58.58	2.84	17.22	10.11	1.39	82495.68
7	11.36	11.92	65.14	3.19	16.19	10.53	1.37	82306.38
8	8.93	12.11	60.72	2.85	16.43	10.64	1.36	81602.08
9	11.09	11.96	59.92	2.89	17.03	10.36	1.39	82098.01
10	11.85	12.16	67.17	2.77	18.31	9.93	1.33	81871.54
11	8.93	15.05	64.84	2.71	17.29	10.30	1.34	81255.98
12	9.32	13.13	57.54	2.72	17.79	10.14	1.37	81524.18
13	8.45	13.96	58.19	2.71	16.56	10.49	1.37	80277.82
14	12.09	13.29	58.33	3.21	16.43	10.57	1.33	77983.13
15	7.53	13.22	57.28	3.02	15.84	10.76	1.31	76738.28
16	7.71	11.58	43.46	3.18	17.57	9.04	1.31	74380.56
17	8.36	10.64	53.68	1.41	16.92	8.83	1.33	71800.47
18	9.37	10.67	46.43	3.05	18.04	8.74	1.31	78176.69
19	7.69	11.33	47.33	2.79	16.39	9.20	1.33	77139.23
20	10.52	15.35	45.67	3.17	15.70	9.08	1.36	75298.06
21	11.15	12.43	43.82	2.01	16.10	9.20	1.35	74835.24
22	11.72	11.84	55.27	3.13	16.18	9.91	1.32	76612.29
23	7.20	11.50	51.46	2.44	17.09	9.83	1.32	77963.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.51	12.63	56.74	2.85	16.93	9.92	1.35	79440.22
最 大 值	12.09	15.35	67.17	3.21	18.31	10.76	1.40	85046.71
發生時間	14	20	10	4	10	15		5
最 小 值	7.20	10.64	43.46	1.41	15.70	8.74	1.29	71800.47
發生時間	23	17	16	17	20	18		17
零點偏移(率)	0.00 %	-0.01 %	-0.07 %	-0.01 %		-0.01		-0.10 %
全幅偏移(率)	0.02 %	0.26 %	0.14 %	0.22 %		0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								