

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.92	11.82	33.03	2.37	15.98	11.36	1.28	80172.08
1	7.79	12.46	52.83	2.32	17.27	11.43	1.29	79259.00
2	13.03	12.61	45.35	2.38	17.89	11.40	1.29	78915.75
3	6.45	12.01	41.91	2.98	16.42	11.53	1.29	77981.18
4	12.78	12.23	43.08	2.84	16.67	11.67	1.29	77343.51
5	3.44	14.01	51.79	2.91	15.94	12.13	1.31	82752.27
6	10.69	13.42	48.71	3.25	14.79	11.92	1.31	76754.02
7	7.64	13.36	48.58	2.12	16.16	11.70	1.29	79231.53
8	7.83	13.31	56.72	1.73	17.08	11.61	1.29	78644.11
9	9.20	12.88	49.27	2.24	15.92	11.53	1.29	81430.76
10	8.57	13.17	48.68	1.58	16.70	11.67	1.29	78548.14
11	9.21	13.19	57.22	1.41	16.70	11.69	1.29	78040.85
12	9.15	13.01	56.64	1.69	16.23	11.59	1.30	79319.91
13	11.00	13.82	62.08	2.08	16.58	12.08	1.30	74339.61
14	8.80	13.00	41.06	1.52	17.73	11.35	1.30	79988.53
15	9.86	12.59	39.29	1.74	17.81	11.02	1.30	83152.10
16	8.30	13.05	51.95	1.77	17.21	11.26	1.33	80226.93
17	10.18	12.61	56.89	1.79	17.45	11.11	1.34	81875.37
18	11.06	12.47	56.58	2.12	17.04	10.95	1.34	84238.85
19	7.44	12.24	44.41	1.66	16.70	11.37	1.31	81713.58
20	9.08	12.05	40.94	1.79	16.69	11.23	1.31	81738.79
21	7.62	12.19	50.16	1.16	17.75	11.49	1.30	79859.32
22	12.07	12.24	45.23	2.20	16.99	10.99	1.29	83463.06
23	10.27	13.62	59.18	2.11	16.49	11.54	1.29	78864.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.18	12.81	49.23	2.07	16.76	11.48	1.30	79910.58
最大值	13.03	14.01	62.08	3.25	17.89	12.13	1.34	84238.85
發生時間	2	5	13	6	2	5		18
最小值	3.44	11.82	33.03	1.16	14.79	10.95	1.27	74339.61
發生時間	5	0	0	21	6	18		13
零點偏移(率)	-0.03 %	0.01 %	-0.04 %	0.01 %		-0.05	-0.01	0.40 %
全幅偏移(率)	-0.87 %	-2.11 %	-0.71 %	-0.44 %		0.06	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.51	11.53	41.23	1.34	17.48	10.09	0.99	80368.21
1	9.53	11.61	37.32	1.78	17.54	10.47	1.01	78714.14
2	12.43	11.64	43.36	1.56	16.83	10.58	1.01	79409.54
3	8.12	11.49	36.86	1.54	16.32	10.50	1.02	78253.27
4	7.82	11.36	43.39	1.33	17.62	10.23	1.02	79654.91
5	10.49	11.46	39.76	1.29	17.30	10.34	1.02	79860.10
6	11.11	11.42	37.93	1.79	16.21	10.47	1.02	78432.98
7	10.62	11.56	47.29	0.77	17.05	10.40	1.02	79063.05
8	7.02	11.59	41.49	0.72	16.11	10.57	1.02	78556.20
9	8.85	11.56	40.16	0.75	16.73	10.45	1.02	79134.54
10	9.28	11.67	40.13	0.62	17.76	10.15	1.02	78872.87
11	8.00	11.54	43.93	1.63	15.10	10.54	1.03	76249.28
12	6.92	11.74	62.75	1.11	17.70	10.43	1.00	74491.97
13	13.46	11.46	59.50	1.38	18.24	9.86	0.97	79586.94
14	4.77	11.27	58.40	1.58	17.01	10.07	0.97	78207.48
15	12.19	11.49	63.31	1.34	17.56	10.26	0.98	79248.45
16	6.04	11.55	41.38	1.70	16.81	10.22	0.97	79174.26
17	12.89	11.40	39.06	1.40	17.78	10.12	0.97	79139.90
18	6.91	13.47	38.24	2.18	15.42	10.43	0.98	79407.13
19	11.28	11.96	48.47	1.21	18.22	10.49	1.01	77752.02
20	9.62	12.26	54.15	2.16	16.07	10.75	1.02	80514.30
21	7.40	15.53	44.24	2.85	14.74	10.73	1.02	79703.79
22	11.63	12.05	60.77	2.14	16.00	10.79	1.02	78819.23
23	6.17	12.66	60.28	1.53	17.25	10.99	1.02	74550.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.09	11.89	46.81	1.49	16.87	10.41	1.01	78631.87
最大值	13.46	15.53	63.31	2.85	18.24	10.99	1.04	80514.30
發生時間	13	21	15	21	13	23		20
最小值	4.77	11.27	36.86	0.62	14.74	9.86	0.97	74491.97
發生時間	14	14	3	10	21	13		12
零點偏移(率)	-0.02 %	-0.05 %	-0.04 %	-0.01 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-1.83 %	-2.20 %	-0.43 %	-0.25 %		0.12	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.35	11.09	45.19	2.66	18.26	9.59	1.43	74931.07
1	6.29	11.79	54.61	2.89	18.74	10.22	1.45	74587.06
2	8.33	11.33	50.58	3.02	17.70	9.83	1.43	76943.30
3	10.20	11.18	54.12	3.42	17.30	9.92	1.43	77218.33
4	6.28	11.44	58.74	2.89	18.18	10.16	1.43	75493.72
5	10.28	11.47	53.71	3.12	17.72	9.97	1.42	76674.11
6	9.14	11.20	46.06	3.27	17.37	9.45	1.42	79625.71
7	5.17	13.21	50.70	2.77	16.69	10.01	1.42	74403.46
8	6.64	11.57	56.76	3.04	16.43	10.38	1.42	75930.14
9	5.61	11.39	55.74	2.96	16.50	10.23	1.43	76086.63
10	7.32	11.66	51.79	2.64	16.36	10.20	1.43	74321.42
11	7.91	11.66	55.46	1.56	17.14	9.91	1.42	74883.42
12	8.58	11.34	52.68	1.51	17.42	9.79	1.42	75936.71
13	8.19	11.61	48.74	1.48	16.71	9.83	1.41	76621.93
14	6.63	11.26	55.53	1.49	17.62	9.80	1.40	74568.53
15	8.27	11.81	45.54	1.60	17.55	9.64	1.41	75776.18
16	8.55	12.85	47.17	1.51	16.04	9.95	1.42	73980.08
17	7.38	11.30	52.41	1.53	15.62	10.07	1.40	76937.08
18	9.92	11.47	62.43	1.60	16.68	10.23	1.42	79184.28
19	9.56	11.64	51.69	2.28	16.19	10.08	1.40	76982.46
20	7.90	11.48	48.37	3.11	16.82	9.75	1.39	75359.54
21	7.27	11.55	51.88	3.08	18.15	9.40	1.38	78533.53
22	9.37	11.80	45.89	0.06	17.72	9.72	1.39	75798.58
23	10.00	10.09	43.47	1.91	16.92	9.60	1.39	75639.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.09	11.55	51.64	2.31	17.16	9.91	1.42	76100.68
最大值	10.28	13.21	62.43	3.42	18.74	10.38	1.52	79625.71
發生時間	5	7	18	3	1	8		6
最小值	5.17	10.09	43.47	0.06	15.62	9.40	1.36	73980.08
發生時間	7	23	23	22	17	21		16
零點偏移(率)	-0.01 %	-0.04 %	-0.03 %	-0.01 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-0.70 %	-0.10 %	-0.31 %	-0.03 %		0.13	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								