

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月06日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.27	5.46	63.40	0.92	18.34	11.53	1.34	74101.90
1	4.62	3.25	57.99	1.30	20.01	10.80	1.34	78980.15
2	5.56	7.49	49.17	2.60	17.16	11.17	1.34	77993.52
3	3.23	3.08	55.81	1.71	17.51	11.16	1.34	79066.58
4	1.81	6.08	54.88	2.23	16.44	11.46	1.34	79262.73
5	2.38	3.15	63.48	1.98	16.63	11.51	1.34	85513.54
6	1.78	2.81	61.23	2.19	16.63	11.37	1.34	79799.61
7	1.55	8.07	60.95	2.38	16.42	11.49	1.34	79688.09
8	4.45	3.54	57.64	1.94	17.36	11.86	1.34	79859.44
9	2.32	5.85	46.66	1.96	17.82	11.20	1.34	84096.56
10	1.96	5.48	43.06	2.54	16.31	11.50	1.34	80019.23
11	0.78	3.91	52.48	1.74	16.81	11.92	1.33	75534.56
12	0.85	3.23	46.24	2.01	16.69	11.74	1.31	78163.77
13	2.08	3.22	52.11	2.13	16.14	11.87	1.31	77311.48
14	3.94	2.95	57.43	1.44	17.57	11.33	1.32	76718.45
15	8.40	4.64	48.40	2.57	17.00	11.08	1.34	79741.50
16	4.75	8.18	46.34	2.20	16.25	11.16	1.34	79907.97
17	1.30	2.90	62.80	2.00	16.54	11.86	1.36	75258.69
18	1.76	6.04	55.02	1.39	18.30	10.70	1.36	83328.32
19	16.52	7.12	54.23	2.93	17.42	10.66	1.36	84364.56
20	12.61	2.44	52.09	3.40	17.14	10.89	1.34	82500.73
21	8.86	2.03	50.11	2.43	17.32	10.74	1.34	80722.13
22	6.55	4.95	63.47	1.96	16.82	11.48	1.34	76725.61
23	0.49	4.97	63.12	1.14	17.41	11.52	1.34	77644.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.12	4.62	54.92	2.05	17.17	11.33	1.34	79429.31
最 大 值	16.52	8.18	63.48	3.40	20.01	11.92	1.38	85513.54
發生時間	19	16	5	20	1	11		5
最 小 值	0.27	2.03	43.06	0.92	16.14	10.66	1.31	74101.90
發生時間	0	21	10	0	13	19		0
零點偏移(率)	-0.04 %	-0.02 %	-0.03 %	-0.00 %		-0.05		0.20 %
全幅偏移(率)	0.00 %	0.31 %	0.34 %	1.55 %		-0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月06日

報表日期: 114年05月06日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.89	6.16	54.31	1.75	17.38	10.25	1.48	76037.93
1	5.66	2.43	64.86	2.10	18.09	10.37	1.50	78189.18
2	8.95	3.40	67.89	2.82	15.10	10.88	1.50	79405.34
3	7.85	1.78	69.46	2.88	15.47	10.79	1.48	77934.58
4	10.21	6.28	55.95	2.91	17.98	9.64	1.49	84321.62
5	8.77	3.04	51.80	3.46	15.19	10.33	1.51	79455.94
6	3.40	4.74	54.19	2.39	15.70	10.44	1.52	77725.20
7	1.99	2.34	51.16	2.54	14.95	10.06	1.51	75958.88
8	0.64	3.26	56.85	2.58	14.97	9.90	1.48	72830.50
9	0.80	1.32	63.15	2.48	15.78	9.98	1.48	75935.36
10	1.56	4.16	58.30	2.31	17.34	9.52	1.50	77734.76
11	2.17	7.24	60.03	2.39	16.66	9.84	1.52	79761.25
12	2.59	3.38	63.10	2.76	14.84	10.60	1.50	75588.36
13	1.87	1.32	66.55	2.78	15.22	10.54	1.51	74703.40
14	3.21	3.52	59.91	2.35	17.38	10.01	1.52	78193.86
15	4.99	3.25	55.58	2.37	16.21	9.83	1.52	78742.76
16	4.42	5.53	59.12	2.72	15.33	9.87	1.50	77284.68
17	1.55	1.51	66.55	2.15	16.80	10.12	1.47	77639.93
18	1.77	2.74	60.67	2.12	17.62	9.63	1.50	83589.04
19	1.08	5.85	55.22	2.26	19.17	8.98	1.52	84680.64
20	1.33	3.16	54.48	2.33	16.72	9.33	1.49	81912.13
21	1.34	4.65	59.89	2.35	17.01	9.75	1.47	80470.97
22	4.29	1.87	69.42	2.45	16.71	10.35	1.48	83865.10
23	3.92	3.96	64.18	2.47	18.61	9.61	1.48	81373.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.72	3.62	60.11	2.49	16.51	10.03	1.50	78888.94
最 大 值	10.21	7.24	69.46	3.46	19.17	10.88	1.53	84680.64
發生時間	4	11	3	5	19	2		19
最 小 值	0.64	1.32	51.16	1.75	14.84	8.98	1.46	72830.50
發生時間	8	9	7	0	12	19		8
零點偏移(率)	-0.02 %	0.00 %	-0.11 %	-0.04 %		-0.02		0.20 %
全幅偏移(率)	-1.46 %	0.20 %	-0.72 %	0.68 %		-0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								