

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月19日

報表日期: 113年02月19日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.90	7.81	45.29	0.77	17.49	11.32	1.02	83276.34
1	4.46	7.08	54.76	0.58	18.88	11.08	1.02	83926.21
2	9.57	10.54	52.20	1.44	16.70	11.40	1.02	83369.99
3	10.18	7.60	44.45	1.39	16.11	11.69	0.99	81548.09
4	9.78	7.73	44.21	2.26	13.83	12.21	1.00	79026.97
5	6.76	11.15	54.16	0.92	16.13	12.31	1.01	75612.15
6	9.36	7.54	51.88	0.95	16.90	11.46	1.01	82785.57
7	5.16	7.91	55.03	1.52	15.33	12.24	1.01	77199.61
8	8.05	3.51	67.68	0.54	18.03	11.57	1.03	80641.92
9	5.46	4.14	63.57	0.33	17.11	11.36	1.02	82891.69
10	7.78	3.69	57.34	0.62	16.83	11.68	1.03	80203.93
11	6.08	4.48	51.25	0.93	15.93	12.07	1.02	77790.27
12	3.59	4.90	63.05	0.86	15.62	12.83	1.04	71388.53
13	6.71	5.21	35.25	0.95	15.79	11.81	1.03	80287.98
14	8.65	4.74	42.25	1.55	15.28	11.80	1.01	80723.61
15	7.66	3.49	46.71	1.37	15.15	11.94	1.01	80009.72
16	9.17	8.14	47.94	1.19	15.71	11.82	1.03	80191.31
17	6.90	8.52	55.81	0.58	16.52	11.67	1.03	80843.99
18	4.27	12.16	64.95	0.87	15.72	12.96	1.04	70280.73
19	5.54	7.65	44.30	0.64	17.24	11.14	1.03	84927.26
20	8.97	7.44	40.56	1.63	15.49	11.48	1.02	83416.80
21	9.71	5.99	41.47	2.45	14.54	11.69	1.02	82411.63
22	9.27	5.47	59.78	1.06	16.78	11.83	1.02	79051.40
23	8.01	9.85	52.47	0.87	16.35	12.51	1.03	74127.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.50	6.95	51.51	1.09	16.23	11.83	1.02	79830.56
最 大 值	10.18	12.16	67.68	2.45	18.88	12.96	1.13	84927.26
發生時間	3	18	8	21	1	18		19
最 小 值	3.59	3.49	35.25	0.33	13.83	11.08	0.99	70280.73
發生時間	12	15	13	9	4	1		18
零點偏移(率)	0.00 %	-0.01 %	-0.02 %	-0.00 %		-0.04		0.00 %
全幅偏移(率)	0.02 %	0.09 %	-0.02 %	0.22 %		-0.21		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月19日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.69	6.16	40.41	1.68	16.92	10.79	1.06	81730.29
1	8.62	7.18	44.18	2.20	15.42	11.18	1.06	79958.37
2	7.26	2.30	57.90	2.94	13.65	12.18	1.05	73573.13
3	7.63	4.11	45.29	2.19	14.55	11.53	1.04	79671.76
4	8.64	3.98	46.58	2.02	14.92	11.36	1.04	79700.71
5	6.99	5.83	47.21	2.48	14.72	11.53	1.04	77832.74
6	7.16	4.78	47.79	3.93	14.04	11.99	1.06	73208.22
7	6.43	4.48	50.21	3.20	14.37	12.12	1.06	73575.88
8	6.45	3.21	41.81	1.74	17.02	10.88	1.08	81551.68
9	2.70	3.55	48.05	1.68	15.50	11.80	1.07	75246.58
10	0.61	2.91	60.16	1.24	16.28	11.63	1.08	75459.81
11	1.55	4.03	49.21	2.52	13.60	12.32	1.07	71859.16
12	1.21	2.92	57.55	1.64	15.50	11.61	1.07	76472.29
13	1.26	3.51	48.06	2.10	15.00	11.41	1.08	78205.62
14	1.35	6.07	42.34	2.88	13.60	11.52	1.07	78612.33
15	1.94	3.40	49.29	2.90	13.20	12.06	1.08	74690.97
16	3.20	3.46	49.86	2.31	14.38	11.58	1.06	77697.64
17	5.28	2.95	57.09	1.69	15.96	11.42	1.06	77462.35
18	7.90	3.45	44.23	1.91	16.54	10.85	1.06	81926.57
19	9.67	4.72	41.96	3.05	14.75	11.12	1.04	80583.97
20	10.49	4.62	48.41	3.08	13.99	11.50	1.05	78239.23
21	8.85	3.33	54.94	1.43	17.02	10.98	1.06	80805.07
22	9.61	3.98	47.65	1.70	16.60	11.11	1.07	79340.35
23	4.13	5.97	59.88	0.87	17.05	11.82	1.08	73882.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.73	4.20	49.17	2.22	15.19	11.51	1.06	77553.65
最 大 值	10.49	7.18	60.16	3.93	17.05	12.32	1.10	81926.57
發生時間	20	1	10	6	23	11		18
最 小 值	0.61	2.30	40.41	0.87	13.20	10.79	1.03	71859.16
發生時間	10	2	0	23	15	0		11
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	-0.03 %		0.03		-0.20 %
全幅偏移(率)	0.02 %	0.46 %	-0.17 %	0.11 %		-0.12		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月19日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.49	7.27	57.97	0.59	17.10	10.32	1.05	82239.72
1	1.07	9.37	60.99	1.29	15.31	11.41	1.05	74391.80
2	5.20	7.12	52.80	2.40	13.45	10.89	1.04	76908.57
3	6.06	11.28	53.68	2.10	14.34	11.15	1.04	74491.83
4	6.90	2.41	48.72	2.09	14.80	10.61	1.04	79679.25
5	8.29	3.08	53.82	1.39	15.19	10.80	1.04	80313.65
6	7.81	5.66	51.60	1.12	15.61	10.77	1.04	80665.27
7	1.80	7.96	58.37	0.74	15.80	11.32	1.05	76451.05
8	4.81	3.01	53.44	0.79	17.45	10.20	1.06	82228.04
9	1.46	3.27	59.90	0.65	15.75	11.40	1.05	72313.48
10	0.90	3.15	54.30	0.45	15.93	11.14	1.05	72276.88
11	2.37	3.39	53.24	0.24	17.07	10.76	1.06	74436.40
12	2.35	4.02	50.23	0.65	15.26	10.91	1.05	72617.59
13	2.35	5.05	55.63	0.65	16.08	10.76	1.04	73840.19
14	2.76	7.07	46.19	1.35	14.00	10.74	1.04	76893.77
15	6.22	7.62	53.58	2.21	13.05	11.53	1.03	69339.93
16	3.40	4.49	48.03	0.88	15.47	10.30	1.05	76420.23
17	2.33	4.51	47.09	0.56	16.04	10.25	1.06	78300.00
18	4.14	2.90	56.23	0.46	17.12	10.20	1.04	81653.60
19	6.98	6.72	50.61	1.63	14.21	10.66	1.04	79917.88
20	9.33	4.16	60.93	1.89	14.39	11.07	1.04	76282.57
21	6.92	4.21	54.36	0.89	16.58	10.23	1.04	80868.39
22	4.77	4.64	59.67	0.54	17.65	10.37	1.04	80439.81
23	4.97	6.30	56.24	0.84	15.59	11.69	1.04	71630.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.40	5.36	54.07	1.10	15.55	10.81	1.04	76858.37
最 大 值	9.33	11.28	60.99	2.40	17.65	11.69	1.08	82239.72
發生時間	20	3	1	2	22	23		0
最 小 值	0.90	2.41	46.19	0.24	13.05	10.20	1.02	69339.93
發生時間	10	4	14	11	15	8		15
零點偏移(率)	-0.06 %	-0.02 %	-0.05 %	-0.03 %		0.07		-0.10 %
全幅偏移(率)	0.02 %	0.16 %	-0.13 %	0.08 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								