

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.93	10.23	55.73	1.02	17.39	11.57	1.07	79169.43
1	2.99	11.60	61.41	0.64	18.53	12.17	1.07	74004.22
2	8.76	8.92	48.23	1.63	18.69	10.91	1.06	81436.55
3	9.30	22.01	49.19	3.21	15.25	11.83	1.05	74217.64
4	5.11	9.01	49.97	2.28	15.80	11.51	1.05	75375.49
5	7.43	11.29	43.46	1.94	16.04	11.51	1.09	76269.80
6	6.65	11.20	46.89	2.27	15.29	11.60	1.05	73771.68
7	6.88	8.88	55.79	1.30	18.45	10.92	1.05	80275.58
8	8.19	8.50	50.07	1.60	17.23	11.23	1.05	75297.36
9	9.72	8.70	60.71	1.38	18.26	11.17	1.03	77976.08
10	5.98	9.30	56.97	1.13	17.75	11.51	1.05	76927.93
11	6.14	10.36	50.78	1.39	17.37	11.25	1.05	76874.39
12	2.70	11.67	56.02	1.08	17.56	11.42	1.04	77044.14
13	2.76	12.15	55.11	0.96	17.29	11.64	1.04	77551.64
14	5.48	13.56	56.80	1.34	18.23	11.25	1.05	78386.83
15	9.48	11.27	46.93	2.81	15.43	11.63	1.03	72664.30
16	8.52	9.24	45.36	2.75	16.31	11.18	1.02	75869.38
17	8.42	10.27	45.50	2.66	15.65	11.50	1.02	73457.32
18	8.42	6.18	50.44	2.04	16.48	11.46	1.04	73024.02
19	8.08	6.82	57.56	1.21	17.81	11.22	1.05	77482.93
20	3.64	11.17	54.07	1.72	16.08	11.97	1.06	75188.46
21	3.89	8.35	55.86	1.31	16.75	11.87	1.06	72850.25
22	4.60	9.54	52.31	0.92	18.17	11.02	1.05	78592.65
23	3.48	12.76	60.19	1.10	17.45	11.67	1.05	73222.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.44	10.54	52.72	1.65	17.05	11.46	1.05	76122.13
最大值	9.72	22.01	61.41	3.21	18.69	12.17	1.13	81436.55
發生時間	9	3	1	3	2	1		2
最小值	2.70	6.18	43.46	0.64	15.25	10.91	1.02	72664.30
發生時間	12	18	5	1	3	2		15
零點偏移(率)	-0.01 %	0.00 %	-0.07 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.35 %	0.03 %	0.39 %		-0.22		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.82	9.35	54.61	0.96	18.15	10.63	1.06	80998.13
1	6.27	11.46	49.68	1.16	19.81	9.93	1.07	85222.09
2	9.37	15.43	54.02	2.44	16.82	10.45	1.06	83508.40
3	8.71	7.03	56.91	2.09	17.74	10.34	1.07	84081.64
4	9.13	3.17	47.14	1.73	17.90	10.03	1.06	86251.46
5	8.12	9.36	50.05	2.06	16.64	10.68	1.06	81597.02
6	10.52	7.04	49.73	1.65	18.34	9.88	1.07	81395.20
7	8.30	4.67	51.07	1.79	17.98	9.90	1.07	85785.83
8	7.25	4.41	48.98	1.60	18.34	9.96	1.08	83047.13
9	8.95	6.07	51.71	1.61	18.30	10.20	1.07	82356.75
10	7.19	10.12	45.76	1.31	19.12	10.23	1.07	82757.39
11	2.05	7.34	41.51	1.59	18.19	9.85	1.07	85294.69
12	4.70	4.30	54.12	2.06	17.15	10.62	1.08	80436.12
13	4.12	4.39	54.30	1.39	18.40	10.15	1.10	83567.30
14	10.41	7.55	56.68	1.84	17.04	10.37	1.10	80335.04
15	14.40	10.95	45.42	2.21	16.72	10.23	1.08	80571.97
16	10.08	8.70	50.52	2.41	16.28	10.59	1.08	80777.52
17	9.16	5.85	64.74	1.23	17.81	10.52	1.08	81432.05
18	9.01	12.73	54.97	1.05	19.32	10.09	1.07	83273.92
19	9.17	9.81	49.41	1.80	16.54	10.43	1.07	81572.71
20	9.70	5.98	58.40	1.23	18.48	10.02	1.08	83732.69
21	9.91	5.08	52.04	1.36	19.66	9.49	1.07	87732.17
22	8.74	7.55	51.03	1.33	18.99	9.94	1.06	84469.72
23	7.37	8.05	53.99	0.79	19.21	10.09	1.07	83143.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.23	7.77	51.95	1.61	18.04	10.19	1.07	83055.84
最大值	14.40	15.43	64.74	2.44	19.81	10.68	1.11	87732.17
發生時間	15	2	17	2	1	5		21
最小值	2.05	3.17	41.51	0.79	16.28	9.49	1.05	80335.04
發生時間	11	4	11	23	16	21		14
零點偏移(率)	0.00 %	-0.02 %	-0.01 %	0.00 %		-0.06		0.00 %
全幅偏移(率)	0.02 %	0.08 %	-0.29 %	0.19 %		-0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.48	4.02	59.07	1.12	17.55	10.17	1.06	80513.48
1	7.73	8.69	45.78	1.05	17.14	10.76	1.06	78248.47
2	9.12	5.38	49.86	1.27	16.86	10.49	1.05	79464.75
3	9.96	11.02	53.95	2.32	14.52	11.17	1.04	77679.61
4	10.02	12.14	55.56	2.05	14.84	10.86	1.05	80010.63
5	8.80	11.89	54.33	1.80	15.70	10.89	1.05	76376.43
6	9.93	6.65	49.33	1.83	15.15	11.14	1.05	79735.00
7	8.84	11.59	51.12	0.71	18.25	10.66	1.05	81119.96
8	9.99	6.90	48.80	1.61	15.66	10.60	1.03	82259.80
9	9.92	9.03	63.85	1.25	16.93	10.99	1.06	80184.39
10	8.11	8.47	46.47	1.66	15.52	10.65	1.02	79008.94
11	7.83	5.10	46.46	1.15	16.35	10.59	1.03	76407.96
12	8.15	6.69	52.75	0.90	16.82	10.68	1.06	77733.82
13	10.03	5.11	50.05	1.24	16.85	10.47	1.04	78436.11
14	8.76	11.26	55.03	1.19	16.27	10.60	1.05	79292.22
15	9.01	10.31	46.68	2.21	14.06	10.73	1.05	74623.08
16	9.32	6.08	39.46	1.79	14.93	10.38	0.99	75449.50
17	9.91	6.86	56.37	1.43	15.75	10.53	1.00	73654.10
18	9.74	9.09	48.62	1.67	15.48	10.37	0.99	73515.82
19	9.58	5.36	50.02	1.09	17.02	10.06	1.01	77601.48
20	7.92	9.88	42.68	1.48	15.06	10.42	1.04	73978.39
21	8.09	6.21	44.58	1.11	15.46	10.61	1.05	73969.47
22	8.38	9.68	51.92	0.92	16.79	10.21	1.05	76372.21
23	9.00	8.77	45.34	1.03	16.30	10.49	1.04	75897.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.11	8.17	50.34	1.41	16.05	10.61	1.04	77563.87
最大值	10.48	12.14	63.85	2.32	18.25	11.17	1.07	82259.80
發生時間	0	4	9	3	7	3		8
最小值	7.73	4.02	39.46	0.71	14.06	10.06	0.99	73515.82
發生時間	1	0	16	7	15	19		18
零點偏移(率)	-0.15 %	0.00 %	-0.24 %	-0.06 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.23 %	0.23 %	0.21 %		0.08		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								