

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年10月04日

報表日期: 113年10月04日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.98	3.65	52.87	0.65	19.10	11.27	1.07	82559.64
1	6.18	4.40	63.29	0.38	18.18	11.89	1.08	78863.85
2	8.77	3.96	56.29	0.48	18.63	11.03	1.07	85125.65
3	9.57	3.57	36.93	0.68	19.18	10.98	1.06	85250.60
4	9.17	4.48	33.02	1.10	17.07	11.60	1.05	81378.96
5	10.76	5.56	53.61	3.08	17.27	11.44	1.03	83945.32
6	7.54	2.40	56.24	2.66	16.88	11.55	1.04	82352.93
7	12.01	2.48	59.84	1.08	16.97	11.65	1.04	81723.99
8	8.89	2.84	44.76	1.09	17.11	12.02	1.05	78906.65
9	8.32	7.92	60.41	0.76	17.36	12.13	1.05	80107.34
10	3.34	10.95	65.02	0.88	16.38	12.51	1.03	77784.56
11	3.16	13.24	65.15	1.00	16.36	12.59	1.02	77491.93
12	1.41	14.78	67.67	0.54	17.43	12.87	1.02	74160.34
13	3.37	14.81	69.93	0.34	18.59	12.02	1.01	80177.19
14	2.62	15.24	63.16	0.37	19.37	11.57	1.02	83822.20
15	5.20	10.92	55.33	0.53	17.68	12.05	1.03	81374.47
16	3.09	14.69	61.28	0.62	17.33	12.59	1.02	76911.21
17	4.90	14.04	48.85	0.45	19.30	11.34	1.02	85851.76
18	7.58	13.70	49.31	0.58	18.59	11.80	1.02	82556.59
19	8.35	14.95	43.50	1.12	18.66	11.43	1.02	85276.64
20	8.41	9.22	53.83	0.57	18.70	11.59	1.02	80994.20
21	3.47	3.44	56.35	0.33	18.88	11.70	1.04	79501.26
22	3.21	3.68	50.68	0.46	18.72	11.99	1.06	77009.05
23	2.24	4.43	47.06	0.30	19.61	11.64	1.07	79252.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.27	8.31	54.77	0.84	18.06	11.80	1.04	80932.46
最 大 值	12.01	15.24	69.93	3.08	19.61	12.87	1.11	85851.76
發生時間	7	14	13	5	23	12		17
最 小 值	1.41	2.40	33.02	0.30	16.36	10.98	1.00	74160.34
發生時間	12	6	4	23	11	3		12
零點偏移(率)	0.00 %	-0.03 %	-0.01 %	0.00 %		-0.05		0.00 %
全幅偏移(率)	-0.67 %	0.03 %	-0.82 %	0.36 %		0.13		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年10月04日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.32	1.82	44.99	0.97	19.16	11.02	0.86	86308.92
1	2.66	9.37	45.57	1.71	18.14	10.58	0.89	87424.00
2	9.65	1.53	57.29	0.51	19.13	10.99	0.90	82099.75
3	16.31	2.14	40.31	1.63	17.64	10.61	0.89	86430.13
4	8.86	3.56	37.84	2.01	16.29	11.00	0.87	83566.36
5	4.21	2.30	46.50	2.14	16.33	11.11	0.88	82132.86
6	5.05	2.80	43.94	0.87	17.74	10.93	0.90	81042.61
7	3.55	1.97	40.91	0.39	18.29	10.77	0.92	83067.99
8	9.38	2.95	52.73	0.50	19.24	10.41	0.92	85271.69
9	10.44	2.58	38.57	0.82	17.26	10.83	0.91	84384.86
10	9.53	2.18	49.91	1.17	17.77	11.59	0.91	80894.64
11	6.96	2.08	48.32	1.13	17.43	11.65	0.90	83241.18
12	11.22	2.02	46.87	1.18	16.51	11.79	0.90	83609.28
13	5.94	1.90	51.57	0.59	16.72	11.65	0.91	82063.49
14	2.33	2.64	49.81	0.84	16.46	11.24	0.92	82594.34
15	3.43	2.00	59.23	0.82	17.44	11.42	0.91	79526.35
16	11.55	6.05	43.26	0.56	18.58	10.39	0.92	84776.33
17	10.66	1.79	46.71	0.34	19.17	10.25	0.91	87025.25
18	9.90	1.66	46.71	0.66	18.61	10.50	0.92	84849.58
19	10.38	1.61	54.52	0.30	19.30	10.46	0.92	84659.24
20	6.50	2.18	59.31	0.22	19.32	10.75	0.93	82056.27
21	6.32	5.88	53.64	0.37	20.36	10.15	0.94	85398.70
22	4.37	2.62	55.29	0.89	19.11	10.50	0.92	84061.05
23	7.61	5.83	48.07	2.64	19.22	10.51	0.92	83525.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.84	2.98	48.41	0.97	18.13	10.88	0.91	83750.42
最 大 值	16.31	9.37	59.31	2.64	20.36	11.79	0.94	87424.00
發生時間	3	1	20	23	21	12		1
最 小 值	2.33	1.53	37.84	0.22	16.29	10.15	0.84	79526.35
發生時間	14	2	4	20	4	21		15
零點偏移(率)	-0.08 %	-0.00 %	-0.04 %	0.00 %		-0.52		-0.20 %
全幅偏移(率)	0.14 %	-0.55 %	-1.14 %	1.23 %		0.14		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年10月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.18	2.19	59.32	0.78	17.58	11.14	1.73	76319.83
1	8.38	2.58	56.74	0.86	20.52	10.38	1.75	80386.26
2	9.92	2.33	41.84	1.31	17.10	10.50	1.73	81548.29
3	12.79	6.75	37.08	1.66	15.50	11.07	1.70	77164.20
4	10.18	4.26	54.51	1.13	16.77	10.72	1.70	76659.32
5	13.48	4.93	47.54	2.59	15.83	10.53	1.69	77461.98
6	11.52	3.27	58.77	2.12	14.49	11.15	1.70	73419.00
7	12.69	3.44	49.18	1.87	15.73	10.99	1.70	75321.30
8	8.87	2.57	47.57	1.19	17.96	10.20	1.69	80777.80
9	9.16	3.59	53.80	1.11	16.58	10.98	1.69	77887.35
10	12.98	2.03	58.13	1.66	15.84	11.21	1.68	78090.54
11	7.98	2.40	52.08	1.29	16.19	10.77	1.69	76602.75
12	11.82	2.09	61.27	1.12	17.64	10.60	1.71	81386.49
13	8.15	3.45	48.32	1.30	15.20	11.36	1.71	75851.05
14	7.25	2.16	59.87	0.84	17.09	11.11	1.70	77072.12
15	8.65	3.07	53.81	0.78	16.98	10.97	1.69	76506.47
16	8.20	2.69	57.20	0.95	17.00	10.95	1.70	78625.16
17	7.42	2.13	53.50	0.98	16.70	10.91	1.70	79843.03
18	9.70	2.21	59.18	1.03	17.36	10.79	1.71	80006.92
19	8.02	2.20	64.00	1.01	18.09	10.76	1.71	79944.68
20	9.93	2.45	55.62	0.98	17.88	10.50	1.69	82521.15
21	9.86	2.35	58.95	1.00	18.64	10.21	1.70	83416.81
22	9.46	3.32	52.14	1.05	18.96	10.02	1.70	80204.60
23	15.74	1.06	51.09	1.67	18.55	9.85	1.69	80685.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.97	2.90	53.81	1.26	17.09	10.74	1.70	78654.27
最 大 值	15.74	6.75	64.00	2.59	20.52	11.36	1.77	83416.81
發生時間	23	3	19	5	1	13		21
最 小 值	7.18	1.06	37.08	0.78	14.49	9.85	1.67	73419.00
發生時間	0	23	3	0	6	23		6
零點偏移(率)	-0.15 %	-0.01 %	-0.02 %	0.00 %		0.00		-0.10 %
全幅偏移(率)	0.02 %	0.23 %	-0.62 %	0.08 %		0.38		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								