

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.03	12.93	65.29	0.56	19.70	11.80	1.06	76738.71
1	8.01	10.89	52.43	0.69	21.07	10.85	1.06	82447.78
2	9.68	10.50	57.94	1.05	17.81	11.34	1.07	82115.76
3	10.10	13.26	46.10	1.95	16.39	12.07	1.07	76657.82
4	7.26	10.01	68.94	1.14	16.70	12.19	1.07	75121.48
5	10.43	11.52	39.40	2.36	16.50	11.64	1.07	75573.12
6	7.91	11.52	58.98	1.85	16.19	12.51	1.06	71739.92
7	8.31	10.97	62.54	1.21	17.75	11.80	1.05	77532.55
8	10.28	11.84	52.40	1.44	17.06	11.69	1.06	77493.32
9	6.81	14.22	59.85	1.29	16.64	12.02	1.05	76202.06
10	8.99	12.24	53.01	1.18	17.91	11.44	1.05	80584.80
11	8.13	14.29	51.18	1.45	17.19	11.76	1.05	77656.90
12	7.75	13.48	64.42	1.67	16.26	12.28	1.05	74651.75
13	8.50	9.70	64.65	0.91	18.32	11.51	1.05	79987.25
14	6.90	9.99	52.00	1.64	17.39	11.77	1.04	75196.80
15	9.25	6.32	54.88	1.25	17.65	11.58	1.05	77871.28
16	8.04	7.96	62.59	1.32	17.79	11.90	1.05	76559.70
17	9.30	9.51	54.48	1.28	18.02	11.44	1.06	79389.63
18	8.92	12.74	46.84	1.57	17.57	11.62	1.07	78822.75
19	13.05	9.31	55.99	2.64	16.66	11.78	1.07	78079.00
20	6.10	4.51	63.32	0.79	18.13	11.74	1.07	77541.89
21	9.37	4.48	45.70	1.36	17.84	11.50	1.07	79558.50
22	9.02	5.73	61.16	1.44	18.16	11.49	1.07	79761.63
23	9.76	8.16	49.37	1.64	17.39	11.49	1.08	79883.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.62	10.25	55.98	1.40	17.59	11.72	1.06	77798.66
最大值	13.05	14.29	68.94	2.64	21.07	12.51	1.09	82447.78
發生時間	19	11	4	19	1	6		1
最小值	5.03	4.48	39.40	0.56	16.19	10.85	1.02	71739.92
發生時間	0	21	5	0	6	1		6
零點偏移(率)	0.00 %	0.00 %	-0.03 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.02 %	0.03 %	0.02 %	0.03 %		-0.10		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.45	6.97	54.02	0.97	20.23	10.11	1.14	81998.36
1	8.68	7.67	56.36	1.07	21.81	9.49	1.14	85719.42
2	7.86	9.92	50.33	1.35	19.49	9.86	1.15	83659.33
3	7.82	8.59	55.73	1.25	19.90	10.38	1.15	79244.58
4	9.85	7.18	57.61	1.44	19.90	9.69	1.15	85176.38
5	7.76	13.96	59.71	1.45	19.78	9.86	1.15	83733.42
6	8.83	7.12	61.53	1.17	20.02	9.92	1.13	79136.16
7	8.10	10.08	51.99	1.26	20.17	10.09	1.12	81176.29
8	8.90	4.66	55.30	1.14	19.79	9.61	1.15	86322.50
9	9.45	5.91	50.43	1.33	19.15	10.01	1.14	83063.01
10	9.88	6.16	59.54	1.65	17.96	10.08	1.14	83627.23
11	12.34	6.84	54.47	1.45	18.64	10.21	1.12	82871.24
12	10.35	15.03	46.06	1.31	20.01	9.77	1.12	84823.17
13	9.43	9.59	49.38	1.45	19.17	10.00	1.13	83872.92
14	10.56	5.31	59.52	1.24	19.67	9.72	1.13	85706.95
15	8.46	5.54	61.21	0.92	19.91	10.24	1.14	80736.59
16	6.54	11.60	48.48	1.70	22.17	9.29	1.15	85907.34
17	9.18	11.11	38.44	1.21	21.15	8.95	1.16	84071.27
18	9.53	3.29	58.97	0.71	21.23	9.50	1.15	84666.53
19	9.27	11.45	41.37	0.82	22.16	9.11	1.14	87106.88
20	8.24	13.86	61.05	0.91	22.08	9.18	1.15	86558.40
21	10.13	8.17	45.82	1.79	19.51	9.52	1.14	84674.18
22	9.15	6.34	42.91	1.21	21.36	9.35	1.15	87663.76
23	8.76	7.09	40.48	1.52	19.76	9.91	1.15	84369.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.06	8.48	52.53	1.26	20.21	9.74	1.14	83995.24
最大值	12.34	15.03	61.53	1.79	22.17	10.38	1.19	87663.76
發生時間	11	12	6	21	16	3		22
最小值	6.54	3.29	38.44	0.71	17.96	8.95	1.12	79136.16
發生時間	16	18	17	18	10	17		6
零點偏移(率)	-0.05 %	-0.01 %	-0.04 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.04 %	1.30 %	0.23 %	0.55 %		-0.26		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.13	14.46	62.03	0.90	18.35	10.92	1.04	84592.20
1	1.11	11.68	61.38	0.92	18.33	11.20	1.02	81965.92
2	1.96	11.32	60.33	1.06	16.71	11.32	1.00	82176.56
3	9.13	9.80	55.81	1.62	16.47	11.06	0.99	84897.30
4	15.52	10.08	60.62	2.64	15.48	11.41	0.99	83228.60
5	9.47	10.63	56.42	2.20	15.03	11.75	1.02	82451.82
6	9.62	8.80	61.92	1.94	15.79	11.62	1.02	81475.84
7	7.58	12.87	57.10	3.01	13.64	12.05	1.04	85376.91
8	9.33	13.02	51.03	2.17	15.11	10.91	1.00	74304.27
9	2.20	12.61	40.38	1.23	15.74	10.28	0.99	70924.45
10	2.30	8.93	50.06	1.34	15.74	10.38	1.01	72097.99
11	0.25	5.73	60.37	0.93	16.13	11.34	1.06	77574.16
12	0.85	14.83	52.00	1.05	15.99	10.89	1.06	79809.18
13	5.21	9.52	64.33	1.73	15.29	11.46	1.05	75021.40
14	0.25	7.58	57.85	0.84	16.59	11.49	1.04	78894.78
15	1.77	12.49	48.97	1.15	15.99	10.89	1.01	78201.03
16	0.28	3.40	56.91	0.87	17.90	10.74	1.01	75591.60
17	0.01	9.62	54.79	0.90	18.82	10.35	1.02	79486.25
18	0.65	10.59	52.47	1.01	18.37	10.21	1.00	82012.07
19	7.38	16.30	39.45	1.50	15.96	10.80	1.00	78484.33
20	9.91	9.61	54.98	1.53	16.60	11.05	1.00	79275.41
21	1.47	3.33	70.55	0.92	17.82	11.16	0.99	75240.53
22	5.16	6.19	45.59	1.15	16.77	10.87	0.99	75729.82
23	1.65	13.70	53.59	0.88	18.39	10.59	0.99	76651.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.38	10.30	55.37	1.40	16.54	11.03	1.01	78977.66
最大值	15.52	16.30	70.55	3.01	18.82	12.05	1.08	85376.91
發生時間	4	19	21	7	17	7		7
最小值	0.01	3.33	39.45	0.84	13.64	10.21	0.97	70924.45
發生時間	17	21	19	14	7	18		9
零點偏移(率)	0.00 %	-0.01 %	-0.10 %	-0.06 %		0.03		0.00 %
全幅偏移(率)	0.04 %	1.06 %	-1.09 %	0.31 %		0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								