

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.54	12.91	52.39	3.43	16.29	11.64	1.30	79279.08
1	11.48	12.88	53.69	2.47	18.72	10.98	1.29	79764.84
2	12.27	12.51	51.58	3.04	16.66	10.72	1.29	83169.27
3	10.78	14.22	44.03	2.85	15.03	11.32	1.30	79331.17
4	12.35	13.65	46.24	2.25	17.47	11.48	1.31	77954.65
5	11.63	12.85	49.14	3.66	15.37	11.65	1.31	78311.67
6	11.51	13.43	51.18	3.03	16.17	11.76	1.32	75405.61
7	10.24	12.86	45.63	2.83	16.82	11.20	1.31	80230.63
8	6.15	13.42	55.23	3.04	17.26	11.63	1.32	78587.72
9	10.15	13.52	52.35	4.00	16.50	11.69	1.30	78994.13
10	9.82	14.58	39.89	3.75	15.55	11.22	1.29	81881.60
11	10.37	14.16	50.91	1.84	13.35	11.99	1.30	75956.25
12	9.56	14.07	36.14	1.57	14.28	12.14	1.31	75838.02
13	7.00	13.42	47.77	1.27	14.76	11.83	1.32	78041.46
14	12.63	13.44	55.39	2.04	13.69	11.95	1.34	77277.76
15	11.52	13.57	57.92	1.97	15.52	11.98	1.33	75279.33
16	14.12	12.51	58.00	2.33	17.48	10.86	1.31	82600.16
17	7.17	13.09	43.49	3.42	15.39	11.20	1.29	80320.57
18	7.98	12.89	40.68	3.17	16.31	11.25	1.29	81471.85
19	10.18	12.56	38.61	3.48	15.65	11.25	1.29	82062.44
20	8.65	13.32	47.31	2.97	16.60	11.35	1.28	80896.79
21	13.91	13.51	47.68	2.86	15.17	11.93	1.27	77306.65
22	5.51	13.18	48.57	2.03	16.66	11.60	1.27	78533.23
23	9.43	14.41	62.07	2.44	16.54	12.55	1.27	70775.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.16	13.37	49.00	2.74	15.97	11.55	1.30	78719.62
最大值	14.12	14.58	62.07	4.00	18.72	12.55	1.34	83169.27
發生時間	16	10	23	9	1	23		2
最小值	5.51	12.51	36.14	1.27	13.35	10.72	1.27	70775.89
發生時間	22	2	12	13	11	2		23
零點偏移(率)	-0.09 %	-0.00 %	-0.01 %	0.00 %		-0.20	-0.01	0.30 %
全幅偏移(率)	-0.35 %	1.13 %	0.79 %	0.81 %		-0.02	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.44	35.62	62.85	2.06	16.99	11.08	0.83	74989.28
1	8.57	11.21	59.05	1.85	17.20	11.51	0.83	74087.55
2	10.46	10.85	62.16	1.25	17.26	10.95	0.83	75266.36
3	7.91	10.43	62.12	0.76	18.49	10.46	0.83	77556.23
4	8.05	10.01	65.38	1.42	16.28	11.29	0.83	69486.01
5	11.45	11.09	59.30	1.56	17.45	11.62	0.83	67491.48
6	12.57	11.50	55.11	1.51	18.71	10.41	0.81	72309.14
7	8.77	12.43	55.87	1.04	17.45	11.12	0.81	70490.78
8	10.65	9.82	62.91	1.08	16.57	11.35	0.81	77218.41
9	11.75	10.24	55.69	1.18	16.35	11.56	0.80	75911.71
10	7.99	13.78	57.75	1.55	15.12	12.17	0.79	72570.59
11	9.05	15.67	64.26	1.66	14.87	12.38	0.79	73554.81
12	8.31	15.25	50.69	1.59	15.71	12.00	0.80	74962.39
13	8.22	12.31	54.31	1.36	16.45	11.94	0.79	75887.58
14	9.79	11.28	60.86	1.38	16.86	11.55	0.85	79244.70
15	12.78	14.72	59.37	1.96	15.74	11.97	0.81	75038.16
16	8.02	16.31	45.63	1.46	16.45	11.27	0.80	80114.39
17	9.23	12.33	42.39	1.69	16.26	11.06	0.81	83114.32
18	11.47	20.46	46.48	1.10	17.45	11.09	0.81	82034.54
19	7.78	12.96	40.34	0.93	18.25	10.59	0.79	81539.67
20	10.67	11.54	42.08	1.62	16.92	11.24	0.80	79962.32
21	10.83	13.04	40.00	1.22	17.14	11.20	0.79	80956.83
22	6.65	12.58	50.07	1.39	15.73	12.25	0.79	69496.93
23	10.51	13.08	42.79	1.06	17.05	11.27	0.79	75089.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.71	13.69	54.06	1.40	16.78	11.39	0.81	75765.56
最大值	12.78	35.62	65.38	2.06	18.71	12.38	0.97	83114.32
發生時間	15	0	4	0	6	11		17
最小值	6.65	9.82	40.00	0.76	14.87	10.41	0.79	67491.48
發生時間	22	8	21	3	11	6		5
零點偏移(率)	-0.08 %	-0.00 %	-0.04 %	-0.00 %		-0.08	-0.06	0.00 %
全幅偏移(率)	0.02 %	-1.28 %	-0.81 %	-0.05 %		-0.06	0.31	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.22	11.70	42.77	3.17	15.42	10.33	1.33	69597.87
1	9.92	11.30	42.27	3.01	18.29	9.80	1.34	71981.76
2	9.78	11.68	43.77	3.23	16.40	9.58	1.36	72920.62
3	9.06	12.26	49.64	2.66	16.86	9.41	1.36	73673.51
4	9.85	12.42	44.78	3.73	16.45	9.40	1.34	71885.28
5	9.83	12.05	43.14	3.07	17.22	9.30	1.34	72087.86
6	12.12	11.86	44.83	3.78	17.99	9.13	1.34	72867.32
7	5.59	10.75	41.04	2.08	18.01	8.99	1.34	75551.16
8	9.73	11.86	47.48	3.12	15.65	10.80	1.36	76976.81
9	6.11	11.73	48.06	2.47	16.60	10.63	1.36	76012.04
10	11.17	12.69	47.41	2.84	16.41	10.48	1.36	76219.61
11	7.73	17.23	53.34	2.90	15.49	10.79	1.36	74105.11
12	8.62	15.12	58.05	3.28	14.69	11.03	1.36	74752.35
13	6.42	19.13	58.26	3.77	14.17	10.82	1.34	69671.82
14	9.34	10.63	61.08	2.79	16.41	10.56	1.33	71896.19
15	7.17	13.46	62.12	2.71	16.54	10.99	1.34	74936.70
16	10.02	13.19	55.13	2.89	16.82	10.26	1.34	77530.68
17	8.30	12.00	58.09	2.69	17.41	10.13	1.35	78175.54
18	8.68	10.77	55.37	2.84	18.34	9.31	1.36	78321.97
19	9.68	11.95	50.03	5.30	19.16	9.26	1.35	78484.64
20	8.10	11.65	56.93	2.64	16.90	10.31	1.34	73615.89
21	11.77	11.45	60.02	2.86	17.70	10.23	1.34	74638.94
22	9.97	11.15	57.14	3.07	18.63	9.72	1.34	83018.56
23	9.73	11.78	56.82	2.79	16.91	10.58	1.36	77118.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.00	12.49	51.57	3.07	16.85	10.08	1.35	74835.03
最大值	12.12	19.13	62.12	5.30	19.16	11.03	1.37	83018.56
發生時間	6	13	15	19	19	12		22
最小值	5.59	10.63	41.04	2.08	14.17	8.99	1.31	69597.87
發生時間	7	14	7	7	13	7		0
零點偏移(率)	-0.11 %	0.00 %	0.00 %	-0.00 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-0.72 %	0.98 %	1.94 %	0.87 %		-0.08	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								