

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.15	5.35	45.10	3.46	15.32	12.23	1.41	69162.60
1	1.22	4.47	53.76	2.75	17.94	12.19	1.41	67202.16
2	8.66	7.11	47.11	3.12	17.69	11.54	1.41	72753.54
3	10.02	4.26	51.52	3.82	15.92	12.11	1.41	70024.61
4	9.09	3.34	57.31	3.32	17.32	11.75	1.41	71967.61
5	6.38	5.86	59.76	3.32	16.77	12.32	1.45	74063.00
6	5.71	3.60	55.00	3.45	16.53	12.57	1.47	67255.28
7	4.85	3.25	56.86	3.24	16.74	12.11	1.41	70190.70
8	8.67	3.49	58.48	3.25	17.19	11.94	1.41	70885.54
9	6.38	3.15	55.75	2.93	17.95	11.55	1.41	72627.72
10	8.02	6.24	56.54	3.65	17.79	11.72	1.42	71173.41
11	10.25	3.37	55.26	3.65	16.49	11.77	1.46	72503.14
12	7.43	3.20	48.92	3.34	17.28	11.60	1.46	72539.18
13	5.77	3.24	60.71	3.06	17.60	11.90	1.46	70506.52
14	9.76	3.41	53.81	3.94	16.05	12.03	1.46	70369.32
15	10.32	3.33	56.79	3.75	16.51	11.84	1.45	71726.44
16	9.85	3.49	52.67	3.82	15.85	11.92	1.43	71299.79
17	9.28	3.33	59.50	3.41	16.65	11.80	1.44	72415.02
18	5.98	6.01	57.72	4.08	15.04	12.45	1.46	68305.24
19	3.11	3.21	62.70	2.86	17.11	11.82	1.45	72021.63
20	8.20	3.83	50.87	3.55	15.96	12.06	1.43	71032.76
21	10.40	6.92	52.84	4.50	14.39	12.27	1.41	70571.59
22	7.13	3.37	61.49	2.95	16.89	11.84	1.42	72056.33
23	9.13	3.55	53.52	3.22	16.93	12.00	1.41	70200.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.41	4.18	55.17	3.44	16.66	11.97	1.43	70952.21
最大值	10.40	7.11	62.70	4.50	17.95	12.57	1.54	74063.00
發生時間	21	2	19	21	9	6		5
最小值	1.22	3.15	45.10	2.75	14.39	11.54	1.41	67202.16
發生時間	1	9	0	1	21	2		1
零點偏移(率)	0.00 %	-0.03 %	-0.05 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.14 %	0.46 %	-0.92 %	-0.14 %		-0.24	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.69	5.44	42.37	2.31	18.99	9.63	1.39	83664.70
1	10.66	8.98	45.79	2.31	19.73	10.02	1.39	81270.04
2	9.24	4.80	46.90	3.41	16.27	10.22	1.40	77774.18
3	9.71	6.28	47.04	3.31	17.95	9.84	1.42	79610.01
4	9.74	7.25	46.55	4.08	18.37	9.74	1.43	81049.93
5	8.96	4.37	42.62	2.93	19.21	9.80	1.43	81409.33
6	8.31	7.11	45.76	2.75	19.09	9.91	1.47	74863.92
7	9.66	6.67	43.34	3.20	18.14	9.86	1.46	82070.05
8	9.88	4.49	52.49	3.05	18.40	10.02	1.44	81630.13
9	9.66	4.00	45.42	2.75	18.49	10.16	1.45	84162.22
10	5.95	4.93	50.33	2.52	17.46	10.30	1.44	82917.59
11	9.80	4.79	55.69	2.32	20.31	9.92	1.42	84934.44
12	10.71	3.84	50.06	2.96	19.90	9.90	1.43	85384.60
13	9.45	4.52	51.26	2.48	19.03	10.20	1.43	85910.02
14	9.88	5.01	55.06	3.39	16.96	10.56	1.43	83182.21
15	11.46	5.29	56.81	4.72	16.32	10.75	1.43	82810.71
16	10.76	8.24	53.83	3.97	15.40	10.96	1.43	81848.38
17	8.20	3.74	53.43	2.69	16.22	10.90	1.43	80205.67
18	6.35	3.73	58.68	2.24	17.06	10.79	1.43	80855.84
19	5.86	5.09	47.84	2.68	15.61	10.88	1.46	79770.24
20	4.84	5.21	50.52	2.52	15.60	10.59	1.46	78104.54
21	8.42	3.78	50.62	2.49	17.37	10.21	1.45	81647.42
22	9.26	3.61	54.75	2.66	18.26	10.19	1.44	82458.08
23	9.54	3.95	56.12	2.07	19.52	10.09	1.45	84125.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.00	5.21	50.14	2.91	17.90	10.23	1.43	81735.84
最大值	11.46	8.98	58.68	4.72	20.31	10.96	1.49	85910.02
發生時間	15	1	18	15	11	16		13
最小值	4.84	3.61	42.37	2.07	15.40	9.63	1.38	74863.92
發生時間	20	22	0	23	16	0		6
零點偏移(率)	-0.03 %	-0.05 %	-0.01 %	-0.02 %		-0.06	0.00	0.00 %
全幅偏移(率)	1.78 %	1.01 %	-0.81 %	0.20 %		-0.16	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.35	4.88	59.14	2.80	16.15	10.80	1.49	80399.46
1	6.99	4.57	59.53	2.59	16.60	10.76	1.49	79206.73
2	13.00	9.32	56.99	4.89	13.75	10.83	1.47	75839.69
3	5.48	1.47	55.83	2.91	15.93	10.64	1.46	79202.02
4	5.85	6.60	56.96	2.87	17.33	10.18	1.46	81546.09
5	8.33	3.00	50.30	3.13	16.93	10.27	1.46	80174.48
6	8.23	4.02	57.46	3.03	16.46	10.46	1.48	80232.39
7	3.34	7.66	48.35	2.87	14.68	11.04	1.56	84285.02
8	5.94	2.85	65.68	2.75	17.83	10.50	1.51	83465.84
9	9.53	2.52	51.87	2.68	16.81	10.57	1.47	82720.93
10	7.72	3.92	60.44	2.84	15.57	10.95	1.46	79562.94
11	5.82	3.90	58.70	2.53	17.49	10.43	1.48	84520.21
12	9.48	2.87	52.59	2.89	18.03	10.12	1.46	86091.45
13	9.73	2.19	60.50	3.31	17.14	10.50	1.47	85271.44
14	9.87	2.16	59.85	3.31	16.41	10.77	1.47	83032.91
15	8.59	9.76	58.05	3.39	15.04	10.90	1.48	82729.02
16	8.31	4.27	60.17	3.39	14.80	10.93	1.46	79118.62
17	8.96	2.40	58.38	3.12	16.05	10.69	1.47	80976.45
18	4.82	3.37	57.64	2.98	15.05	11.08	1.47	77655.55
19	3.64	3.23	62.62	2.93	14.93	11.04	1.47	77949.89
20	9.02	2.75	63.13	3.29	15.18	10.98	1.49	79669.71
21	8.49	2.57	58.28	2.68	16.42	10.65	1.49	81807.99
22	8.23	3.09	65.22	2.58	17.59	10.55	1.49	82625.23
23	4.39	4.54	56.80	2.31	18.61	10.46	1.49	84232.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.63	4.08	58.10	3.00	16.28	10.67	1.48	81346.53
最大值	13.00	9.76	65.68	4.89	18.61	11.08	1.68	86091.45
發生時間	2	15	8	2	23	18		12
最小值	3.34	1.47	48.35	2.31	13.75	10.12	1.45	75839.69
發生時間	7	3	7	23	2	12		2
零點偏移(率)	-0.01 %	-0.04 %	-0.05 %	-0.04 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.65 %	0.97 %	-0.45 %	0.37 %		-0.04	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								