

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.13	5.38	54.11	0.79	17.77	11.93	0.99	68818.94
1	0.12	7.84	51.97	1.08	17.88	12.59	1.00	64592.84
2	0.12	6.90	49.27	0.96	19.31	11.82	0.99	69314.75
3	1.18	5.41	43.53	1.27	18.34	11.12	0.99	76085.93
4	3.20	6.02	47.76	1.78	17.80	11.13	0.99	76218.65
5	2.81	8.93	56.87	1.85	17.64	12.01	0.99	71002.69
6	4.17	5.71	51.25	1.09	19.34	10.88	0.99	76459.58
7	3.32	2.73	47.71	2.51	15.94	11.86	0.99	71631.13
8	4.06	2.18	47.46	2.18	16.86	11.65	0.98	72484.69
9	2.57	3.40	49.33	1.78	16.58	11.85	0.99	70828.52
10	3.11	5.06	54.73	1.32	17.29	11.87	0.99	70486.27
11	5.27	5.38	48.81	1.32	17.76	11.50	0.99	72499.90
12	4.70	7.26	43.95	2.10	15.62	12.11	0.99	69007.06
13	6.49	10.25	38.60	1.63	16.57	11.85	0.99	70480.27
14	3.30	11.82	43.70	1.31	17.85	11.70	0.99	69989.12
15	4.79	9.78	48.31	1.77	16.51	12.10	0.99	68407.61
16	2.61	7.73	54.59	0.87	19.04	11.47	0.99	71410.97
17	2.72	7.11	50.91	0.75	20.15	10.73	1.00	76089.45
18	5.07	11.08	40.63	1.55	17.21	11.15	1.00	74902.74
19	8.07	7.30	43.80	2.21	17.44	11.36	0.99	73352.75
20	4.61	7.40	50.33	1.32	17.84	11.56	1.00	71937.89
21	3.93	6.71	51.21	1.29	18.20	11.57	1.00	71687.53
22	5.14	7.54	51.65	1.32	17.51	11.63	1.00	72246.43
23	10.21	8.24	43.35	2.36	16.75	11.46	0.99	73887.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.82	6.97	48.49	1.52	17.63	11.62	0.99	71825.98
最大值	10.21	11.82	56.87	2.51	20.15	12.59	1.04	76459.58
發生時間	23	14	5	7	17	1		6
最小值	0.12	2.18	38.60	0.75	15.62	10.73	0.97	64592.84
發生時間	1	8	13	17	12	17		1
零點偏移(率)	-0.05 %	0.00 %	-0.05 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	0.02 %	-2.10 %	-0.95 %	-0.61 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.08	5.27	51.41	1.54	17.79	11.29	1.01	77247.48
1	0.01	6.35	26.05	1.11	20.41	10.34	1.01	82458.12
2	0.12	2.06	51.59	1.13	19.21	10.12	0.99	85476.86
3	0.09	5.61	38.87	1.36	19.04	9.64	0.99	89108.03
4	0.01	2.47	51.22	1.19	18.86	10.50	0.99	82188.54
5	0.04	11.03	47.47	1.99	17.71	10.46	0.99	83952.72
6	0.10	6.08	42.92	2.32	17.61	10.47	1.00	81560.68
7	0.38	2.90	48.36	2.54	17.53	10.23	1.02	85873.35
8	2.14	4.12	51.96	2.13	16.82	10.39	1.02	85289.94
9	3.90	2.56	55.43	1.68	17.19	10.46	1.06	84829.41
10	3.36	10.71	51.85	1.66	17.75	10.06	1.06	86588.64
11	2.68	7.26	50.87	1.29	17.83	10.18	1.02	86081.39
12	2.35	10.27	52.33	1.78	17.17	10.34	1.02	84849.85
13	0.47	9.05	51.18	2.47	15.81	11.03	1.02	80895.73
14	0.15	2.57	51.95	1.85	16.13	10.61	1.02	84274.25
15	0.20	6.54	48.48	1.43	17.45	10.11	1.02	86296.84
16	0.72	4.36	56.68	1.22	17.68	10.16	1.03	85674.21
17	2.63	10.15	52.47	1.98	16.68	10.10	1.02	86824.66
18	2.25	4.49	54.88	1.51	16.85	10.63	1.02	82188.57
19	1.89	8.38	57.40	2.09	16.07	10.42	1.02	84991.29
20	6.79	7.47	46.47	1.83	16.18	10.33	1.02	85273.21
21	10.24	7.92	47.80	2.05	16.03	10.43	1.04	84371.97
22	8.66	5.28	57.56	1.63	16.58	10.38	1.02	84326.92
23	9.08	6.95	53.78	1.38	16.89	10.42	1.02	83865.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.43	6.24	49.96	1.71	17.39	10.38	1.02	84353.68
最大值	10.24	11.03	57.56	2.54	20.41	11.29	1.13	89108.03
發生時間	21	5	22	7	1	0		3
最小值	0.01	2.06	26.05	1.11	15.81	9.64	0.99	77247.48
發生時間	1	2	1	1	13	3		0
零點偏移(率)	-0.07 %	-0.01 %	-0.25 %	-0.05 %		0.02		-0.20 %
全幅偏移(率)	0.04 %	-1.47 %	0.04 %	-8.17 %		-0.05		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.67	4.58	42.84	0.88	15.94	10.72	0.96	80660.47
1	0.24	4.38	46.23	0.99	17.01	11.36	0.97	76706.56
2	1.31	7.14	40.71	1.29	16.30	11.03	0.97	81652.78
3	2.38	3.56	47.99	1.21	16.02	10.91	0.97	82305.65
4	4.21	3.94	50.41	1.78	14.98	10.91	0.98	81610.64
5	2.75	4.07	59.50	1.64	14.98	11.37	0.97	76167.54
6	3.72	4.04	48.55	1.86	14.74	11.00	0.97	78307.18
7	6.61	11.68	49.99	1.75	17.03	10.23	0.99	79572.48
8	5.61	2.99	54.07	2.40	14.30	11.23	0.99	77000.87
9	3.46	2.50	47.87	1.60	15.99	10.68	0.99	78035.33
10	2.24	11.63	49.57	1.21	16.95	10.14	0.97	79937.71
11	1.46	9.74	53.20	2.30	13.49	11.23	0.97	72505.73
12	0.64	4.29	55.43	1.46	15.31	11.06	0.98	76364.21
13	0.74	3.82	53.54	1.59	15.08	11.02	0.99	77062.66
14	4.10	4.55	52.54	1.87	15.26	11.02	1.00	78718.66
15	4.26	5.02	55.20	1.82	14.98	11.33	0.99	76744.25
16	3.86	4.44	52.81	1.23	16.46	10.69	0.99	78001.61
17	4.12	6.93	48.01	1.38	16.17	10.59	1.01	77875.61
18	2.91	5.96	46.19	1.60	14.94	10.93	1.00	75832.90
19	2.59	5.40	54.00	1.91	14.48	11.00	0.99	74861.23
20	4.04	6.64	46.70	1.67	15.26	10.64	0.99	73537.36
21	2.49	4.75	48.04	1.29	16.08	10.57	0.99	75163.91
22	3.65	7.24	44.50	1.50	15.73	10.54	0.99	75061.87
23	6.09	6.01	49.61	1.84	15.43	10.64	0.99	73339.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.09	5.64	49.90	1.59	15.54	10.87	0.98	77376.13
最大值	6.61	11.68	59.50	2.40	17.03	11.37	1.04	82305.65
發生時間	7	7	5	8	7	5		3
最小值	0.24	2.50	40.71	0.88	13.49	10.14	0.95	72505.73
發生時間	1	9	2	0	11	10		11
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-2.76 %	-0.22 %	-1.22 %		0.32		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								