

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.36	5.39	57.84	1.82	16.80	12.04	1.01	78159.86
1	1.69	7.57	62.73	1.83	17.33	12.66	1.01	72852.01
2	3.46	7.86	52.06	1.57	17.10	12.57	1.01	73874.37
3	6.95	5.30	47.89	1.81	17.27	11.30	0.98	84511.27
4	5.75	5.78	48.83	2.66	16.04	11.66	0.98	82595.56
5	7.73	5.32	58.76	1.07	17.45	11.73	1.02	81574.01
6	6.15	5.20	57.55	1.03	17.67	11.74	1.02	80389.95
7	7.53	4.70	54.01	1.34	17.35	11.46	1.02	83113.27
8	7.55	5.34	53.24	1.37	16.93	11.69	1.02	81427.72
9	6.06	5.31	63.73	0.72	17.97	11.61	1.02	81196.44
10	9.85	5.29	52.68	1.50	17.76	11.12	1.02	85593.33
11	8.59	5.67	45.52	2.35	16.43	11.47	1.02	83497.20
12	6.25	3.93	50.70	1.77	15.98	11.93	1.02	80076.56
13	5.15	8.36	53.09	1.80	15.51	12.04	1.01	79876.79
14	3.56	8.87	60.03	1.01	16.74	11.87	0.99	79798.17
15	5.85	8.98	59.03	1.14	16.88	11.71	1.01	81098.05
16	8.31	8.00	60.14	1.01	17.41	11.22	0.99	84107.37
17	8.23	9.62	44.90	2.78	14.67	11.76	1.00	82410.04
18	4.08	9.33	58.44	0.83	17.84	11.41	1.02	82369.19
19	2.39	9.38	40.08	1.23	18.02	10.74	1.02	88072.00
20	6.93	3.16	42.72	2.68	16.18	11.26	1.00	84643.37
21	8.96	3.86	40.55	1.69	16.18	11.54	1.00	83377.41
22	6.82	7.80	44.25	1.40	16.85	11.78	1.02	80571.07
23	4.95	7.48	51.14	1.47	16.61	11.96	1.02	79179.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.21	6.56	52.50	1.58	16.87	11.68	1.01	81431.86
最大值	9.85	9.62	63.73	2.78	18.02	12.66	1.05	88072.00
發生時間	10	17	9	17	19	1		19
最小值	1.69	3.16	40.08	0.72	14.67	10.74	0.97	72852.01
發生時間	1	20	19	9	17	19		1
零點偏移(率)	-0.10 %	-0.00 %	-0.09 %	-0.07 %		-0.05		0.00 %
全幅偏移(率)	4.87 %	1.09 %	0.11 %	0.53 %		-0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.72	4.56	60.02	1.83	16.79	11.67	1.02	76123.01
1	1.42	5.24	59.18	2.34	17.94	11.53	1.02	76036.48
2	2.15	4.80	60.18	1.55	18.41	11.26	1.02	78151.48
3	3.01	4.96	48.02	2.50	17.47	11.13	1.01	79440.40
4	3.46	4.66	63.87	1.55	17.64	11.66	1.02	75369.73
5	2.76	4.66	52.59	1.30	18.14	10.99	0.99	80589.61
6	0.61	5.25	55.70	1.82	16.62	11.85	0.99	74113.97
7	0.57	4.94	57.16	1.20	18.29	11.40	1.00	76989.98
8	0.83	5.24	49.62	1.08	18.24	11.15	1.02	78563.99
9	6.44	5.32	44.05	2.85	17.56	11.09	1.02	79847.49
10	8.40	8.35	45.08	1.69	18.91	10.79	1.02	80673.19
11	9.13	4.33	42.66	2.19	17.89	10.80	1.02	81700.31
12	10.93	4.28	45.33	3.22	16.06	11.29	1.03	79578.64
13	5.15	3.71	57.90	1.86	17.02	11.30	1.03	78848.74
14	8.11	5.22	49.60	2.06	18.07	11.11	1.03	79225.32
15	9.52	2.69	51.76	2.61	17.22	11.14	1.02	80313.84
16	8.35	4.23	44.73	1.61	19.16	10.57	1.02	82551.65
17	8.02	4.46	49.66	1.35	19.24	10.42	1.02	84125.82
18	6.58	8.32	48.17	1.69	19.20	10.08	1.02	86728.41
19	7.45	2.69	45.35	1.34	19.88	9.93	1.02	86813.89
20	5.14	4.29	39.15	1.59	17.78	10.84	1.03	81842.02
21	7.99	5.63	42.41	2.57	16.03	11.32	1.02	79760.76
22	2.38	6.46	55.76	3.15	14.61	12.18	1.02	74148.33
23	1.92	7.92	54.52	3.32	14.81	12.20	1.02	73764.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.17	5.09	50.94	2.01	17.62	11.15	1.02	79387.56
最大值	10.93	8.35	63.87	3.32	19.88	12.20	1.04	86813.89
發生時間	12	10	4	23	19	23		19
最小值	0.57	2.69	39.15	1.08	14.61	9.93	0.98	73764.34
發生時間	7	15	20	8	22	19		23
零點偏移(率)	-0.09 %	-0.01 %	-0.02 %	-0.00 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	0.47 %	-0.64 %	-0.20 %		-0.26		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.41	4.61	52.29	0.25	17.17	10.94	0.99	81302.46
1	2.62	6.92	51.35	0.39	18.82	10.49	0.98	86335.05
2	2.75	7.39	46.88	0.33	17.91	10.37	0.98	86936.36
3	2.44	9.42	47.37	0.29	17.11	10.96	0.98	82713.66
4	2.48	8.77	56.86	0.21	18.35	10.90	0.99	82988.18
5	2.59	7.41	46.45	0.23	18.47	10.32	0.98	87709.15
6	2.80	7.26	53.04	0.34	17.86	10.49	0.99	86674.82
7	0.61	4.87	50.36	0.19	17.74	11.04	0.99	無效
8	0.66	6.01	62.25	0.21	18.19	10.71	0.99	78343.69
9	0.01	6.53	60.61	0.20	18.33	10.31	0.99	81650.61
10	4.10	6.71	54.35	0.56	17.34	10.25	1.01	82916.71
11	2.31	6.34	66.62	0.32	18.01	10.34	1.02	82229.71
12	2.19	6.41	60.84	0.42	17.67	10.31	1.00	82512.83
13	2.24	5.71	63.85	0.28	18.21	10.23	1.01	82409.88
14	1.18	6.34	53.63	0.48	16.65	10.41	1.04	79610.99
15	1.17	7.17	62.02	0.24	18.29	10.18	1.04	82089.39
16	5.46	2.14	57.28	0.44	18.27	9.96	1.04	84749.41
17	1.41	2.93	60.62	0.28	19.31	11.17	1.05	74818.48
18	3.16	5.76	31.42	0.32	20.15	8.97	1.00	88697.06
19	3.41	6.09	38.40	0.57	16.43	9.77	0.99	79423.25
20	1.39	4.15	45.77	0.32	17.16	9.76	0.97	80901.13
21	3.78	2.50	48.71	0.65	16.57	10.28	0.99	77576.10
22	1.53	3.52	44.00	0.72	16.06	10.76	0.99	74569.76
23	5.21	1.27	39.64	0.84	15.69	10.73	0.99	74706.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	23
平均值	2.41	5.68	52.28	0.38	17.74	10.40	1.00	81820.22
最大值	5.46	9.42	66.62	0.84	20.15	11.17	1.08	88697.06
發生時間	16	3	11	23	18	17		18
最小值	0.01	1.27	31.42	0.19	15.69	8.97	0.96	74569.76
發生時間	9	23	18	7	23	18		22
零點偏移(率)	-0.05 %	-0.08 %	-0.01 %	-0.01 %		-0.12		0.00 %
全幅偏移(率)	0.02 %	0.28 %	-1.36 %	0.13 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	95.83 %
備註								