

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.57	無效	44.07	3.03	16.52	11.45	1.05	67840.68
1	8.84	無效	51.53	2.55	18.14	11.59	1.05	67651.05
2	9.97	17.02	49.91	2.81	17.89	10.96	1.05	71475.48
3	3.27	18.07	62.06	2.13	18.28	11.85	1.05	64905.68
4	7.08	17.69	53.16	1.70	20.46	10.73	1.05	73028.22
5	12.90	19.31	54.15	2.30	19.37	11.00	1.05	68653.38
6	5.78	19.37	43.16	2.01	20.15	10.52	1.05	74808.94
7	4.12	無效	48.80	2.39	18.43	11.45	1.05	68991.12
8	7.50	無效	47.32	2.50	18.59	11.23	1.03	71094.25
9	9.73	無效	55.61	2.66	18.52	11.35	1.03	70431.03
10	9.31	無效	48.91	2.24	20.26	10.21	1.05	75838.78
11	6.67	無效	40.10	2.76	17.42	11.34	1.02	68437.08
12	9.18	19.15	40.00	2.79	19.12	10.22	1.02	71562.73
13	8.54	8.54	49.70	2.70	19.46	10.07	1.01	70934.15
14	9.65	14.59	25.42	3.26	17.65	10.49	0.99	68079.25
15	10.09	16.41	31.00	3.05	18.08	10.97	1.01	66488.99
16	9.84	9.84	37.98	2.83	19.26	10.17	1.03	70208.17
17	10.05	18.08	40.33	2.80	19.85	10.25	1.03	69096.08
18	9.66	17.34	55.06	2.45	19.51	10.01	1.03	71864.96
19	10.19	12.79	33.61	2.61	18.38	10.11	1.00	70736.95
20	10.18	11.32	52.89	2.36	19.92	10.27	0.99	71375.25
21	9.76	16.32	27.23	2.33	19.55	9.71	0.99	72700.58
22	10.23	12.09	37.52	2.35	19.57	10.16	0.99	69916.08
23	9.66	13.46	34.60	2.48	19.10	10.18	0.99	69354.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	17	24	24	24	24	24	24
平均值	8.82	15.38	44.34	2.55	18.90	10.68	1.03	70228.04
最大值	12.90	19.37	62.06	3.26	20.46	11.85	1.05	75838.78
發生時間	5	6	3	14	4	3		10
最小值	3.27	8.54	25.42	1.70	16.52	9.71	0.99	64905.68
發生時間	3	13	14	4	0	21		3
零點偏移(率)	-0.01 %	-0.02 %	-0.03 %	-0.01 %		0.04		0.00 %
全幅偏移(率)	0.00 %	0.56 %	0.53 %	-0.04 %		-0.04		0.20 %
有效比率	100.00 %	70.83 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.66	無效	52.44	1.57	16.83	10.69	1.10	69255.46
1	8.14	19.71	70.44	1.14	18.81	10.82	1.10	71339.93
2	7.71	19.59	45.15	1.02	19.15	9.98	1.10	75549.16
3	10.21	16.67	55.61	1.45	18.50	9.72	1.10	83145.29
4	8.76	15.77	61.89	1.02	19.11	9.65	1.10	81996.58
5	8.46	16.99	68.68	1.06	18.45	10.52	1.10	76068.68
6	無效	16.78	60.28	2.63	18.22	10.18	1.10	81798.81
7	3.26	15.21	66.17	1.40	18.47	10.31	1.10	79844.24
8	9.98	17.44	55.86	1.48	19.81	9.74	1.11	84953.32
9	9.08	無效	52.35	1.41	19.88	9.45	1.10	84802.31
10	7.78	無效	61.05	1.47	19.77	9.66	1.11	81607.60
11	8.59	19.26	66.99	2.19	16.57	10.08	1.11	80340.92
12	5.65	17.80	62.93	2.08	16.32	9.92	1.11	74147.37
13	9.86	7.73	59.73	2.90	17.07	8.98	1.10	78861.23
14	10.21	10.13	61.17	2.98	17.32	9.04	1.10	78001.41
15	9.97	14.34	69.69	3.31	14.90	10.09	1.10	74728.10
16	8.44	7.16	57.33	2.41	17.52	9.31	1.10	77493.76
17	10.40	15.35	65.76	1.71	18.03	9.02	1.10	83819.68
18	9.10	17.58	65.05	1.51	18.75	9.22	1.10	79838.05
19	9.55	16.10	57.40	1.70	18.36	9.03	1.10	80973.00
20	7.00	15.78	50.05	1.66	18.10	9.61	1.10	76924.65
21	8.27	10.11	61.61	1.77	17.85	9.35	1.10	79766.39
22	7.72	12.90	63.59	1.91	17.34	10.34	1.10	75001.34
23	1.88	8.67	55.16	1.34	18.51	10.19	1.10	70998.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	21	24	24	24	24	24	24
平均值	8.16	14.81	60.27	1.80	18.07	9.79	1.10	78385.65
最大值	10.40	19.71	70.44	3.31	19.88	10.82	1.11	84953.32
發生時間	17	1	1	15	9	1		8
最小值	1.88	7.16	45.15	1.02	14.90	8.98	1.10	69255.46
發生時間	23	16	2	2	15	13		0
零點偏移(率)	-0.02 %	-0.17 %	-0.02 %	-0.02 %		0.01		0.00 %
全幅偏移(率)	0.04 %	-0.55 %	0.13 %	-0.61 %		-0.18		0.00 %
有效比率	95.83 %	87.50 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.97	無效	71.57	4.73	17.41	9.63	1.05	78919.75
1	6.80	無效	65.11	4.90	15.78	10.83	1.05	77025.43
2	10.88	無效	72.02	5.43	17.66	10.24	1.04	80817.91
3	8.20	16.90	無效	5.07	18.11	10.09	1.04	81328.03
4	7.00	17.47	無效	4.83	17.69	10.47	1.05	79892.48
5	1.81	16.23	無效	4.82	17.99	10.57	1.06	79515.22
6	4.60	無效	73.62	4.76	18.34	10.29	1.07	87539.87
7	10.81	無效	68.99	3.12	16.02	11.25	1.05	86715.03
8	9.96	無效	65.36	3.13	16.56	11.03	1.04	86165.37
9	8.88	18.34	69.16	3.00	18.43	10.61	1.06	86686.25
10	8.89	無效	63.76	2.88	18.81	10.53	1.03	85813.93
11	9.49	無效	59.43	3.02	16.52	11.00	1.05	80546.38
12	9.21	無效	53.78	3.36	15.62	10.27	1.05	74451.33
13	9.90	8.09	49.17	3.64	15.93	9.90	1.02	75442.00
14	7.89	11.83	53.01	3.38	14.76	10.75	1.01	76138.98
15	7.26	18.76	47.65	3.73	14.04	11.02	0.99	70130.26
16	8.11	12.72	49.28	3.10	16.30	10.24	1.01	73880.87
17	7.40	12.92	61.83	2.95	17.31	9.83	1.03	77695.98
18	8.62	15.51	52.83	2.94	16.92	9.94	1.04	76162.87
19	2.65	12.08	70.92	2.69	18.49	9.61	1.00	77046.92
20	7.86	17.14	68.01	3.16	16.16	10.15	1.00	80643.17
21	7.25	7.66	49.70	2.68	17.61	10.20	0.99	79687.96
22	8.90	11.96	53.91	3.09	16.55	10.25	0.99	80348.13
23	6.09	4.83	61.14	2.74	16.87	10.60	0.99	75376.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	15	21	24	24	24	24	24
平均值	7.73	13.50	60.96	3.63	16.91	10.39	1.03	79498.77
最大值	10.88	18.76	73.62	5.43	18.81	11.25	1.07	87539.87
發生時間	2	15	6	2	10	7		6
最小值	1.81	4.83	47.65	2.68	14.04	9.61	0.99	70130.26
發生時間	5	23	15	21	15	19		15
零點偏移(率)	-0.05 %	-0.00 %	-0.48 %	-0.05 %		0.01		0.00 %
全幅偏移(率)	0.04 %	1.28 %	0.02 %	0.17 %		0.31		0.00 %
有效比率	100.00 %	62.50 %	87.50 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								