

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.38	13.40	61.45	2.27	17.96	11.65	1.23	78732.17
1	10.22	13.08	57.03	3.51	18.68	11.31	1.23	80676.74
2	10.15	12.42	50.42	3.40	18.66	10.68	1.23	85843.73
3	7.19	13.49	59.69	3.25	17.48	11.78	1.23	78349.64
4	5.39	12.87	51.25	3.68	17.24	11.35	1.23	81383.13
5	3.39	13.25	60.53	3.63	18.19	11.41	1.25	83897.57
6	8.84	12.40	53.16	3.00	18.98	10.79	1.24	84128.14
7	10.01	12.12	50.89	3.14	19.78	10.32	1.23	87227.72
8	9.95	12.22	48.93	1.88	19.65	10.49	1.21	86035.66
9	7.69	12.16	49.22	1.10	18.94	10.54	1.21	85935.81
10	9.73	12.35	53.93	1.04	18.94	10.76	1.23	84153.62
11	8.79	12.32	53.44	0.96	18.24	10.79	1.25	84672.25
12	10.71	12.89	56.48	1.59	18.54	11.05	1.24	81865.07
13	9.49	12.55	55.68	1.51	18.22	10.79	1.22	84369.85
14	7.37	12.48	45.39	1.36	18.03	10.93	1.21	83938.86
15	10.47	12.97	53.40	1.50	17.79	11.38	1.23	80296.38
16	9.06	12.73	54.53	0.98	19.09	10.93	1.24	82903.54
17	5.91	12.20	53.18	0.94	19.06	10.62	1.22	85478.07
18	9.57	12.21	58.61	1.18	19.50	10.55	1.20	85368.49
19	10.66	13.21	58.18	1.11	19.23	11.37	1.21	79234.13
20	9.36	12.52	44.79	1.23	20.64	10.08	1.22	87859.39
21	11.68	12.01	50.82	1.39	19.62	10.33	1.23	86797.31
22	5.46	12.43	48.97	0.96	19.42	10.55	1.24	85218.93
23	7.29	13.47	55.93	1.28	18.06	11.53	1.24	78666.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.53	12.66	53.58	1.91	18.75	10.92	1.23	83459.68
最大值	11.68	13.49	61.45	3.68	20.64	11.78	1.28	87859.39
發生時間	21	3	0	4	20	3		20
最小值	3.39	12.01	44.79	0.94	17.24	10.08	1.20	78349.64
發生時間	5	21	20	17	4	20		3
零點偏移(率)	-0.05 %	-0.11 %	-0.04 %	-0.00 %		0.01	-0.01	0.10 %
全幅偏移(率)	1.31 %	-1.01 %	0.14 %	-0.71 %		-0.05	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.24	13.62	53.03	1.73	17.65	11.80	0.99	76557.11
1	9.15	12.91	46.72	2.90	18.73	10.94	0.99	82464.81
2	16.16	11.87	48.51	1.44	19.18	10.37	0.99	87250.28
3	10.71	12.15	51.27	0.99	19.19	10.63	0.99	85148.55
4	5.09	12.30	47.70	0.73	18.92	10.80	0.98	84167.23
5	12.63	12.24	47.91	0.85	19.05	10.73	0.99	84077.58
6	7.85	13.14	59.07	0.30	19.52	11.21	1.01	82014.28
7	12.02	13.59	58.05	1.36	19.53	10.43	1.02	85531.33
8	11.02	12.16	51.59	0.84	19.11	10.54	1.02	84963.52
9	11.78	12.66	46.16	1.88	18.28	10.82	1.01	83110.59
10	6.31	13.22	56.34	2.16	16.37	11.42	1.00	80613.63
11	14.93	12.76	51.87	1.94	16.69	11.29	0.99	80905.45
12	10.18	12.96	60.07	0.93	18.06	11.09	0.98	82035.18
13	14.15	12.72	52.17	2.13	16.66	11.25	0.98	81418.19
14	10.40	13.07	61.77	1.53	17.93	11.49	1.01	78698.83
15	8.76	13.01	50.37	1.34	17.05	11.46	1.02	79928.60
16	14.61	14.65	61.86	3.33	15.79	11.61	1.02	79494.21
17	2.81	14.33	50.84	0.79	18.91	11.95	1.03	74080.96
18	3.26	12.52	48.39	0.27	18.57	10.95	1.02	83129.44
19	6.81	11.79	37.00	0.73	20.31	9.98	1.01	88518.85
20	11.06	11.60	52.78	1.06	19.93	9.97	1.01	88307.56
21	12.31	11.58	57.20	0.74	20.29	9.98	0.99	88149.06
22	2.90	12.00	37.53	0.35	20.53	10.14	0.98	85556.38
23	12.05	12.13	37.24	1.02	19.67	10.22	0.97	86096.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.80	12.71	51.06	1.31	18.58	10.88	1.00	83009.08
最大值	16.16	14.65	61.86	3.33	20.53	11.95	1.24	88518.85
發生時間	2	16	16	16	22	17		19
最小值	2.81	11.58	37.00	0.27	15.79	9.97	0.97	74080.96
發生時間	17	21	19	18	16	20		17
零點偏移(率)	-0.13 %	0.00 %	-0.06 %	-0.01 %		-0.02	-0.01	-0.20 %
全幅偏移(率)	2.96 %	0.07 %	0.92 %	-0.06 %		0.06	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.96	11.20	42.08	2.68	19.93	8.68	1.34	71672.13
1	4.62	12.06	37.97	2.45	22.50	8.45	1.35	70898.85
2	7.09	10.12	35.46	3.92	20.81	7.74	1.36	76751.63
3	8.70	10.31	54.41	3.00	20.67	8.26	1.36	75165.51
4	9.52	10.68	56.55	2.83	19.12	8.53	1.36	73265.66
5	6.42	10.65	58.85	2.64	19.94	8.40	1.35	74397.62
6	9.99	10.91	52.95	2.97	20.01	8.44	1.35	73324.11
7	4.98	10.65	51.61	2.71	19.39	8.10	1.31	78888.86
8	2.69	10.83	63.25	2.50	18.66	9.49	1.31	78316.84
9	2.61	10.92	48.53	2.22	19.83	9.08	1.33	76409.91
10	4.12	10.75	52.35	2.43	18.19	9.33	1.36	75154.74
11	8.09	10.62	60.72	2.79	18.66	9.19	1.35	75482.29
12	5.63	11.84	59.42	2.50	18.60	9.45	1.32	73209.43
13	3.28	12.05	55.67	2.46	20.31	8.98	1.34	74784.62
14	4.86	11.96	51.21	2.27	17.57	9.54	1.35	75024.27
15	3.16	12.15	61.73	2.43	19.57	9.45	1.36	71724.86
16	5.92	11.85	62.99	2.49	19.94	9.03	1.36	80332.01
17	7.55	12.10	56.76	2.59	19.19	9.59	1.34	79238.58
18	4.49	12.36	51.63	2.39	20.73	9.21	1.36	77505.95
19	5.70	12.41	62.65	2.64	20.33	9.63	1.36	77085.22
20	3.39	12.30	56.42	2.18	21.32	9.38	1.35	75101.27
21	4.72	11.68	49.13	2.12	20.86	8.79	1.32	79790.61
22	4.20	12.09	54.69	2.64	20.00	9.37	1.31	77390.75
23	6.49	12.46	67.84	2.96	19.28	9.93	1.31	75257.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.63	11.46	54.37	2.62	19.81	9.00	1.34	75673.89
最大值	9.99	12.46	67.84	3.92	22.50	9.93	1.37	80332.01
發生時間	6	23	23	2	1	23		16
最小值	2.61	10.12	35.46	2.12	17.57	7.74	1.31	70898.85
發生時間	9	2	2	21	14	2		1
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	0.00 %		-0.05	-0.01	0.10 %
全幅偏移(率)	1.42 %	0.60 %	1.29 %	-0.18 %		0.33	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								