

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月11日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.01	13.18	61.25	1.32	16.65	12.37	1.35	74560.37
1	10.69	12.19	45.02	2.33	16.32	11.69	1.34	81000.25
2	13.59	12.16	55.95	2.45	16.16	11.77	1.34	80476.98
3	13.06	12.36	53.89	3.62	14.65	11.91	1.35	80657.89
4	9.87	12.12	50.55	1.68	15.92	11.78	1.39	80508.52
5	5.13	11.84	46.74	3.03	15.30	11.75	1.38	82256.54
6	5.08	12.10	52.08	3.58	14.80	11.92	1.37	79749.36
7	8.02	12.26	57.65	3.07	14.87	12.06	1.37	79141.58
8	5.04	12.18	59.39	3.62	15.10	11.94	1.38	79455.84
9	3.78	12.14	61.71	2.78	15.39	11.94	1.36	79377.84
10	4.23	12.44	36.64	4.27	13.36	12.23	1.33	78371.92
11	15.61	12.08	41.04	4.59	14.65	11.95	1.33	80354.82
12	6.60	12.39	40.98	4.51	13.81	12.27	1.32	77876.00
13	3.99	12.24	38.96	3.60	14.31	12.08	1.33	79003.87
14	2.40	13.40	54.63	2.60	14.50	12.86	1.36	71858.58
15	2.63	12.51	42.29	2.94	14.52	12.17	1.37	78005.30
16	2.95	12.15	40.33	2.27	15.27	11.92	1.37	79569.39
17	5.64	12.02	44.72	2.73	14.58	11.92	1.34	80110.21
18	6.61	12.55	59.24	2.21	14.51	12.31	1.35	76775.55
19	6.06	12.04	50.30	1.99	15.31	11.81	1.34	80418.78
20	6.51	11.92	49.43	2.72	14.71	11.81	1.31	80994.32
21	8.09	11.95	52.31	3.23	14.57	11.85	1.31	80308.72
22	10.09	11.90	57.00	2.91	14.74	11.83	1.31	80700.85
23	14.73	12.15	53.76	2.98	14.55	11.78	1.31	81089.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.48	12.26	50.24	2.96	14.94	12.00	1.34	79275.95
最 大 值	15.61	13.40	61.71	4.59	16.65	12.86	1.39	82256.54
發生時間	11	14	9	11	0	14		5
最 小 值	2.40	11.84	36.64	1.32	13.36	11.69	1.30	71858.58
發生時間	14	5	10	0	10	1		14
零點偏移(率)	-0.10 %	-0.01 %	-0.02 %	-0.01 %		-0.06	-0.01	0.40 %
全幅偏移(率)	0.44 %	1.86 %	-0.57 %	-0.30 %		0.11	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 115年01月11日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.71	11.77	51.41	2.15	15.52	10.24	1.42	71126.45
1	9.97	11.86	50.67	2.14	16.55	10.22	1.43	72687.58
2	9.91	12.60	50.64	2.75	15.11	10.10	1.43	71886.94
3	9.77	12.31	49.85	2.60	15.29	10.19	1.43	71758.39
4	9.78	11.62	54.47	2.41	15.69	10.40	1.42	73160.87
5	9.54	11.79	60.59	2.47	16.01	10.43	1.41	73576.01
6	9.36	12.48	54.08	2.50	15.19	10.57	1.41	72311.97
7	7.76	10.80	53.73	2.06	14.25	11.19	1.42	69827.96
8	8.85	11.90	49.64	3.15	15.18	10.13	1.41	72183.14
9	9.94	11.14	54.31	2.65	16.39	9.96	1.42	74502.61
10	9.32	12.72	47.02	3.76	14.08	10.24	1.43	71429.58
11	9.47	11.63	55.18	3.12	14.74	10.59	1.43	72914.72
12	5.93	13.29	55.27	3.56	14.33	10.59	1.44	72170.41
13	6.90	14.90	41.59	4.49	14.65	9.67	1.42	70547.86
14	9.45	11.62	48.41	3.41	14.61	10.13	1.41	70439.77
15	9.51	11.47	48.30	2.95	15.29	9.94	1.40	71545.91
16	9.71	11.27	44.94	2.46	17.04	9.54	1.41	73560.72
17	10.38	11.47	57.83	2.38	17.41	10.00	1.41	74296.25
18	9.25	12.35	52.99	2.59	16.06	10.11	1.40	76692.06
19	10.05	13.41	45.90	2.86	14.84	9.91	1.39	74162.19
20	9.82	12.13	46.95	1.09	14.88	10.02	1.39	72562.65
21	9.56	13.11	53.29	1.27	14.31	10.51	1.40	74503.07
22	9.69	12.83	46.91	1.10	14.75	10.28	1.41	71942.89
23	9.53	13.81	38.84	2.36	16.33	9.48	1.41	73921.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.30	12.26	50.53	2.60	15.35	10.18	1.41	72654.66
最 大 值	10.38	14.90	60.59	4.49	17.41	11.19	1.46	76692.06
發生時間	17	13	5	13	17	7		18
最 小 值	5.93	10.80	38.84	1.09	14.08	9.48	1.38	69827.96
發生時間	12	7	23	20	10	23		7
零點偏移(率)	-0.06 %	-0.04 %	-0.04 %	-0.01 %		-0.06	-0.01	0.10 %
全幅偏移(率)	-0.26 %	0.16 %	-0.38 %	0.33 %		0.17	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								