

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月01日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.44	6.83	44.07	1.67	16.63	11.95	1.04	78442.95
1	10.32	1.19	36.12	1.53	16.08	11.93	1.05	79626.71
2	9.07	1.92	43.37	0.68	18.29	11.23	1.06	83617.16
3	7.93	2.42	46.90	1.32	16.78	11.98	1.08	76524.11
4	4.86	10.70	16.46	3.21	20.32	9.16	1.06	85049.17
5	11.13	9.75	52.26	1.54	17.97	9.95	1.06	90742.89
6	11.87	1.64	67.47	1.51	15.98	10.95	1.06	85378.77
7	10.08	6.49	44.06	1.87	15.56	11.40	1.06	82589.94
8	9.37	26.52	18.01	4.31	16.25	10.41	1.06	88341.10
9	9.31	2.45	54.00	1.33	13.81	12.53	1.05	77685.60
10	6.61	4.82	53.92	1.28	15.44	11.98	1.04	80212.52
11	5.25	4.61	59.24	1.23	15.30	12.19	1.04	78371.88
12	7.33	4.30	49.06	1.61	14.81	12.19	1.06	78602.94
13	8.08	6.81	50.43	2.67	13.61	12.50	1.05	76475.76
14	7.99	5.96	54.12	1.96	14.24	12.40	1.06	76880.79
15	7.72	4.66	55.88	1.66	14.26	12.31	1.06	77825.08
16	8.21	7.54	49.03	2.34	13.79	12.47	1.06	76799.53
17	4.56	5.91	52.64	1.37	14.97	12.11	1.06	79313.68
18	1.12	9.72	56.85	0.72	16.18	11.60	1.06	82705.22
19	2.86	10.00	57.45	0.72	17.13	11.20	1.05	85100.33
20	7.99	10.47	46.48	1.41	15.87	11.49	1.04	83858.06
21	7.81	10.57	47.37	1.58	16.11	11.45	1.03	83321.69
22	7.92	6.88	47.74	1.68	15.11	12.08	1.02	78997.90
23	4.07	7.08	64.01	0.68	16.61	11.84	1.03	79891.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.62	7.05	48.62	1.66	15.88	11.64	1.05	81098.12
最 大 值	11.87	26.52	67.47	4.31	20.32	12.53	1.09	90742.89
發生時間	6	8	6	8	4	9		5
最 小 值	1.12	1.19	16.46	0.68	13.61	9.16	1.02	76475.76
發生時間	18	1	4	2	13	4		13
零點偏移(率)	-0.01 %	-0.01 %	-0.14 %	-0.00 %		0.00		0.20 %
全幅偏移(率)	0.02 %	1.25 %	-0.06 %	0.37 %		-0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月01日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	5.36	3.88	46.06	1.08	15.06	10.88	1.13	77213.04
1	7.30	4.15	40.46	1.22	15.44	10.59	1.14	78133.58
2	7.02	1.68	48.18	0.79	17.82	10.37	1.13	80513.72
3	6.86	1.27	46.69	1.57	16.81	10.47	1.13	80148.99
4	4.25	1.33	49.60	2.55	15.94	10.58	1.13	80316.92
5	9.05	4.03	54.23	1.07	16.68	10.46	1.11	82395.31
6	2.61	4.14	50.68	0.82	16.49	10.49	1.11	80621.01
7	1.01	5.84	54.63	1.30	15.12	11.05	1.10	75130.54
8	0.96	3.67	47.02	1.27	14.27	10.87	1.10	75443.44
9	0.86	4.19	41.79	1.26	14.24	10.84	1.12	72289.19
10	1.12	3.20	39.85	0.59	15.81	10.32	1.12	75251.44
11	1.19	2.97	43.04	0.79	15.59	10.04	1.11	76418.99
12	1.13	3.56	46.64	1.06	14.60	10.59	1.11	72648.99
13	1.13	2.70	47.98	0.81	14.99	10.59	1.10	72932.83
14	1.13	3.83	46.71	0.98	14.98	10.53	1.13	74494.15
15	1.13	3.78	43.92	0.76	15.44	10.41	1.11	73935.61
16	1.13	6.52	41.57	0.99	14.43	10.61	1.10	72425.61
17	1.08	3.45	42.86	0.65	16.07	9.90	1.10	79363.13
18	1.12	7.74	44.75	1.43	14.01	10.48	1.10	76128.59
19	1.13	2.69	47.76	0.73	15.72	10.44	1.10	75931.38
20	0.68	8.40	41.73	0.63	15.28	10.45	1.10	74343.26
21	0.02	8.47	42.69	0.86	15.17	10.39	1.10	75526.85
22	0.24	6.90	47.29	1.04	14.98	10.54	1.10	75143.51
23	0.07	9.35	42.52	0.90	14.95	10.31	1.10	75422.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.40	4.49	45.78	1.05	15.41	10.51	1.11	76340.52
最 大 值	9.05	9.35	54.63	2.55	17.82	11.05	1.14	82395.31
發生時間	5	23	7	4	2	7		5
最 小 值	0.02	1.27	39.85	0.59	14.01	9.90	1.09	72289.19
發生時間	21	3	10	10	18	17		9
零點偏移(率)	-0.11 %	-0.00 %	-0.02 %	0.00 %		0.02		0.00 %
全幅偏移(率)	0.00 %	-0.35 %	-1.04 %	-0.05 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								