

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月08日

報表日期: 114年06月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.85	3.32	65.32	1.51	18.44	11.84	1.28	76546.34
1	7.73	3.65	52.54	3.30	17.97	11.24	1.26	82149.31
2	3.88	3.16	62.88	2.51	16.99	11.63	1.25	79813.81
3	2.77	6.67	58.95	3.24	16.53	11.52	1.25	81250.82
4	4.98	3.70	59.74	3.09	17.42	11.41	1.26	81212.10
5	5.03	1.27	53.40	1.72	17.64	11.60	1.26	81864.55
6	8.73	2.63	54.90	3.82	17.66	11.15	1.26	83320.79
7	5.85	2.55	62.78	2.88	17.80	11.68	1.26	78718.99
8	4.21	2.74	53.40	2.79	17.91	11.35	1.27	81039.75
9	6.95	4.31	53.43	2.69	19.14	10.75	1.26	85144.24
10	9.29	9.19	43.96	4.47	18.54	10.69	1.25	85890.30
11	0.52	5.16	43.00	2.30	17.21	11.32	1.25	81526.64
12	11.14	1.11	45.27	5.10	15.75	11.54	1.25	81732.56
13	4.66	1.04	53.13	3.02	17.75	11.22	1.26	82222.88
14	3.27	1.38	42.61	3.46	15.53	11.75	1.25	79839.56
15	6.68	1.24	49.87	3.49	16.18	11.69	1.25	79846.73
16	5.91	3.44	53.71	1.99	15.80	11.74	1.25	79340.77
17	3.93	2.73	58.94	2.32	17.78	11.51	1.25	79703.72
18	3.31	2.80	51.44	2.32	17.72	11.33	1.25	81356.01
19	2.17	5.28	44.03	2.72	17.12	11.30	1.25	82050.70
20	2.86	2.81	54.86	2.37	17.87	11.27	1.25	81858.61
21	3.79	2.56	52.89	3.17	16.73	11.47	1.25	81125.43
22	5.39	2.36	65.46	2.43	18.35	11.34	1.25	80802.66
23	3.25	3.57	50.92	2.77	17.31	11.08	1.25	83321.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.88	3.28	53.64	2.90	17.38	11.39	1.26	81319.93
最 大 值	11.14	9.19	65.46	5.10	19.14	11.84	1.29	85890.30
發生時間	12	10	22	12	9	0		10
最 小 值	0.52	1.04	42.61	1.51	15.53	10.69	1.24	76546.34
發生時間	11	13	14	0	14	10		0
零點偏移(率)	-0.75 %	-0.01 %	-0.00 %	0.00 %		-0.06		0.10 %
全幅偏移(率)	0.00 %	-0.24 %	0.23 %	0.62 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月08日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.96	3.61	56.08	1.58	18.28	10.94	1.05	80527.39
1	7.59	3.74	62.18	2.23	18.45	11.23	1.05	78757.74
2	7.43	5.22	53.05	2.12	18.49	10.76	1.05	81861.33
3	5.77	1.37	58.99	1.72	19.11	10.18	1.05	86460.12
4	7.55	2.45	53.72	2.02	19.60	10.05	1.04	86331.44
5	7.58	4.32	57.39	1.99	19.73	10.05	1.04	86312.62
6	0.65	1.53	54.80	2.18	18.57	10.53	1.02	84177.96
7	0.50	2.95	53.34	1.22	19.98	10.29	1.03	82505.38
8	1.37	5.08	52.45	2.08	18.97	10.33	1.04	84262.84
9	5.72	1.83	56.17	2.37	18.84	10.32	1.05	85181.30
10	8.80	2.26	52.34	2.54	18.74	10.16	1.04	86073.79
11	5.98	1.91	59.72	2.55	18.18	10.83	1.05	81392.62
12	7.83	4.56	54.25	2.63	20.21	9.55	1.04	89683.82
13	4.31	4.81	57.30	2.44	17.49	10.94	1.04	81231.23
14	1.51	5.68	57.98	3.49	16.58	10.74	1.04	83419.11
15	1.23	3.50	46.03	4.44	14.47	11.62	1.04	71893.81
16	5.01	2.25	61.53	2.79	18.26	10.54	1.04	84083.96
17	9.60	3.63	51.95	2.66	17.18	10.52	1.04	84282.40
18	7.85	2.64	57.19	2.45	18.00	10.35	1.04	85402.39
19	7.47	4.80	59.20	1.95	19.18	9.99	1.04	86541.06
20	8.90	4.53	55.66	1.69	19.43	9.91	1.05	87006.23
21	10.07	7.29	58.90	2.37	17.67	10.17	1.04	86302.29
22	8.64	3.74	60.36	1.36	19.03	10.02	1.04	83585.21
23	8.43	2.47	57.51	1.71	18.89	9.92	1.04	85452.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.86	3.59	56.17	2.27	18.47	10.41	1.04	83863.69
最 大 值	10.07	7.29	62.18	4.44	20.21	11.62	1.09	89683.82
發生時間	21	21	1	15	12	15		12
最 小 值	0.50	1.37	46.03	1.22	14.47	9.55	1.02	71893.81
發生時間	7	3	15	7	15	12		15
零點偏移(率)	-0.06 %	0.01 %	-0.13 %	-0.05 %		-0.06		-0.10 %
全幅偏移(率)	0.14 %	0.17 %	-0.50 %	0.38 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月08日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.69	5.67	61.45	1.98	20.06	9.53	1.43	81248.49
1	5.79	1.43	61.59	2.94	21.08	9.48	1.45	80074.39
2	3.62	12.23	60.32	3.09	19.57	9.20	1.48	84591.95
3	6.60	11.69	61.15	3.20	19.44	9.50	1.47	80043.31
4	6.46	7.36	59.45	2.15	20.06	9.10	1.46	86199.87
5	1.47	2.55	54.48	2.92	19.44	9.31	1.43	83475.69
6	3.22	1.89	59.19	3.18	20.20	9.41	1.44	81469.70
7	1.98	1.45	58.27	2.66	20.26	9.64	1.45	78551.27
8	2.22	5.47	54.50	2.57	20.13	9.37	1.45	81972.24
9	3.36	1.66	46.37	2.71	19.69	9.10	1.48	84094.66
10	4.43	1.09	49.13	2.65	19.37	8.87	1.44	82681.59
11	3.09	3.93	48.30	2.77	18.42	9.24	1.43	82052.16
12	5.32	3.57	49.04	2.63	17.91	9.55	1.43	79146.46
13	5.62	2.43	47.39	2.96	19.32	9.09	1.44	82152.06
14	5.15	3.76	43.80	2.76	18.39	9.09	1.46	80009.88
15	3.51	0.88	52.45	2.81	19.35	9.62	1.47	77262.16
16	3.90	11.38	56.45	2.79	18.60	9.50	1.48	83372.04
17	7.54	4.86	61.10	2.85	16.39	10.15	1.47	81394.99
18	11.00	10.66	57.30	3.40	16.17	9.97	1.42	80080.52
19	5.36	5.26	58.83	2.75	18.13	9.64	1.42	81048.26
20	9.67	6.98	57.54	3.12	18.13	9.39	1.43	82013.45
21	6.42	3.56	58.05	2.59	17.59	9.71	1.43	79047.56
22	6.74	4.11	59.08	2.76	18.29	9.53	1.44	80492.06
23	3.88	4.78	58.36	2.63	17.39	9.64	1.46	80185.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.96	4.94	55.57	2.79	18.89	9.44	1.45	81360.86
最 大 值	11.00	12.23	61.59	3.40	21.08	10.15	1.48	86199.87
發生時間	18	2	1	18	1	17		4
最 小 值	1.47	0.88	43.80	1.98	16.17	8.87	1.41	77262.16
發生時間	5	15	14	0	18	10		15
零點偏移(率)	-0.01 %	-0.00 %	-0.06 %	-0.07 %		-0.02		-0.20 %
全幅偏移(率)	0.39 %	-0.16 %	-0.26 %	0.15 %		0.39		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								