

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.04	3.97	61.27	0.71	19.88	10.48	1.01	88047.29
1	10.23	4.55	46.96	0.91	20.73	10.49	1.01	87349.83
2	10.52	3.34	50.99	1.56	19.57	11.12	1.00	83180.27
3	8.14	3.39	62.02	1.23	17.71	12.00	1.02	78071.19
4	1.47	5.78	66.38	0.39	19.19	12.32	1.02	73662.27
5	8.50	2.19	42.42	1.09	18.18	10.68	1.02	85705.14
6	10.21	3.82	48.80	2.95	15.99	10.99	1.02	83497.43
7	10.28	3.05	53.72	3.84	16.17	11.18	1.02	80612.66
8	9.22	2.44	52.66	2.59	17.64	10.69	1.02	84913.17
9	10.27	3.02	41.57	3.75	16.57	10.76	1.01	79729.12
10	5.59	3.60	64.72	1.35	18.05	11.28	1.00	76426.49
11	6.62	4.73	54.31	1.35	19.10	10.78	1.01	83937.96
12	8.32	5.46	46.63	2.44	17.64	11.06	1.02	84224.14
13	13.21	4.98	64.45	2.47	17.93	11.23	1.02	82355.92
14	13.46	5.22	55.48	2.10	19.55	10.68	0.99	86071.09
15	7.83	6.20	46.06	2.51	16.52	11.48	0.99	83103.30
16	6.21	2.91	50.91	1.74	17.10	11.26	1.00	82573.24
17	9.04	2.61	49.69	1.95	17.39	11.06	1.02	82475.30
18	8.02	3.03	45.17	1.48	18.17	10.78	1.02	84007.50
19	10.18	3.01	45.05	1.32	18.27	10.94	1.02	84640.63
20	8.69	3.49	53.32	0.93	19.14	10.91	1.02	85140.81
21	9.39	3.24	53.49	1.49	19.17	10.51	1.02	88211.68
22	7.82	3.38	48.82	1.98	16.80	11.68	1.02	78464.23
23	19.50	3.39	46.08	2.77	17.00	11.39	1.02	81949.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.24	3.78	52.12	1.87	18.06	11.07	1.01	82847.94
最 大 值	19.50	6.20	66.38	3.84	20.73	12.32	1.04	88211.68
發生時間	23	15	4	7	1	4		21
最 小 值	1.47	2.19	41.57	0.39	15.99	10.48	0.99	73662.27
發生時間	4	5	9	4	6	0		4
零點偏移(率)	-0.29 %	-0.00 %	-0.03 %	0.00 %		-0.16		0.10 %
全幅偏移(率)	4.70 %	1.38 %	-0.46 %	0.72 %		-0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月07日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO ₂ _C ppm	#3-H ₂ O %	#3-O ₂ _C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	0.00	2.90	57.96	0.20	20.14	10.32	0.99	81186.10
1	0.13	3.75	49.89	0.17	22.91	9.11	0.99	87076.17
2	1.98	6.17	40.98	0.38	21.19	9.21	0.99	88981.48
3	5.77	4.92	49.44	0.67	17.40	10.21	0.99	83819.36
4	9.17	3.84	52.26	1.18	17.10	10.10	0.99	85940.83
5	15.01	2.29	56.97	1.29	18.34	10.06	0.99	84389.50
6	6.63	5.47	57.20	1.24	16.47	10.74	0.99	80662.71
7	5.08	4.48	46.06	2.09	15.92	10.08	0.98	84216.52
8	4.81	4.05	46.67	0.58	15.28	10.52	0.96	76823.39
9	1.30	5.20	53.58	0.18	16.01	10.88	0.97	76921.19
10	0.72	4.57	60.90	0.08	19.19	10.35	0.98	80485.34
11	1.64	3.96	43.12	0.08	20.38	9.73	0.99	84911.94
12	1.10	7.74	49.52	0.11	19.46	9.94	0.97	84808.14
13	2.19	3.01	57.33	0.18	17.80	10.46	0.97	81935.90
14	5.66	6.40	49.03	0.36	17.43	10.38	0.94	79130.69
15	1.22	9.91	56.31	0.19	17.45	10.49	0.94	82182.56
16	0.48	8.44	48.84	0.07	20.49	9.75	0.96	85368.16
17	0.73	9.77	37.50	0.21	18.98	9.75	0.98	86464.49
18	3.23	8.12	39.88	0.54	16.99	10.52	0.98	79910.98
19	2.42	4.90	53.08	0.32	19.73	10.14	0.99	80993.58
20	3.01	6.75	44.82	0.27	20.75	9.54	0.99	85202.19
21	6.18	11.66	42.32	0.50	19.41	9.90	0.99	84424.77
22	6.60	2.61	39.95	0.46	17.38	10.78	0.98	77290.07
23	16.92	1.61	45.56	2.87	20.18	9.66	0.99	83648.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均値	4.25	5.52	49.13	0.59	18.60	10.11	0.98	82782.27
最大値	16.92	11.66	60.90	2.87	22.91	10.88	1.00	88981.48
發生時間	23	21	10	23	1	9		2
最小値	0.00	1.61	37.50	0.07	15.28	9.11	0.92	76823.39
發生時間	0	23	17	16	8	1		8
零點偏移(率)	-0.12 %	-0.01 %	-0.20 %	-0.02 %		-0.11		0.20 %
全幅偏移(率)	0.02 %	0.57 %	-0.27 %	0.21 %		0.30		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								