

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.16	3.16	59.67	3.65	14.08	12.40	1.43	68542.56
1	6.03	3.17	46.83	3.35	14.45	12.30	1.43	68890.06
2	7.95	3.31	51.23	3.23	15.01	12.26	1.43	68307.48
3	5.77	2.88	55.11	3.01	14.74	12.17	1.44	69490.29
4	5.92	3.54	62.91	3.36	14.46	12.52	1.44	67327.55
5	2.42	5.33	39.70	3.77	13.42	12.51	1.44	68111.84
6	7.73	3.92	55.24	3.66	14.30	12.45	1.44	67784.22
7	7.65	3.71	58.54	3.16	14.99	12.05	1.43	70497.16
8	10.68	4.02	63.01	3.48	14.64	11.93	1.43	71651.98
9	10.59	3.85	63.17	4.18	13.53	12.58	1.41	67094.53
10	8.50	3.72	53.13	4.17	13.81	12.74	1.41	66970.36
11	6.82	3.88	68.31	3.57	13.96	12.58	1.40	66837.94
12	6.47	5.96	41.69	3.97	13.37	12.69	1.42	66156.77
13	9.80	3.14	41.93	4.58	13.13	12.84	1.43	65849.00
14	6.12	4.09	64.20	4.85	12.67	13.57	1.41	60442.43
15	4.95	3.78	57.83	3.51	14.38	12.74	1.40	65594.36
16	3.28	3.78	48.81	3.63	13.58	12.37	1.38	69336.32
17	8.14	6.33	49.69	3.95	13.59	12.43	1.36	68625.34
18	8.97	3.35	52.61	3.64	14.09	12.27	1.39	69470.01
19	5.93	3.24	63.67	3.35	14.35	12.49	1.42	68003.27
20	4.40	3.44	54.32	3.34	14.38	12.41	1.44	68064.78
21	4.55	3.80	51.32	3.34	14.14	12.27	1.43	69420.26
22	10.31	3.29	51.78	2.90	15.72	12.11	1.42	70703.14
23	9.57	3.67	56.67	3.50	14.62	12.40	1.41	68690.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.15	3.85	54.64	3.63	14.14	12.46	1.42	67994.27
最大值	10.68	6.33	68.31	4.85	15.72	13.57	1.46	71651.98
發生時間	8	17	11	14	22	14		8
最小值	2.42	2.88	39.70	2.90	12.67	11.93	1.36	60442.43
發生時間	5	3	5	22	14	8		14
零點偏移(率)	0.00 %	-0.01 %	-0.00 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	-0.90 %	1.00 %	-0.68 %	0.24 %		0.08	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.10	3.45	50.44	2.45	16.79	10.26	1.51	83214.02
1	8.32	1.52	46.59	2.09	18.28	10.30	1.50	82444.77
2	8.77	2.39	40.83	2.18	19.72	9.60	1.50	85848.59
3	9.20	2.74	35.91	2.58	19.38	9.46	1.49	82755.23
4	10.50	3.16	41.37	2.91	19.16	9.52	1.50	88234.60
5	10.48	6.76	38.88	3.71	18.97	9.60	1.49	85527.05
6	9.40	3.39	61.61	3.50	18.67	9.79	1.45	83177.50
7	7.61	1.59	43.20	2.61	17.26	10.46	1.45	79198.96
8	10.45	1.40	56.42	2.30	20.35	9.63	1.44	89868.40
9	10.02	1.21	53.39	2.72	17.00	10.62	1.47	82473.24
10	10.43	1.51	55.60	2.83	17.38	10.54	1.49	84558.88
11	11.01	1.62	51.76	3.43	16.01	10.52	1.48	81538.09
12	9.95	2.71	49.91	3.24	16.61	10.44	1.48	80330.02
13	9.39	2.17	44.63	3.13	15.47	10.76	1.45	80210.44
14	8.83	1.96	54.23	2.60	17.09	10.48	1.49	81293.01
15	10.39	3.81	53.50	2.71	15.63	10.74	1.50	81195.42
16	10.35	3.46	55.56	2.48	17.48	10.26	1.49	83174.86
17	10.18	3.53	52.12	2.74	16.98	10.47	1.48	81493.08
18	10.33	7.28	59.03	2.30	18.25	10.31	1.45	81989.86
19	10.82	4.48	56.75	2.65	17.05	10.55	1.45	84178.65
20	10.13	3.67	56.52	2.40	17.05	10.55	1.46	81540.32
21	10.78	3.69	47.57	2.62	16.86	10.37	1.49	81313.62
22	10.18	3.85	48.63	2.58	16.36	10.49	1.49	80495.07
23	10.86	3.55	48.34	2.58	17.13	10.15	1.50	79240.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.94	3.12	50.12	2.72	17.54	10.24	1.48	82720.60
最大值	11.01	7.28	61.61	3.71	20.35	10.76	1.52	89868.40
發生時間	11	18	6	5	8	13		8
最小值	7.61	1.21	35.91	2.09	15.47	9.46	1.44	79198.96
發生時間	7	9	3	1	13	3		7
零點偏移(率)	0.00 %	-0.06 %	-0.05 %	-0.01 %		-0.05	0.00	0.00 %
全幅偏移(率)	1.90 %	1.04 %	-0.63 %	0.25 %		0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.19	4.78	56.60	2.97	14.85	10.90	1.40	78479.18
1	9.14	4.24	61.76	2.62	16.66	10.96	1.40	78328.58
2	6.92	9.57	47.59	2.43	16.38	10.69	1.40	78071.48
3	4.44	4.61	63.40	1.99	17.00	10.77	1.41	77094.84
4	4.36	3.80	54.18	1.85	16.75	10.75	1.44	82113.46
5	8.54	6.79	58.58	2.43	15.63	10.98	1.43	83465.80
6	7.50	4.01	55.49	2.79	14.73	10.88	1.41	79527.77
7	9.29	5.50	63.16	2.63	15.32	11.05	1.41	75341.74
8	10.27	4.87	55.82	3.77	15.99	10.55	1.41	83585.50
9	8.99	3.67	61.74	3.10	14.33	11.16	1.41	78180.20
10	8.12	3.57	59.06	2.30	17.35	10.18	1.41	81712.13
11	9.55	9.62	53.78	3.07	14.69	10.52	1.39	79316.49
12	7.57	6.84	47.35	2.27	15.30	10.51	1.38	76058.17
13	8.92	1.86	61.66	2.91	14.27	11.15	1.38	78674.60
14	4.41	1.78	58.72	2.10	15.64	10.81	1.38	79085.71
15	4.07	4.09	56.18	2.08	15.63	11.09	1.38	80712.61
16	3.51	4.84	64.71	2.19	15.58	11.05	1.38	79589.12
17	7.18	3.42	56.91	2.31	15.75	10.60	1.37	81936.80
18	7.43	4.17	58.02	2.70	15.27	10.65	1.38	82234.88
19	7.40	7.91	62.69	2.68	15.36	11.00	1.38	81665.84
20	10.73	4.71	59.25	2.86	15.04	11.16	1.39	81468.05
21	12.66	4.27	65.45	2.66	15.57	11.07	1.39	82509.63
22	11.16	4.11	58.64	2.57	15.65	10.91	1.38	82620.96
23	11.15	4.07	66.54	2.58	15.70	10.86	1.38	82317.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.02	4.88	58.64	2.58	15.60	10.84	1.40	80170.47
最大值	12.66	9.62	66.54	3.77	17.35	11.16	1.54	83585.50
發生時間	21	11	23	8	10	9		8
最小值	3.51	1.78	47.35	1.85	14.27	10.18	1.36	75341.74
發生時間	16	14	12	4	13	10		7
零點偏移(率)	-0.02 %	-0.01 %	-0.07 %	-0.02 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.15 %	0.43 %	-0.55 %	0.38 %		-0.10	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								