

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.31	12.01	38.85	1.83	19.33	10.68	1.32	83844.14
1	7.95	12.05	43.22	1.02	21.44	10.28	1.32	84944.79
2	5.41	12.27	35.54	1.21	19.67	10.55	1.31	84516.54
3	4.39	12.23	57.87	1.64	16.94	11.69	1.32	78366.07
4	8.95	12.13	54.84	2.96	16.01	11.43	1.32	81225.56
5	6.02	12.35	53.74	1.55	18.99	10.81	1.34	72147.00
6	4.36	12.29	49.84	1.11	19.20	10.64	1.34	84427.06
7	8.88	12.28	49.61	1.57	19.11	10.67	1.34	84290.90
8	8.34	12.79	47.97	1.52	18.10	10.87	1.34	83040.90
9	10.23	12.93	54.16	1.64	17.88	11.19	1.34	79714.82
10	7.65	13.10	61.69	1.51	17.42	11.56	1.33	77908.52
11	8.28	12.63	56.10	1.28	17.94	11.15	1.34	81100.22
12	10.75	12.73	54.99	1.84	16.85	11.34	1.34	79784.09
13	8.49	12.77	55.64	2.03	15.80	11.42	1.34	77123.96
14	10.41	12.84	60.30	1.76	15.65	11.57	1.34	75568.07
15	11.78	12.75	53.08	1.96	15.91	11.31	1.34	77896.53
16	9.47	13.05	48.81	1.94	16.80	11.01	1.34	81325.43
17	10.18	12.43	51.42	1.65	17.33	11.01	1.34	82432.28
18	8.89	12.71	57.05	1.32	17.33	11.27	1.34	80772.66
19	9.57	12.70	55.87	2.03	15.59	11.22	1.34	80848.01
20	8.95	12.81	52.63	1.34	17.31	11.13	1.34	81394.55
21	9.81	12.38	51.59	1.67	18.06	10.60	1.34	85727.21
22	9.86	12.72	50.43	1.84	16.89	11.07	1.34	82763.69
23	11.44	13.75	59.63	2.48	16.00	12.05	1.34	74446.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.72	12.61	52.29	1.70	17.56	11.10	1.34	80650.41
最大值	11.78	13.75	61.69	2.96	21.44	12.05	1.35	85727.21
發生時間	15	23	10	4	1	23		21
最小值	4.36	12.01	35.54	1.02	15.59	10.28	1.31	72147.00
發生時間	6	0	2	1	19	1		5
零點偏移(率)	-0.08 %	-0.00 %	-0.36 %	-0.04 %		-0.05	-0.01	0.20 %
全幅偏移(率)	0.02 %	-0.08 %	-0.03 %	-0.42 %		0.17	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.12	10.09	62.17	0.91	17.57	11.32	0.83	70742.30
1	10.70	9.30	62.27	1.14	18.91	10.83	0.83	79521.05
2	9.24	10.09	63.19	1.04	18.17	11.58	0.83	70404.77
3	12.04	10.20	59.40	0.82	19.06	10.81	0.83	80897.09
4	15.06	9.31	58.45	1.33	18.06	10.83	0.83	82860.31
5	17.08	10.80	65.24	1.99	16.80	11.32	0.83	80762.02
6	9.21	8.41	61.41	0.65	18.70	10.73	0.83	76420.93
7	12.38	8.65	58.13	0.51	19.50	10.66	0.82	81979.67
8	9.30	8.01	53.74	0.97	18.55	10.70	0.82	83386.78
9	9.85	15.70	65.43	0.63	19.03	10.37	0.82	84772.00
10	8.91	9.52	60.23	0.79	17.66	11.57	0.81	75200.74
11	11.80	8.68	58.42	1.18	17.41	11.01	0.81	78683.95
12	10.93	13.79	49.84	1.25	17.18	10.98	0.82	80252.07
13	9.70	9.66	55.45	0.74	17.35	11.18	0.81	78027.79
14	13.14	9.30	52.99	0.98	17.33	10.95	0.81	79150.59
15	9.58	8.47	50.55	1.06	16.83	11.11	0.81	79102.04
16	9.60	7.45	58.69	0.80	16.70	10.99	0.82	79759.22
17	12.56	10.12	56.81	0.80	16.87	11.02	0.81	80617.44
18	11.00	8.97	54.46	0.81	16.89	10.94	0.81	79805.80
19	8.95	12.32	64.96	0.45	18.12	10.91	0.82	79442.97
20	9.63	12.51	59.49	0.73	17.95	11.45	0.83	73286.23
21	10.81	10.76	54.31	0.85	17.51	11.39	0.82	74438.16
22	13.69	14.23	50.54	1.78	16.25	11.61	0.82	73314.32
23	9.75	11.85	54.37	0.88	16.68	11.78	0.82	68616.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.83	10.34	57.94	0.96	17.71	11.08	0.82	77976.88
最大值	17.08	15.70	65.43	1.99	19.50	11.78	0.84	84772.00
發生時間	5	9	9	5	7	23		9
最小值	5.12	7.45	49.84	0.45	16.25	10.37	0.81	68616.86
發生時間	0	16	12	19	22	9		23
零點偏移(率)	-0.41 %	-0.10 %	-0.12 %	-0.00 %		-0.09	-0.06	-0.10 %
全幅偏移(率)	-1.17 %	0.60 %	1.02 %	-0.12 %		-0.07	0.31	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.50	12.80	64.96	1.79	17.64	11.22	1.35	65776.94
1	10.80	13.91	40.63	2.65	23.33	8.71	1.35	80286.83
2	12.27	11.34	40.52	1.79	20.09	8.92	1.34	82843.77
3	8.57	11.57	52.95	1.68	17.76	10.33	1.35	76311.66
4	9.61	11.68	53.03	1.70	17.92	10.43	1.35	75207.22
5	8.64	11.81	53.66	1.66	17.39	10.56	1.34	74188.57
6	10.58	11.83	57.22	1.83	18.32	10.50	1.34	76223.64
7	10.94	14.93	57.48	3.39	17.26	11.07	1.36	73837.38
8	15.71	16.05	54.20	3.39	19.09	10.18	1.36	78143.12
9	10.25	12.68	62.16	3.32	17.63	11.12	1.36	73979.12
10	11.97	17.36	55.90	4.22	16.77	11.46	1.33	71273.88
11	7.88	10.53	47.19	3.39	17.55	10.10	1.33	73811.45
12	6.76	10.35	50.66	2.68	17.63	9.91	1.36	73468.01
13	9.55	10.13	55.35	2.95	17.58	9.93	1.36	72580.37
14	11.03	10.16	54.83	3.06	17.53	9.90	1.34	72359.84
15	8.49	9.97	55.97	2.85	17.46	9.78	1.34	74701.73
16	9.45	10.04	53.05	2.74	17.24	9.83	1.36	74876.83
17	8.95	10.14	59.72	2.89	17.58	10.00	1.36	77352.69
18	9.77	11.07	49.28	2.37	16.21	9.78	1.35	75603.26
19	10.25	9.83	52.67	1.64	17.31	9.60	1.33	76003.83
20	10.51	11.49	52.00	2.87	18.65	9.34	1.34	78713.86
21	10.15	11.08	57.58	2.88	18.11	9.72	1.34	81405.12
22	10.30	11.65	58.47	3.05	18.29	10.24	1.33	78524.26
23	9.27	11.17	56.96	2.89	18.38	9.80	1.34	76546.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.93	11.82	54.02	2.65	18.03	10.10	1.35	75584.18
最大值	15.71	17.36	64.96	4.22	23.33	11.46	1.37	82843.77
發生時間	8	10	0	10	1	10		2
最小值	6.50	9.83	40.52	1.64	16.21	8.71	1.31	65776.94
發生時間	0	19	2	19	18	1		0
零點偏移(率)	-0.08 %	0.00 %	-0.16 %	-0.00 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-0.18 %	-0.00 %	0.30 %	0.06 %		0.28	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								