

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.37	3.39	62.04	3.72	16.97	12.23	1.43	68837.17
1	4.49	4.13	67.53	3.96	17.19	12.69	1.41	65011.17
2	10.43	3.61	48.10	4.13	16.55	12.17	1.40	70296.53
3	6.05	4.92	64.32	4.38	16.00	13.04	1.39	64704.55
4	3.94	3.97	62.03	3.83	16.84	12.36	1.37	68817.70
5	2.51	3.46	60.66	2.45	18.39	11.71	1.33	72526.54
6	9.59	3.14	50.69	3.01	16.82	11.74	1.33	73232.79
7	9.75	2.79	60.84	3.40	16.78	11.92	1.33	72095.72
8	8.98	2.92	56.93	3.48	16.45	12.26	1.38	69116.71
9	4.98	2.81	68.64	2.50	18.46	11.82	1.35	70854.44
10	4.91	2.92	45.20	2.52	18.10	11.61	1.39	72784.68
11	4.89	2.74	58.87	2.65	17.34	11.97	1.40	70222.05
12	1.93	2.71	63.20	2.27	18.59	11.59	1.41	72576.16
13	1.61	2.74	49.97	2.55	17.00	11.73	1.40	72529.43
14	4.48	3.50	44.80	2.95	16.28	12.17	1.40	69919.32
15	2.96	2.68	62.72	2.50	17.38	11.87	1.41	71458.86
16	7.56	2.63	48.12	2.97	16.90	11.85	1.37	71314.24
17	4.36	2.83	59.69	2.59	17.53	12.19	1.38	68676.73
18	8.09	2.69	53.85	2.61	17.66	11.72	1.39	72627.99
19	7.97	2.96	55.32	2.94	16.72	11.94	1.37	71310.99
20	10.29	4.50	51.46	3.68	15.05	12.42	1.38	68612.64
21	9.25	3.07	61.82	3.12	16.08	12.20	1.39	69592.20
22	7.27	2.70	66.62	2.87	16.76	12.28	1.41	69194.64
23	7.31	2.64	52.81	2.94	16.24	12.14	1.38	70658.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.25	3.19	57.34	3.08	17.00	12.07	1.38	70290.50
最大值	10.43	4.92	68.64	4.38	18.59	13.04	1.44	73232.79
發生時間	2	3	9	3	12	3		6
最小值	1.61	2.63	44.80	2.27	15.05	11.59	1.32	64704.55
發生時間	13	16	14	12	20	12		3
零點偏移(率)	-0.06 %	-0.00 %	-0.00 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.05 %	-0.12 %	-0.02 %	0.03 %		-0.05	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.22	2.79	53.68	1.40	19.58	10.05	1.43	84150.65
1	3.90	5.18	45.87	1.50	20.69	9.49	1.43	88487.61
2	10.18	5.03	49.16	2.45	18.67	9.51	1.41	86595.70
3	9.66	2.53	60.80	2.43	18.11	9.81	1.40	89225.92
4	10.20	3.74	54.52	2.92	16.37	10.10	1.41	86295.41
5	8.44	2.99	58.76	2.63	16.71	10.15	1.39	84903.25
6	11.65	3.09	49.58	2.97	17.14	9.75	1.35	84758.57
7	9.79	2.71	58.29	2.57	16.77	10.50	1.37	80038.06
8	6.18	2.61	54.11	1.74	18.83	9.68	1.36	84550.80
9	2.93	5.05	50.12	1.46	18.28	9.45	1.36	83619.74
10	2.12	3.88	46.23	1.47	17.97	9.99	1.34	78905.39
11	2.63	3.63	52.27	1.36	18.11	9.85	1.36	87188.44
12	6.78	2.87	61.29	1.84	17.52	10.18	1.37	81599.95
13	8.37	8.89	48.63	3.86	16.70	9.76	1.35	80135.81
14	10.25	6.52	39.47	2.25	18.15	9.24	1.36	81302.20
15	11.03	5.36	50.38	2.31	17.58	9.60	1.36	85841.41
16	9.14	5.30	41.66	2.01	17.19	9.76	1.36	82533.78
17	4.78	3.35	49.45	1.44	18.47	9.58	1.35	82305.54
18	9.79	4.81	44.87	2.02	17.79	9.52	1.33	83728.79
19	8.56	3.58	47.76	1.96	17.26	9.74	1.33	82411.67
20	9.07	4.87	57.47	1.98	17.75	9.86	1.33	82755.70
21	8.96	2.50	56.41	1.81	18.57	9.65	1.34	85035.96
22	10.70	2.67	56.16	1.74	18.29	10.06	1.37	87130.62
23	4.14	2.35	64.79	1.35	18.75	10.50	1.37	79069.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.56	4.01	52.16	2.06	17.97	9.82	1.37	83857.11
最大值	11.65	8.89	64.79	3.86	20.69	10.50	1.43	89225.92
發生時間	6	13	23	13	1	7		3
最小值	2.12	2.35	39.47	1.35	16.37	9.24	1.33	78905.39
發生時間	10	23	14	23	4	14		10
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.15 %		0.01	0.00	0.00 %
全幅偏移(率)	2.70 %	2.00 %	0.88 %	0.82 %		0.02	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.72	3.15	54.70	3.50	16.60	10.89	1.43	82392.24
1	4.19	2.64	59.85	3.56	17.13	11.52	1.43	79691.55
2	10.36	4.75	47.95	4.08	15.51	10.92	1.43	84736.88
3	10.77	3.59	56.04	4.00	15.05	10.93	1.43	85199.73
4	9.76	2.68	64.26	4.04	15.05	10.96	1.43	86001.27
5	10.07	2.19	61.45	4.00	14.94	10.98	1.43	86623.30
6	10.42	5.39	51.01	4.58	14.27	11.17	1.43	84275.67
7	8.24	5.52	60.84	3.96	15.84	10.93	1.43	83816.56
8	10.19	2.21	59.63	4.19	15.75	10.69	1.42	79553.49
9	7.79	2.84	63.84	3.33	16.73	10.95	1.42	78093.71
10	5.32	3.14	56.12	2.82	17.40	10.53	1.42	81121.48
11	4.88	1.94	62.97	2.85	16.68	10.56	1.42	82995.62
12	6.02	4.72	53.58	2.93	16.67	10.40	1.43	84644.75
13	3.26	2.31	59.88	2.88	15.39	10.82	1.43	80537.27
14	3.25	4.89	56.38	2.79	16.44	10.67	1.42	81170.25
15	8.27	3.45	57.38	3.25	16.13	10.65	1.41	79874.24
16	8.24	3.14	56.29	3.04	17.01	10.44	1.40	82412.97
17	9.38	3.68	69.09	3.42	16.65	11.66	1.42	76468.29
18	10.14	4.82	49.41	3.33	16.47	10.51	1.43	87911.73
19	8.49	2.63	62.97	3.23	16.19	10.65	1.42	86271.54
20	7.42	2.67	51.91	3.08	16.77	10.60	1.41	85666.00
21	8.67	1.61	69.23	3.13	16.66	11.01	1.41	81810.62
22	9.46	1.74	64.22	3.29	17.04	10.61	1.42	84514.88
23	10.53	2.37	65.08	3.59	16.73	10.98	1.40	81185.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.08	3.25	58.92	3.45	16.21	10.83	1.42	82790.41
最大值	10.77	5.52	69.23	4.58	17.40	11.66	1.45	87911.73
發生時間	3	7	21	6	10	17		18
最小值	3.25	1.61	47.95	2.79	14.27	10.40	1.38	76468.29
發生時間	14	21	2	14	6	12		17
零點偏移(率)	-0.17 %	0.00 %	-0.04 %	-0.08 %		0.01	0.00	0.00 %
全幅偏移(率)	1.11 %	-0.01 %	-0.26 %	0.06 %		-0.07	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								