

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.93	8.24	57.44	1.37	18.63	11.18	1.05	75670.07
1	9.21	8.76	55.72	1.56	20.30	10.97	1.05	75880.32
2	9.04	7.92	55.67	1.50	18.96	10.98	1.05	77300.03
3	11.37	9.25	52.12	2.07	18.35	11.09	1.05	76353.94
4	8.99	8.35	50.51	1.80	18.56	11.05	1.05	76374.59
5	12.12	11.35	57.83	1.19	19.71	10.81	1.05	85310.46
6	9.72	8.04	48.19	1.68	18.60	10.92	1.05	77464.29
7	10.49	7.78	50.98	1.72	18.23	11.17	1.06	75540.67
8	8.72	8.07	48.50	2.01	17.40	11.35	1.06	74921.73
9	9.89	7.45	52.70	1.56	17.86	11.26	1.06	75677.85
10	9.37	7.74	51.39	1.35	18.12	11.20	1.06	76276.58
11	8.97	8.30	51.35	1.52	17.83	11.48	1.06	74307.03
12	9.85	8.63	54.52	1.44	18.19	11.29	1.06	75292.16
13	9.38	8.48	51.67	1.90	17.62	11.45	1.06	74725.17
14	9.59	6.57	48.60	1.26	19.13	10.99	1.06	76938.84
15	7.40	8.47	56.60	1.07	17.99	11.84	1.06	71459.10
16	8.42	7.71	42.08	1.13	19.17	11.15	1.06	76084.16
17	9.21	7.69	42.55	1.31	19.00	11.19	1.05	75144.88
18	10.51	7.27	37.94	1.83	18.24	10.88	1.06	78382.34
19	9.13	8.02	42.44	1.93	18.31	11.36	1.06	73947.08
20	8.71	7.88	45.10	1.22	19.17	11.17	1.07	74737.07
21	9.11	8.86	48.54	1.18	18.82	11.67	1.07	70920.38
22	9.27	7.81	42.80	1.06	19.39	10.82	1.07	76830.89
23	10.61	8.80	47.08	1.34	18.71	10.73	1.07	77667.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.50	8.23	49.68	1.50	18.60	11.17	1.06	75966.95
最大值	12.12	11.35	57.83	2.07	20.30	11.84	1.08	85310.46
發生時間	5	5	5	3	1	15		5
最小值	7.40	6.57	37.94	1.06	17.40	10.73	1.05	70920.38
發生時間	15	14	18	22	8	23		21
零點偏移(率)	0.00 %	-0.01 %	-0.09 %	-0.02 %		-0.08		0.00 %
全幅偏移(率)	-0.44 %	2.59 %	0.42 %	1.08 %		0.15		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.05	8.57	42.11	1.82	18.08	9.92	1.00	86367.40
1	8.79	9.85	45.49	2.46	17.26	10.20	0.99	85178.40
2	9.49	2.48	56.29	2.37	16.79	10.34	1.00	84598.50
3	9.20	3.72	46.01	2.24	17.17	9.94	1.00	87909.77
4	9.70	6.23	49.09	2.70	16.50	10.13	1.01	86252.72
5	9.13	4.14	50.41	3.03	15.93	10.12	1.02	87236.27
6	10.50	5.68	58.01	2.49	15.75	10.29	1.02	83307.53
7	9.97	10.10	56.07	2.83	15.58	10.31	1.02	85690.71
8	10.18	4.90	49.90	2.85	15.90	10.44	1.02	84416.11
9	9.36	4.12	49.89	2.56	16.08	10.28	1.03	85630.12
10	9.90	8.17	47.68	3.26	14.86	10.63	1.05	84262.02
11	11.72	2.08	58.30	1.80	17.20	10.06	1.04	86756.96
12	9.35	2.35	40.76	1.65	17.10	9.92	1.02	87643.37
13	8.66	3.23	51.69	2.53	15.39	10.81	1.02	82255.29
14	8.25	4.66	61.28	1.14	16.92	10.64	1.03	82204.12
15	5.91	4.26	51.38	1.45	17.36	10.45	1.05	82951.69
16	8.34	5.37	47.05	2.13	16.74	10.42	1.03	83861.52
17	9.25	6.83	52.32	2.67	15.77	10.54	1.02	84149.04
18	7.57	3.74	51.91	1.31	17.90	10.06	1.05	85464.65
19	9.38	4.41	48.73	1.77	17.30	10.29	1.05	84580.33
20	9.49	3.96	50.11	1.03	18.56	10.27	1.05	83051.53
21	9.68	7.19	47.24	1.08	18.06	10.01	1.05	85148.01
22	9.79	4.81	45.18	1.48	16.87	10.60	1.06	82196.94
23	10.02	6.49	41.50	1.79	17.37	10.03	1.06	85652.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.28	5.31	49.93	2.10	16.77	10.28	1.03	84865.21
最大值	11.72	10.10	61.28	3.26	18.56	10.81	1.07	87909.77
發生時間	11	7	14	10	20	13		3
最小值	5.91	2.08	40.76	1.03	14.86	9.92	0.99	82196.94
發生時間	15	11	12	20	10	0		22
零點偏移(率)	-0.05 %	0.00 %	-0.03 %	-0.06 %		0.01		-0.10 %
全幅偏移(率)	0.02 %	2.36 %	0.83 %	0.92 %		-0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.27	7.93	59.53	1.45	16.27	11.01	0.97	82436.56
1	8.94	7.82	56.85	1.97	15.27	11.44	0.97	77460.24
2	9.52	8.09	60.23	1.86	15.79	11.10	0.96	79750.07
3	9.43	5.26	58.23	2.08	15.16	11.35	0.97	79822.69
4	9.17	5.71	58.81	2.11	15.44	11.16	0.97	80988.25
5	8.87	5.22	55.03	1.96	15.38	11.00	0.96	78462.47
6	9.32	5.11	54.84	2.17	15.02	10.96	0.96	79186.83
7	3.27	6.57	54.48	2.15	13.76	11.33	0.95	75622.54
8	9.64	7.43	52.38	2.56	13.75	11.15	0.96	75152.80
9	9.07	5.52	52.57	2.04	14.84	10.90	0.96	77434.28
10	9.75	5.48	52.22	2.14	14.73	10.92	0.96	76540.25
11	9.58	5.68	60.72	1.82	15.33	11.24	0.95	73018.66
12	10.06	7.17	44.57	2.23	14.83	10.68	0.94	76736.32
13	9.31	6.06	51.17	1.79	15.14	10.89	0.96	76875.78
14	9.62	4.61	45.77	2.15	14.62	10.70	0.95	78951.56
15	7.34	3.75	61.15	1.79	14.73	11.65	0.95	71723.55
16	2.67	4.61	53.71	1.39	14.97	11.63	0.95	70597.62
17	6.56	5.80	42.66	1.74	15.12	11.05	0.96	75537.05
18	9.15	4.91	48.50	2.03	15.07	10.91	0.96	76964.72
19	8.74	4.09	49.87	1.94	15.32	11.09	0.97	75250.16
20	7.86	5.22	48.17	1.74	15.86	11.08	0.97	77985.56
21	9.17	6.08	47.99	1.39	17.27	10.63	0.97	86610.95
22	9.30	4.87	45.32	1.67	16.15	11.09	0.97	84252.16
23	9.84	4.98	54.13	1.79	15.97	10.92	0.97	84993.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.56	5.75	52.87	1.92	15.24	11.08	0.96	78014.79
最大值	10.06	8.09	61.15	2.56	17.27	11.65	0.98	86610.95
發生時間	12	2	15	8	21	15		21
最小值	2.67	3.75	42.66	1.39	13.75	10.63	0.94	70597.62
發生時間	16	15	17	16	8	21		16
零點偏移(率)	0.00 %	0.00 %	-0.12 %	-0.03 %		0.04		0.00 %
全幅偏移(率)	0.04 %	-0.10 %	-0.81 %	0.07 %		0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								