





P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月14日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.12	4.18	58.81	1.91	16.75	9.58	1.42	82113.86
1	7.77	2.57	61.74	3.08	13.69	10.92	1.41	76335.85
2	4.12	5.93	59.55	1.79	15.82	10.01	1.41	74641.02
3	1.71	3.18	60.39	1.42	17.41	10.01	1.42	74286.67
4	2.66	1.99	52.76	1.26	17.92	9.56	1.43	77228.25
5	2.28	2.10	59.93	1.27	18.44	9.62	1.43	78571.75
6	2.52	2.12	62.17	1.22	18.51	9.84	1.44	79296.58
7	4.36	2.52	59.63	1.74	17.86	9.74	1.45	82057.19
8	5.74	1.90	59.57	1.69	18.35	9.54	1.47	81936.26
9	5.28	1.67	61.34	1.78	18.64	9.36	1.43	81832.24
10	5.25	9.93	54.18	1.72	19.40	9.05	1.43	87077.90
11	6.47	6.96	56.56	1.86	15.94	9.99	1.47	82126.09
12	6.21	2.91	57.84	1.88	15.78	10.31	1.43	78916.30
13	7.57	7.80	58.66	2.27	15.89	10.01	1.42	78670.06
14	10.95	3.56	59.12	3.73	15.02	10.56	1.43	76566.04
15	2.24	2.05	60.62	1.51	16.25	10.83	1.45	76174.89
16	1.01	3.45	58.04	1.26	17.54	9.70	1.43	82008.60
17	3.52	2.43	61.08	1.53	17.80	9.53	1.43	82227.17
18	4.23	7.26	59.45	1.79	18.10	9.49	1.44	84949.82
19	4.96	5.90	54.60	2.13	16.89	9.59	1.46	81419.84
20	4.53	8.65	57.51	1.75	16.72	9.81	1.45	80005.63
21	8.09	6.72	59.73	2.34	15.92	10.02	1.43	78895.83
22	5.83	3.50	57.16	2.22	14.97	10.42	1.43	75634.90
23	4.45	8.75	60.31	2.45	18.08	9.53	1.46	81464.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.91	4.50	58.78	1.90	16.99	9.88	1.44	79768.21
最 大 值	10.95	9.93	62.17	3.73	19.40	10.92	1.48	87077.90
發生時間	14	10	6	14	10	1		10
最 小 值	1.01	1.67	52.76	1.22	13.69	9.05	1.41	74286.67
發生時間	16	9	4	6	1	10		3
零點偏移(率)	-0.10 %	-0.07 %	-0.03 %	-0.00 %		0.00		-0.10 %
全幅偏移(率)	0.02 %	-0.33 %	-0.36 %	-0.01 %		0.13		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								