

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.72	4.41	55.32	0.68	20.58	11.16	1.46	74772.25
1	5.88	5.22	47.02	0.75	20.82	11.40	1.46	72791.74
2	5.36	5.85	42.20	0.97	19.84	11.03	1.44	77006.31
3	10.17	9.55	42.77	1.49	18.98	11.35	1.43	74996.43
4	9.09	5.81	44.58	1.38	19.20	11.26	1.43	75684.87
5	11.51	4.44	45.45	1.94	19.35	11.25	1.40	73549.86
6	9.62	3.94	45.31	1.89	18.86	11.27	1.41	75862.80
7	8.73	4.30	45.45	1.93	18.57	11.40	1.41	74753.24
8	8.99	3.53	49.03	1.53	19.41	10.89	1.43	78308.21
9	9.80	4.30	47.37	2.02	17.36	11.69	1.46	72831.31
10	5.41	3.03	49.49	1.82	17.89	12.25	1.45	68912.76
11	0.99	2.61	56.82	1.66	18.79	12.20	1.40	68805.29
12	7.02	1.23	49.38	1.64	19.49	11.52	1.42	72961.00
13	1.60	1.61	50.36	1.55	18.78	11.68	1.43	72685.14
14	10.58	3.45	45.60	1.81	18.10	11.83	1.41	71678.22
15	2.27	2.33	52.72	1.43	19.49	11.54	1.43	72844.90
16	2.37	2.88	57.00	1.11	20.60	11.13	1.45	74737.32
17	3.71	13.30	50.88	1.46	18.63	11.54	1.46	73420.85
18	6.66	1.37	64.51	1.50	19.61	11.68	1.45	71492.29
19	1.42	7.93	57.84	1.86	19.02	12.94	1.68	62664.56
20	0.42	2.29	49.05	1.60	19.11	12.45	1.48	66236.04
21	2.21	1.58	59.94	1.04	20.96	11.27	1.43	73904.88
22	4.70	1.10	63.81	0.85	21.18	11.35	1.43	72876.51
23	6.32	1.56	41.69	0.69	21.45	10.81	1.41	76719.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.90	4.07	50.57	1.44	19.42	11.54	1.44	72937.36
最大值	11.51	13.30	64.51	2.02	21.45	12.94	2.10	78308.21
發生時間	5	17	18	9	23	19		8
最小值	0.42	1.10	41.69	0.68	17.36	10.81	1.39	62664.56
發生時間	20	22	23	0	9	23		19
零點偏移(率)	-0.28%	-0.01%	-0.04%	-0.00%		0.00	0.00	0.00%
全幅偏移(率)	0.90%	0.03%	-0.35%	0.03%		0.37	-0.03	0.30%
有效比率	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.73	7.61	57.43	1.38	17.48	11.37	1.38	61030.05
1	4.34	1.84	45.72	1.14	18.84	10.15	1.38	66850.98
2	7.84	3.53	49.91	1.95	16.48	10.38	1.38	65424.69
3	9.61	11.99	47.11	2.12	16.29	10.27	1.38	65064.11
4	8.95	8.81	40.68	2.15	15.44	10.23	1.38	62865.32
5	7.68	1.72	46.90	1.88	16.38	10.08	1.38	62723.52
6	4.97	5.06	41.40	1.68	16.57	9.97	1.40	61782.94
7	5.42	2.72	52.09	1.41	17.33	9.82	1.41	63851.76
8	8.38	3.19	52.69	1.79	16.24	9.93	1.42	63180.38
9	10.06	3.32	61.28	1.95	15.44	10.54	1.42	63201.33
10	4.70	2.81	41.53	1.51	16.84	10.09	1.37	60665.64
11	6.76	1.70	44.69	1.55	17.23	10.10	1.39	64915.49
12	5.96	1.71	43.25	1.48	17.30	10.28	1.42	63012.07
13	4.92	1.58	43.42	1.63	16.37	10.55	1.42	62855.31
14	4.15	1.27	49.67	1.45	17.05	10.60	1.39	64553.73
15	1.59	1.14	47.39	1.22	17.61	10.52	1.38	62737.82
16	6.83	2.26	48.58	1.49	17.39	10.48	1.38	63519.48
17	10.29	1.70	47.19	1.59	16.94	10.46	1.39	63963.27
18	4.72	1.19	53.42	1.23	18.03	10.56	1.38	63503.20
19	4.94	0.65	52.55	1.16	17.98	10.59	1.39	64901.10
20	9.94	0.90	58.63	1.38	17.69	10.54	1.40	65890.57
21	7.11	0.64	67.99	1.01	18.92	10.68	1.40	64398.95
22	3.45	0.73	57.83	0.74	19.76	10.09	1.39	67171.89
23	6.51	0.94	60.79	0.79	19.87	10.17	1.38	67355.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.24	2.88	50.51	1.49	17.31	10.35	1.39	63975.79
最大值	10.29	11.99	67.99	2.15	19.87	11.37	1.43	67355.38
發生時間	17	3	21	4	23	0		23
最小值	0.73	0.64	40.68	0.74	15.44	9.82	1.36	60665.64
發生時間	0	21	4	22	4	7		10
零點偏移(率)	-0.02 %	-0.01 %	-0.01 %	-0.05 %		-0.05	0.00	0.00 %
全幅偏移(率)	3.41 %	0.57 %	-0.40 %	0.29 %		0.17	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.02	8.78	55.04	0.83	15.85	11.19	1.83	86338.90
1	6.68	4.67	57.81	1.05	15.22	11.45	1.85	84690.04
2	8.57	6.69	56.46	1.71	13.94	11.54	1.84	84610.30
3	6.95	9.23	57.36	1.21	15.15	11.15	1.83	86995.46
4	6.20	7.63	56.26	1.01	15.52	11.13	1.84	86727.95
5	3.89	2.55	55.86	0.92	15.76	11.17	1.82	86648.02
6	1.86	6.91	63.28	0.78	15.84	11.48	1.84	83584.44
7	5.36	11.11	52.27	1.79	13.97	11.21	1.85	82509.10
8	9.26	4.41	51.82	1.59	14.70	11.21	1.86	86402.31
9	9.19	3.82	50.56	1.34	15.45	10.92	1.85	88401.95
10	4.92	2.00	56.06	1.00	15.51	11.18	1.85	86194.58
11	4.01	7.02	52.76	1.46	14.58	11.23	1.91	85463.44
12	2.51	2.42	54.36	1.18	15.02	11.23	1.86	85484.93
13	1.67	4.94	55.82	1.48	14.48	11.45	1.86	84323.34
14	8.80	2.30	55.96	1.31	15.66	11.28	1.87	85005.28
15	8.11	9.62	57.82	1.49	15.09	11.47	1.86	83832.59
16	4.04	5.29	62.49	1.07	15.85	11.43	1.87	84073.20
17	2.66	5.12	64.09	1.08	16.09	11.31	1.88	84431.05
18	6.99	1.87	67.66	0.90	17.38	11.06	1.88	85266.41
19	5.91	2.24	57.37	0.82	17.25	10.89	1.87	86977.20
20	5.80	2.95	56.65	1.02	15.96	11.16	1.87	85164.63
21	5.11	5.37	60.04	1.14	15.73	11.30	1.87	85037.59
22	5.37	2.81	63.12	1.09	16.25	11.28	1.88	84802.53
23	3.10	1.75	65.56	0.84	18.13	10.77	1.88	87483.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.50	5.06	57.77	1.17	15.60	11.23	1.86	85435.37
最大值	9.26	11.11	67.66	1.79	18.13	11.54	1.95	88401.95
發生時間	8	7	18	7	23	2		9
最小值	1.67	1.75	50.56	0.78	13.94	10.77	1.82	82509.10
發生時間	13	23	9	6	2	23		7
零點偏移(率)	-0.43 %	-0.02 %	-0.14 %	-0.06 %		-0.08	0.00	0.00 %
全幅偏移(率)	2.83 %	0.70 %	-0.42 %	0.44 %		0.28	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								