

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.40	13.20	58.65	2.46	15.78	11.64	1.35	80984.13
1	7.50	13.51	57.26	2.71	15.02	12.05	1.36	77896.88
2	10.28	13.63	56.48	3.21	14.57	12.20	1.34	77492.17
3	10.42	13.62	59.56	3.38	13.70	12.27	1.33	77768.08
4	8.96	13.62	58.63	3.21	13.37	12.33	1.30	77276.40
5	7.36	11.02	47.07	2.60	13.87	12.41	1.29	72843.58
6	7.32	10.97	58.19	4.14	13.78	12.34	1.31	76918.21
7	6.19	10.83	56.43	2.78	14.37	12.19	1.34	77949.08
8	10.08	10.76	47.88	3.79	13.43	12.22	1.34	78599.58
9	3.72	11.26	62.80	2.21	14.65	12.47	1.32	75198.31
10	4.61	10.42	56.63	1.59	16.50	11.52	1.33	81402.24
11	4.31	11.62	50.91	2.58	14.40	12.69	1.30	73064.32
12	0.57	11.42	57.89	1.51	15.46	12.41	1.34	74931.43
13	2.13	10.62	52.82	1.21	16.36	11.62	1.33	80205.53
14	1.33	12.15	60.52	1.43	14.90	12.87	1.36	70876.48
15	7.05	11.43	48.26	1.78	14.24	12.50	1.34	74208.43
16	5.98	14.11	54.10	2.39	14.78	12.66	1.35	73247.50
17	5.27	13.49	57.37	1.65	15.75	11.71	1.32	80220.34
18	7.09	14.13	43.36	3.31	14.09	11.91	1.34	79691.41
19	9.65	14.64	48.66	2.99	15.15	11.72	1.34	80916.13
20	7.08	13.58	47.19	2.90	14.14	11.97	1.32	79603.71
21	11.30	15.41	45.37	3.70	14.96	12.05	1.30	77909.79
22	11.09	13.58	59.57	2.87	15.81	11.80	1.30	79248.03
23	11.44	13.62	44.90	3.01	15.78	11.69	1.29	80008.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.09	12.61	53.77	2.64	14.79	12.14	1.33	77435.85
最 大 值	11.44	15.41	62.80	4.14	16.50	12.87	1.41	81402.24
發生時間	23	21	9	6	10	14		10
最 小 值	0.57	10.42	43.36	1.21	13.37	11.52	1.29	70876.48
發生時間	12	10	18	13	4	10		14
零點偏移(率)	-0.10 %	-0.01 %	-0.02 %	-0.01 %		-0.08	-0.01	0.30 %
全幅偏移(率)	1.23 %	0.62 %	-0.99 %	-0.41 %		-0.01	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

