

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月03日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月03日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	6.24	12.11	43.76	1.05	18.28	10.04	1.07	79595.17
1	4.87	11.57	44.67	1.07	18.62	10.06	1.06	77302.29
2	9.38	11.47	39.19	1.67	16.99	10.15	1.06	77424.74
3	8.98	11.60	37.75	2.31	16.88	10.20	1.06	78991.47
4	9.30	11.75	42.76	2.37	16.33	10.56	1.06	77671.66
5	15.67	11.94	46.44	2.51	16.21	10.63	1.07	78242.22
6	6.78	12.00	49.12	2.19	16.66	10.73	1.09	78801.24
7	11.74	12.91	46.14	2.63	15.86	10.66	1.09	79375.15
8	10.18	13.57	48.70	2.37	15.83	10.90	1.06	77293.16
9	14.99	12.81	40.50	2.18	16.82	10.22	1.06	78943.02
10	10.46	13.19	44.57	2.81	14.85	10.90	1.07	77496.40
11	11.74	13.31	44.58	2.33	15.09	10.98	1.06	77410.09
12	8.99	13.34	55.49	2.64	14.73	11.02	1.06	79598.83
13	8.49	13.61	59.55	2.31	15.46	11.17	1.06	76577.94
14	8.77	14.29	56.16	1.77	16.23	11.34	1.03	70422.16
15	12.64	14.38	37.71	3.61	15.18	10.46	1.02	77328.13
16	5.22	13.21	34.31	2.85	15.40	10.02	1.03	79174.36
17	3.30	10.76	56.15	2.48	15.57	10.79	1.06	78081.25
18	4.42	10.46	47.01	2.15	16.68	10.28	1.06	82038.29
19	4.69	10.87	47.79	1.57	17.10	10.08	1.06	78935.55
20	4.43	10.72	37.49	1.74	17.11	9.93	1.06	79984.60
21	8.20	10.61	33.44	1.73	17.03	9.88	1.06	79656.77
22	4.50	11.49	55.83	2.35	15.42	10.73	1.06	79981.54
23	3.30	11.37	43.24	1.00	17.34	10.14	1.06	73930.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.22	12.22	45.51	2.15	16.32	10.49	1.06	78094.04
最 大 值	15.67	14.38	59.55	3.61	18.62	11.34	1.10	82038.29
發生時間	5	15	13	15	1	14		18
最 小 值	3.30	10.46	33.44	1.00	14.73	9.88	1.02	70422.16
發生時間	17	18	21	23	12	21		14
零點偏移(率)	-0.01 %	-0.19 %	-0.06 %	-0.01 %		-0.01	-0.01	0.10 %
全幅偏移(率)	-0.26 %	-0.10 %	-1.26 %	-1.68 %		0.07	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月03日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.02	12.50	49.73	1.83	16.48	9.74	1.40	73542.08
1	11.52	13.72	55.59	2.42	17.30	10.28	1.40	71093.62
2	12.95	13.33	59.53	2.60	16.77	10.04	1.41	74622.53
3	11.06	13.68	55.88	2.33	16.86	10.33	1.42	74866.90
4	12.07	14.04	52.59	2.23	15.96	10.69	1.43	72861.56
5	11.43	14.83	64.02	2.57	15.84	11.17	1.41	72538.77
6	11.68	14.33	52.87	2.60	15.00	11.02	1.43	73349.11
7	5.06	12.35	42.77	2.57	15.69	10.37	1.39	68340.14
8	12.70	11.58	49.69	2.58	16.38	10.29	1.39	75135.78
9	11.60	11.19	42.90	2.34	16.17	10.04	1.36	73322.94
10	12.22	11.26	57.18	2.95	15.12	10.30	1.36	74077.93
11	11.16	11.26	60.93	2.59	16.02	10.16	1.36	74552.62
12	11.23	12.09	61.07	3.01	14.24	10.81	1.36	72652.50
13	12.22	12.07	57.61	2.86	14.71	10.70	1.36	71459.67
14	11.46	13.21	61.85	3.34	16.44	10.03	1.36	76782.89
15	11.94	12.59	50.46	3.35	13.94	10.57	1.36	71854.05
16	11.99	12.68	53.07	2.53	16.51	9.89	1.36	73778.37
17	12.26	11.71	54.19	2.04	17.35	10.26	1.36	72863.80
18	9.54	12.55	64.07	1.71	16.31	11.18	1.35	67473.34
19	10.47	12.62	62.87	2.24	15.77	11.25	1.36	68355.93
20	10.58	12.36	44.48	2.56	15.42	10.82	1.36	76214.37
21	10.89	12.13	60.25	2.59	14.74	11.00	1.38	72310.46
22	10.80	13.70	51.20	4.62	13.78	10.79	1.37	68376.27
23	12.01	12.92	43.93	1.55	14.45	10.61	1.36	67755.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.29	12.70	54.53	2.58	15.72	10.51	1.38	72424.21
最 大 值	12.95	14.83	64.07	4.62	17.35	11.25	1.46	76782.89
發生時間	2	5	18	22	17	19		14
最 小 值	5.06	11.19	42.77	1.55	13.78	9.74	1.34	67473.34
發生時間	7	9	7	23	22	0		18
零點偏移(率)	-0.04 %	0.01 %	-0.02 %	-0.01 %		-0.04	-0.01	0.00 %
全幅偏移(率)	0.29 %	-1.83 %	0.63 %	-0.64 %		0.21	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								