

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.36	9.17	65.08	1.30	18.09	12.06	1.28	74488.05
1	5.57	9.81	51.97	1.89	19.37	11.06	1.29	81729.83
2	5.31	11.54	52.32	2.51	17.03	11.52	1.29	80018.70
3	4.49	8.33	55.26	2.42	17.98	11.34	1.28	80680.89
4	5.92	8.28	52.93	2.53	16.88	11.45	1.28	80720.81
5	3.88	7.37	57.31	2.81	16.38	11.58	1.29	79400.35
6	3.19	8.07	58.04	3.03	16.16	11.57	1.28	80048.29
7	1.15	9.93	62.98	1.79	17.59	11.55	1.29	79064.18
8	3.83	7.07	62.35	2.86	16.30	11.73	1.29	79510.76
9	1.44	8.15	47.80	3.40	15.70	12.27	1.26	77618.12
10	0.16	7.04	57.93	2.33	16.59	12.20	1.25	78032.25
11	7.99	12.81	54.84	3.97	16.01	11.96	1.25	79626.70
12	5.33	12.29	58.29	1.70	16.53	12.23	1.25	73836.06
13	10.11	13.62	64.88	2.16	16.26	12.00	1.25	76557.99
14	9.44	14.06	57.44	2.44	14.80	12.11	1.26	77372.45
15	8.02	8.90	50.52	1.91	14.86	12.41	1.25	75452.19
16	5.62	11.02	42.77	1.60	15.25	11.98	1.26	78614.83
17	3.66	8.65	48.20	0.79	16.66	11.47	1.26	81045.15
18	4.70	7.43	53.19	1.31	15.36	11.89	1.28	79492.70
19	3.18	9.36	57.83	2.03	16.04	11.70	1.27	81817.55
20	3.37	8.64	67.62	1.47	16.70	11.61	1.27	82312.66
21	3.98	8.45	51.65	1.60	16.63	11.52	1.29	82713.85
22	6.81	8.39	64.56	1.22	17.35	11.56	1.28	81249.90
23	6.49	11.11	57.48	1.18	17.14	11.89	1.28	78779.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.79	9.56	56.38	2.09	16.57	11.78	1.27	79174.34
最 大 值	10.11	14.06	67.62	3.97	19.37	12.41	1.29	82713.85
發生時間	13	14	20	11	1	15		21
最 小 值	0.16	7.04	42.77	0.79	14.80	11.06	1.25	73836.06
發生時間	10	10	16	17	14	1		12
零點偏移(率)	-0.42 %	0.00 %	-0.00 %	-0.00 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	0.51 %	-0.14 %	1.03 %		-0.08		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.98	8.54	56.67	1.75	17.99	11.05	1.43	72491.76
1	2.85	9.08	55.20	1.81	19.09	10.36	1.44	79056.96
2	2.97	9.89	61.01	1.73	19.44	9.44	1.43	80401.06
3	6.51	8.85	58.70	2.10	18.40	9.53	1.46	81675.90
4	3.12	10.75	58.55	1.76	16.60	10.22	1.50	79461.09
5	2.49	9.73	60.27	1.93	16.24	10.29	1.48	77617.59
6	2.28	5.54	58.34	1.84	16.81	10.11	1.48	78855.38
7	0.51	6.61	64.46	2.01	17.17	9.83	1.44	76623.34
8	1.92	7.80	67.31	1.98	17.27	9.79	1.46	78919.98
9	0.95	8.09	65.52	2.02	17.48	9.76	1.43	76901.02
10	2.14	5.57	65.52	2.01	17.14	9.67	1.47	76886.20
11	9.19	5.68	66.35	2.87	18.50	9.18	1.41	76904.99
12	12.79	10.81	64.74	2.82	16.04	9.66	1.39	72509.02
13	6.30	9.75	65.51	2.69	16.15	9.63	1.39	72860.02
14	2.95	7.60	63.78	2.61	15.26	9.78	1.39	70565.57
15	5.82	11.01	66.75	3.77	13.91	10.26	1.39	69641.98
16	7.38	10.91	61.73	3.55	15.66	9.60	1.40	72966.28
17	4.14	8.10	55.00	1.27	15.83	9.62	1.43	73971.35
18	1.76	7.47	60.68	1.09	16.31	9.83	1.41	76120.11
19	9.12	9.89	58.67	2.47	17.77	9.34	1.42	82241.60
20	3.76	10.31	57.00	2.07	17.57	9.18	1.41	76587.48
21	2.84	8.85	54.75	2.02	17.40	9.08	1.39	75432.73
22	5.11	12.18	61.60	2.67	18.69	9.10	1.41	77054.31
23	1.64	7.13	60.70	1.85	17.71	9.82	1.42	74672.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.15	8.76	61.20	2.20	17.10	9.76	1.43	76267.42
最 大 值	12.79	12.18	67.31	3.77	19.44	11.05	1.51	82241.60
發生時間	12	22	8	15	2	0		19
最 小 值	0.51	5.54	54.75	1.09	13.91	9.08	1.38	69641.98
發生時間	7	6	21	18	15	21		15
零點偏移(率)	-0.07 %	-0.00 %	-0.03 %	-0.00 %		-0.11		0.20 %
全幅偏移(率)	0.02 %	0.27 %	-1.19 %	0.20 %		0.27		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								