

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.81	12.45	49.48	5.11	16.56	11.13	1.18	82582.62
1	8.16	13.08	53.69	3.43	17.69	11.06	1.18	83033.92
2	10.87	13.22	61.95	3.14	17.39	11.21	1.20	82071.79
3	18.71	12.96	58.48	3.56	16.79	11.47	1.22	80473.78
4	3.84	13.32	67.53	2.28	17.39	11.62	1.22	78731.20
5	5.98	14.40	50.39	1.41	17.58	11.58	1.23	80097.13
6	8.96	13.76	54.96	3.81	17.16	11.14	1.23	82333.62
7	10.39	13.90	44.50	2.89	18.08	10.64	1.22	85824.79
8	6.72	14.54	50.55	3.92	17.05	11.41	1.20	80796.47
9	15.95	14.22	55.60	5.30	17.00	11.46	1.23	80347.85
10	3.80	14.99	60.37	2.11	16.46	12.06	1.22	75817.44
11	9.09	14.44	45.97	1.35	16.99	11.65	1.21	79056.42
12	6.59	14.22	46.62	1.19	17.52	11.44	1.20	80107.77
13	9.74	14.16	51.90	1.73	16.99	11.47	1.20	80439.86
14	9.14	14.05	58.59	1.61	18.23	11.21	1.21	80887.46
15	9.52	13.56	54.81	1.67	17.90	10.92	1.20	83647.48
16	8.85	13.70	56.59	1.78	18.31	10.98	1.20	82823.36
17	10.48	13.75	58.66	2.01	18.53	10.97	1.20	82290.24
18	6.62	14.13	63.69	1.53	18.01	11.41	1.21	79553.93
19	9.93	12.47	58.34	2.76	18.49	10.83	1.22	83773.73
20	11.20	12.67	51.47	3.08	17.14	11.13	1.22	82592.53
21	8.54	12.73	59.94	1.34	17.42	11.18	1.21	82109.43
22	7.49	13.35	61.92	1.15	17.91	11.57	1.21	78548.34
23	9.26	13.05	56.29	1.93	18.90	11.16	1.22	80395.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.28	13.63	55.51	2.50	17.56	11.28	1.21	81180.68
最大值	18.71	14.99	67.53	5.30	18.90	12.06	1.24	85824.79
發生時間	3	10	4	9	23	10		7
最小值	3.80	12.45	44.50	1.15	16.46	10.64	1.18	75817.44
發生時間	10	0	7	22	10	7		10
零點偏移(率)	-0.03 %	-0.05 %	-0.04 %	-0.00 %		-0.02	-0.01	0.10 %
全幅偏移(率)	0.86 %	-0.70 %	-0.08 %	-0.30 %		-0.14	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.52	12.49	56.24	1.40	17.34	11.07	0.98	80004.90
1	1.99	12.35	63.47	1.33	18.75	10.55	0.99	84488.75
2	1.38	12.37	50.83	1.45	17.53	10.95	1.00	83120.57
3	4.10	12.11	54.41	1.17	17.47	10.81	0.99	84279.37
4	3.01	12.11	48.66	0.83	18.30	10.70	1.00	84037.67
5	2.62	12.37	48.56	0.86	17.21	11.04	0.99	80153.12
6	0.57	11.19	54.28	1.26	19.53	9.66	0.97	80055.12
7	0.99	12.24	53.00	1.25	17.15	10.96	0.97	80694.91
8	1.39	12.27	52.19	1.03	18.27	10.84	0.96	79672.56
9	0.42	12.31	60.52	0.32	19.97	10.56	0.98	80453.99
10	0.36	12.10	31.75	0.67	19.39	10.29	0.97	81777.90
11	0.68	12.09	46.49	0.95	19.21	10.51	0.97	82724.35
12	0.57	12.11	49.54	1.49	17.32	10.83	0.98	80135.16
13	0.22	12.85	56.50	1.41	17.66	10.77	0.97	80580.32
14	0.14	12.11	56.32	0.87	18.06	10.82	0.95	82483.60
15	0.28	12.32	62.13	1.64	17.89	10.93	0.94	80437.76
16	0.43	11.97	53.73	0.57	19.57	10.39	0.94	82370.91
17	0.26	12.42	55.02	0.98	18.67	10.85	0.94	82455.45
18	0.22	12.10	60.66	0.35	19.88	10.46	0.95	85071.46
19	0.23	12.44	46.32	0.58	19.49	10.23	0.95	84965.72
20	0.59	12.22	61.26	0.71	19.49	10.53	0.97	84302.40
21	0.27	12.29	46.23	1.06	18.73	10.67	0.97	84105.71
22	0.23	12.64	58.28	1.19	18.24	11.05	0.96	80536.26
23	0.25	12.51	60.27	0.89	19.11	10.83	0.97	80205.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	0.95	12.25	53.61	1.01	18.51	10.68	0.97	82046.38
最大值	4.10	12.85	63.47	1.64	19.97	11.07	1.02	85071.46
發生時間	3	13	1	15	9	0		18
最小值	0.14	11.19	31.75	0.32	17.15	9.66	0.94	79672.56
發生時間	14	6	10	9	7	6		8
零點偏移(率)	-0.11 %	0.00 %	-0.26 %	-0.01 %		-0.01	-0.01	-0.20 %
全幅偏移(率)	2.14 %	-0.63 %	0.01 %	-1.31 %		0.15	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.76	12.58	46.27	2.89	19.31	9.39	1.39	78974.03
1	9.78	12.27	58.79	3.24	18.43	9.87	1.39	76368.47
2	5.13	12.61	57.89	2.93	18.71	10.19	1.36	75363.96
3	6.00	12.06	63.90	3.23	19.64	9.50	1.35	75738.67
4	4.22	12.23	58.12	3.13	17.02	9.94	1.35	76162.80
5	6.41	12.56	67.07	3.20	18.91	10.11	1.36	76853.71
6	3.80	12.60	50.88	2.84	17.91	10.28	1.36	75248.13
7	3.51	10.87	56.79	3.15	20.33	9.33	1.38	72809.34
8	3.49	11.11	32.27	3.05	20.08	9.66	1.40	69757.55
9	2.43	11.21	56.08	2.85	19.72	9.79	1.36	67610.52
10	2.27	12.21	65.02	2.74	18.94	10.69	1.40	62255.36
11	2.25	12.23	54.09	2.72	19.88	10.39	1.35	63176.47
12	3.36	11.69	48.25	4.10	19.13	8.44	1.32	80515.32
13	2.30	12.10	42.61	1.72	17.56	8.89	1.35	76818.42
14	2.09	12.76	37.70	5.45	19.79	8.48	1.34	74987.45
15	2.73	11.62	42.57	2.41	19.09	8.67	1.36	72858.54
16	4.96	12.19	41.16	2.53	18.60	9.19	1.36	74820.91
17	3.41	13.37	42.98	2.33	18.81	9.24	1.36	74596.56
18	3.86	12.37	45.12	2.37	19.89	8.90	1.35	75138.91
19	2.71	12.92	63.89	2.59	19.87	9.40	1.36	74085.66
20	2.79	12.49	54.71	2.48	19.89	8.96	1.36	74644.94
21	3.05	11.95	54.34	2.23	20.87	8.60	1.36	77633.83
22	3.64	11.04	56.63	2.40	21.12	8.75	1.37	76093.51
23	5.43	10.93	52.91	2.63	20.97	8.74	1.36	77971.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.97	12.08	52.09	2.88	19.35	9.39	1.36	74186.84
最大值	9.78	13.37	67.07	5.45	21.12	10.69	1.43	80515.32
發生時間	1	17	5	14	22	10		12
最小值	2.09	10.87	32.27	1.72	17.02	8.44	1.31	62255.36
發生時間	14	7	8	13	4	12		10
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	0.00 %		-0.04	-0.01	-0.20 %
全幅偏移(率)	1.68 %	-0.18 %	1.98 %	0.38 %		0.27	0.04	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								