

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.43	2.51	62.62	3.28	14.23	12.58	1.41	68293.27
1	3.34	0.89	62.93	1.93	17.44	11.99	1.41	70222.91
2	5.47	1.43	47.43	2.22	16.73	11.87	1.41	71745.28
3	8.41	2.20	50.95	2.93	15.30	12.18	1.41	70829.04
4	8.44	2.95	58.55	2.88	15.29	12.31	1.41	69541.75
5	4.08	3.95	67.04	2.71	15.63	12.35	1.38	67750.49
6	4.18	2.13	64.29	2.72	15.52	12.35	1.39	68976.27
7	2.67	1.92	65.45	2.75	15.21	12.36	1.38	69637.69
8	1.59	2.77	60.58	3.16	14.37	12.54	1.38	68541.95
9	4.49	7.20	56.13	3.33	14.41	12.38	1.39	69750.14
10	8.65	3.90	72.00	3.32	14.49	12.40	1.42	69364.99
11	4.23	5.24	73.56	2.90	15.17	12.57	1.45	67438.82
12	6.71	6.28	56.03	3.10	14.73	12.45	1.45	69088.85
13	7.90	3.96	66.96	2.96	15.09	12.37	1.42	68880.13
14	2.74	3.32	63.54	2.51	15.67	12.26	1.45	69224.40
15	5.32	2.18	58.50	2.58	15.91	11.91	1.46	72066.80
16	7.30	2.94	59.19	2.77	15.91	11.89	1.45	73047.78
17	3.40	3.21	62.34	1.73	18.72	11.61	1.44	72394.21
18	0.74	1.70	64.11	1.25	20.64	11.20	1.41	74798.38
19	0.66	1.81	57.83	1.29	20.60	11.17	1.39	75818.91
20	1.28	2.18	58.12	1.30	20.40	11.01	1.39	76881.57
21	8.16	2.77	57.01	1.79	19.26	11.23	1.38	76267.31
22	7.91	4.00	64.35	1.89	19.55	11.60	1.38	73097.49
23	6.15	1.99	62.85	1.34	20.83	11.01	1.40	76498.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.01	3.06	61.35	2.44	16.71	11.98	1.41	71256.54
最大值	8.65	7.20	73.56	3.33	20.83	12.58	1.46	76881.57
發生時間	10	9	11	9	23	0		20
最小值	0.66	0.89	47.43	1.25	14.23	11.01	1.37	67438.82
發生時間	19	1	2	18	0	20		11
零點偏移(率)	-0.01 %	-0.12 %	-0.01 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	3.00 %	1.00 %	-0.81 %	0.33 %		0.03	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.42	2.01	49.07	0.97	19.49	10.09	1.42	66778.27
1	6.93	1.41	57.57	0.95	19.54	10.24	1.41	65394.72
2	9.40	0.95	64.36	1.16	19.42	10.27	1.42	65497.11
3	8.88	1.06	49.19	1.42	18.80	10.20	1.41	65412.81
4	9.09	0.69	53.62	1.30	19.57	10.00	1.42	66494.64
5	10.00	1.69	62.95	1.43	18.70	10.24	1.41	66205.78
6	6.15	1.04	58.05	1.30	18.30	10.20	1.44	66737.61
7	5.58	0.82	64.42	1.32	17.89	10.49	1.44	62876.12
8	3.72	0.43	63.20	0.98	18.74	10.55	1.44	63532.68
9	2.65	0.72	65.42	1.18	17.88	10.91	1.45	61124.84
10	6.56	0.90	61.74	1.69	16.99	10.71	1.48	64157.46
11	9.55	0.84	60.74	1.87	16.64	10.76	1.44	64444.44
12	8.51	2.16	61.35	1.97	16.56	10.60	1.41	63178.88
13	11.61	3.55	64.42	2.35	15.82	10.90	1.41	64301.33
14	10.44	1.20	70.53	1.66	16.99	10.57	1.41	63956.97
15	9.76	1.63	60.61	1.45	17.63	10.42	1.41	64410.62
16	7.94	0.88	56.61	1.32	17.68	10.24	1.43	65977.83
17	6.08	2.12	68.04	1.30	17.30	10.79	1.48	64302.72
18	8.99	1.67	47.54	1.44	17.28	10.50	1.47	65472.39
19	6.76	2.81	44.97	1.37	17.12	10.43	1.45	65676.38
20	4.79	2.83	51.35	1.32	17.41	10.73	1.44	63521.38
21	4.58	1.23	45.03	0.97	19.35	10.06	1.43	66710.69
22	3.41	2.09	51.48	0.92	18.94	10.32	1.41	65768.29
23	3.85	10.30	60.10	1.01	18.68	10.06	1.41	65163.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.24	1.88	58.01	1.36	18.03	10.43	1.43	64879.06
最大值	11.61	10.30	70.53	2.35	19.57	10.91	1.49	66778.27
發生時間	13	23	14	13	4	9		0
最小值	2.65	0.43	44.97	0.92	15.82	10.00	1.40	61124.84
發生時間	9	8	19	22	13	4		9
零點偏移(率)	-0.01 %	-0.12 %	-0.01 %	-0.03 %		-0.10	0.00	0.00 %
全幅偏移(率)	2.54 %	1.54 %	-0.02 %	0.45 %		0.07	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.60	2.97	57.80	1.21	17.42	10.73	1.80	87223.20
1	1.97	3.43	56.67	1.21	18.59	10.39	1.80	87385.08
2	2.23	1.90	63.90	1.28	18.63	10.40	1.80	88421.07
3	6.94	7.74	53.98	1.51	17.90	10.43	1.80	90027.25
4	6.38	1.24	62.37	1.45	17.74	10.72	1.80	86356.29
5	3.89	1.80	61.14	1.42	17.87	10.59	1.80	87231.91
6	7.43	1.72	61.00	1.68	17.43	10.80	1.80	85649.31
7	7.30	1.44	60.84	1.61	17.43	10.66	1.80	83096.51
8	6.34	2.15	66.41	1.98	16.56	11.30	1.81	82168.22
9	7.20	2.57	56.80	1.84	18.06	10.54	1.81	83380.87
10	8.67	0.86	58.88	1.91	16.58	10.63	1.81	84408.10
11	10.17	1.47	60.91	1.90	16.97	10.62	1.84	85247.90
12	9.90	1.38	61.41	1.88	17.07	10.60	1.85	85255.94
13	10.20	3.29	56.25	2.38	15.63	10.71	1.85	83136.35
14	9.16	3.45	64.18	2.30	15.80	10.99	1.83	79560.44
15	11.14	2.92	53.82	1.60	17.48	10.44	1.85	84779.50
16	8.39	0.97	64.48	1.86	16.07	11.07	1.82	85892.59
17	9.31	0.58	63.61	1.64	18.54	10.49	1.81	88627.94
18	9.55	0.57	61.93	1.64	17.93	10.67	1.80	86889.73
19	7.37	3.12	55.94	1.81	16.42	10.59	1.80	85021.52
20	3.88	4.42	59.46	1.97	15.34	10.97	1.80	80883.74
21	6.27	0.64	63.34	1.57	17.19	10.70	1.81	85774.92
22	8.34	0.79	55.96	1.59	17.61	10.52	1.80	85979.69
23	6.72	7.90	62.04	1.51	18.48	10.30	1.80	87246.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.10	2.47	60.13	1.70	17.28	10.66	1.81	85401.87
最大值	11.14	7.90	66.41	2.38	18.63	11.30	1.86	90027.25
發生時間	15	23	8	13	2	8		3
最小值	1.60	0.57	53.82	1.21	15.34	10.30	1.80	79560.44
發生時間	0	18	15	0	20	23		14
零點偏移(率)	-0.11 %	-0.08 %	-0.00 %	-0.02 %		0.00	0.00	0.00 %
全幅偏移(率)	1.45 %	0.88 %	-0.51 %	0.32 %		0.19	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								