

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.57	5.15	46.96	1.14	17.34	12.08	1.05	76625.42
1	7.35	0.31	37.08	1.20	17.37	11.26	1.02	83948.42
2	7.64	3.88	38.45	1.32	17.55	11.31	1.02	83429.19
3	8.73	4.49	45.00	1.01	16.78	11.64	1.02	81494.01
4	9.20	8.06	44.25	0.94	18.45	10.21	1.02	92062.95
5	10.04	11.00	46.31	1.71	16.84	11.36	0.99	84329.50
6	7.73	4.65	59.08	1.21	16.18	12.33	0.98	76191.28
7	6.72	5.37	51.83	1.16	18.09	10.97	0.99	85191.35
8	3.77	6.32	48.05	0.84	17.15	11.79	1.00	79923.69
9	2.74	6.45	51.36	0.60	17.50	12.23	1.01	76011.73
10	3.70	4.71	52.69	0.22	18.71	11.33	1.00	82750.64
11	5.17	5.28	43.44	0.73	17.62	11.48	0.97	81843.37
12	9.20	6.08	40.27	1.14	16.52	11.73	0.98	80626.10
13	6.72	6.72	45.69	0.82	16.76	11.93	1.00	78872.50
14	7.05	7.86	46.70	0.79	17.70	11.29	0.99	83115.98
15	7.41	5.93	50.22	0.73	18.08	11.87	1.00	77881.95
16	2.27	7.82	46.16	0.40	19.41	10.72	1.01	86161.65
17	5.03	6.82	44.52	0.88	17.24	11.36	1.01	83039.47
18	5.65	7.34	48.22	0.61	17.42	11.23	1.01	84283.09
19	5.01	7.02	56.57	0.36	18.06	11.01	0.98	85452.01
20	7.07	7.79	43.63	1.11	17.04	11.26	0.97	84219.34
21	3.17	7.28	53.88	0.47	17.71	11.43	0.97	82149.60
22	3.46	8.76	61.20	0.48	18.04	11.93	0.98	77715.15
23	1.09	7.48	51.47	0.30	19.19	10.84	0.99	85712.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.77	6.36	48.04	0.84	17.61	11.44	1.00	82209.61
最大值	10.04	11.00	61.20	1.71	19.41	12.33	1.10	92062.95
發生時間	5	5	22	5	16	6		4
最小值	1.09	0.31	37.08	0.22	16.18	10.21	0.97	76011.73
發生時間	23	1	1	10	6	4		9
零點偏移(率)	-0.05 %	-0.01 %	-0.03 %	-0.01 %		-0.09		-0.10 %
全幅偏移(率)	0.00 %	-0.06 %	-0.40 %	-0.25 %		-0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.48	3.69	39.86	2.51	17.18	11.74	1.04	73732.26
1	3.58	0.21	34.19	1.78	19.34	10.40	1.04	81783.81
2	6.81	9.76	39.41	3.36	18.48	9.93	1.04	86716.86
3	8.38	5.43	33.12	3.35	14.84	11.57	1.02	76907.23
4	4.60	5.21	33.05	2.45	16.22	11.42	1.02	77715.08
5	3.18	7.38	48.31	2.59	15.92	12.02	1.02	73113.28
6	5.92	8.73	40.57	3.81	14.88	11.65	1.03	83587.21
7	5.20	2.85	38.59	2.38	16.35	11.26	1.04	78884.88
8	8.58	2.80	42.81	1.95	17.15	11.20	1.03	78555.94
9	6.99	3.78	29.87	2.35	16.14	11.25	1.04	79294.18
10	4.83	2.57	40.63	2.58	15.48	11.49	1.04	76693.20
11	1.82	2.70	52.08	1.66	16.47	11.49	1.02	76343.48
12	7.62	4.38	42.84	2.76	15.06	11.30	1.03	78835.56
13	8.61	3.29	44.34	2.16	15.42	11.55	1.03	76673.69
14	7.72	3.41	49.08	2.01	15.60	11.62	1.03	76090.05
15	3.73	3.02	58.21	1.57	17.07	10.91	1.04	80248.64
16	5.24	3.38	36.91	1.54	17.53	10.58	1.02	81923.90
17	3.07	6.26	48.92	1.00	17.86	10.78	1.03	79951.08
18	5.66	5.26	42.86	2.29	16.79	10.79	1.02	81045.00
19	4.35	7.28	57.79	1.39	17.40	11.01	1.02	78799.72
20	8.61	7.53	49.62	2.28	18.01	10.45	1.03	82535.52
21	9.55	6.78	50.82	1.76	17.95	10.52	1.03	82238.25
22	7.80	6.66	61.58	1.37	18.12	10.99	1.04	78984.03
23	10.23	7.37	60.54	1.85	19.21	10.47	1.04	82060.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.02	4.99	44.83	2.20	16.85	11.10	1.03	79279.70
最大值	10.23	9.76	61.58	3.81	19.34	12.02	1.05	86716.86
發生時間	23	2	22	6	1	5		2
最小值	1.82	0.21	29.87	1.00	14.84	9.93	1.02	73113.28
發生時間	11	1	9	17	3	2		5
零點偏移(率)	-0.09 %	-0.01 %	-0.04 %	-0.01 %		-0.04		-0.10 %
全幅偏移(率)	0.14 %	0.13 %	0.14 %	0.14 %		-0.19		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.27	3.44	38.16	0.23	18.16	10.20	1.02	82316.59
1	4.72	2.65	40.65	0.41	17.52	10.45	0.99	80960.91
2	4.46	4.47	40.26	0.65	17.98	9.98	0.99	84211.86
3	9.53	1.57	38.46	0.77	15.64	10.51	0.99	79024.71
4	3.88	3.03	40.70	0.27	17.01	10.15	0.99	80302.22
5	2.26	4.09	34.80	0.18	16.66	10.23	0.99	76733.92
6	6.07	7.29	35.34	0.70	17.36	10.03	1.02	77490.99
7	0.89	9.01	47.17	0.13	17.81	10.35	1.04	80810.17
8	2.81	4.50	45.24	0.31	19.31	9.93	1.03	78863.29
9	5.08	6.60	39.03	1.24	18.72	10.47	1.01	79945.87
10	3.56	8.95	52.38	0.57	20.07	10.32	1.02	83337.64
11	0.63	4.46	51.67	0.15	17.52	10.82	1.04	79424.66
12	1.77	8.67	53.87	0.24	17.02	11.10	0.99	78506.56
13	1.92	9.08	54.54	0.20	17.14	11.21	1.00	76837.07
14	0.18	8.30	48.91	0.13	18.84	10.71	1.03	79330.90
15	1.11	8.93	37.21	0.15	18.41	10.36	1.02	78126.28
16	0.09	4.75	40.94	0.14	17.27	10.70	1.00	78047.95
17	0.01	3.20	48.52	0.12	18.57	9.79	0.99	81195.87
18	0.59	3.93	50.96	0.15	18.85	9.87	1.02	82336.57
19	1.32	4.15	52.03	0.15	19.58	9.70	1.03	83349.43
20	1.32	2.22	52.00	0.13	19.35	9.72	0.99	83923.51
21	1.34	2.17	54.69	0.20	18.32	10.04	0.99	82711.49
22	1.55	2.06	59.12	0.21	17.73	10.43	0.99	78909.45
23	1.40	1.98	54.02	0.19	18.61	10.39	1.02	80589.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.45	4.98	46.28	0.32	18.06	10.31	1.01	80303.65
最大值	9.53	9.08	59.12	1.24	20.07	11.21	1.04	84211.86
發生時間	3	13	22	9	10	13		2
最小值	0.01	1.57	34.80	0.12	15.64	9.70	0.99	76733.92
發生時間	17	3	5	17	3	19		5
零點偏移(率)	-0.08 %	-0.00 %	-0.02 %	-0.01 %		-0.07		0.20 %
全幅偏移(率)	0.02 %	0.19 %	-0.32 %	0.65 %		-0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								